Specifications



Photo is representative

Eaton 104548

Eaton Moeller series NZM - Molded Case Circuit Breaker. Interlock, mechanical, for remote operator, 2

| General specifications | |
|-------------------------|---------------------------------------------|
| PRODUCT NAME | Eaton Moeller series NZM mounting accessory |
| CATALOG NUMBER | 104548 |
| MODEL CODE | NZM2-XMVRL |
| EAN | 4015081043668 |
| PRODUCT LENGTH/DEPTH | 260 mm |
| PRODUCT HEIGHT | 100 mm |
| PRODUCT WIDTH | 220 mm |
| PRODUCT WEIGHT | 0.9 kg |
| COMPLIANCES | IEC RoHS conform |
| GLOBAL CATALOG | 104548 |



| Product specifications | |
|----------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------|
| USED WITH | Mechanical interlock NZM2(-4) N(S)2(-4) Accessory N2 N2-4 NS2 NZM2 NZM2-4 NZM2-4 NZM2-4-NA NZM2-NA |
| 10.10 TEMPERATURE RISE | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 SHORT-CIRCUIT RATING | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 ELECTROMAGNETIC COMPATIBILITY | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 MECHANICAL FUNCTION | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |
| 10.2.2 CORROSION RESISTANCE | Meets the product standard's requirements. |
| 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES | Meets the product standard's requirements. |
| 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT | Meets the product standard's requirements. |
| 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS | Meets the product standard's requirements. |
| 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION | Meets the product standard's requirements. |
| 10.2.5 LIFTING | Does not apply, since the entire switchgear needs to |

| Resources | |
|------------------------------|--------------------------------------------------------------------------------|
| BROCHURES | eaton-feerum-the-whole- grain-solution-success- story-en-us.pdf |
| | eaton-digital-nzm- brochure-br013003en-en- us.pdf |
| CATALOGS | eaton-digital-nzm-catalog- ca013003en-en-us.pdf |
| DRAWINGS | eaton-circuit-breaker- mechanical-interlock-nzm- mccb-3d-drawing.eps |
| | eaton-circuit-breaker- mechanical-interlock-nzm- mccb-3d-drawing-002.eps |
| INSTALLATION INSTRUCTIONS | eaton-mechanical- interlock-nzm2-remote- operator-il01219035z.pdf |
| INSTALLATION VIDEOS | The new digital NZM Range Introduction of the new |
| | digital circuit breaker NZM |
| MCAD MODEL | DA-CD-nzm_xmvr_I DA-CS-nzm_xmvr_I |
| TECHNICAL DATA SHEETS | eaton-nzm-technical- information-sheet |

| | be evaluated. |
|----------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------|
| 10.2.6 MECHANICAL IMPACT | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 INSCRIPTIONS | Meets the product standard's requirements. |
| 10.3 DEGREE OF PROTECTION OF ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 CLEARANCES AND CREEPAGE DISTANCES | Meets the product standard's requirements. |
| 10.5 PROTECTION AGAINST ELECTRIC SHOCK | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS | ls the panel builder's responsibility. |
| 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS | ls the panel builder's responsibility. |
| 10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH | ls the panel builder's responsibility. |
| 10.9.3 IMPULSE WITHSTAND VOLTAGE | ls the panel builder's responsibility. |
| 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL | ls the panel builder's responsibility. |
| FRAME | NZM2 |
| ACCESSORY/SPARE PART TYPE | Remote operator |
| NUMBER OF CONTACTS (NORMALLY CLOSED CONTACTS) | 0 |
| NUMBER OF CONTACTS (NORMALLY OPEN CONTACTS) | 0 |
| ТҮРЕ | AccessoryMechanical interlock |
| SPECIAL FEATURES | For 2 switches of the same or next frame size with each other Extra long bowden |

cables for mounting under one another or in adjacent control panel sections

| PROJECT NAME: | |
|-----------------|--|
| PROJECT NUMBER: | |
| PREPARED BY: | |
| DATE: | |



Eaton Corporation plc

Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









