Specifications



Photo is representative

Eaton 107842

Eaton Moeller series NZM - Molded Case Circuit Breaker. Circuit-breaker, 3p, 250A, box terminals, H2-VEF250-BT-NA

General specifications	
PRODUCT NAME	Eaton Moeller series NZM - Molded case circuit breaker
CATALOG NUMBER	107842
MODEL CODE	NZMH2-VEF250-BT-NA
EAN	4015081074921
PRODUCT LENGTH/DEPTH	149 mm
PRODUCT HEIGHT	195 mm
PRODUCT WIDTH	105 mm
PRODUCT WEIGHT	2.345 kg
COMPLIANCES	RoHS conform
CERTIFICATIONS	UL/CSA CSA (Class No. 1432-01) CSA certified UL (Category Control Number DIVQ) UL (File No. E31593) IEC IEC 60947-2 Specially designed for North America UL listed UL 489 CSA (File No. 22086) CE marking IEC/EN 60947 CSA-C22.2 No. 5-09



Product specifications	
AMPERAGE RATING	250 A
VOLTAGE RATING	690 V - 690 V
CIRCUIT BREAKER FRAME TYPE	NZM2
FEATURES	Protection unit Motor drive optional
10.10 TEMPERATURE RISE	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Meets the product standard's requirements.
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to

Resources	
BROCHURES	eaton-feerum-the-whole-grain-solution-success-story-en-us.pdf eaton-digital-nzm-brochure-br013003en-en-us.pdf
CATALOGUES	eaton-digital-nzm-catalog- ca013003en-en-us.pdf
CHARACTERISTIC CURVE	eaton-circuit-breaker-nzm-mccb-characteristic-curve-044.eps eaton-circuit-breaker-nzm-mccb-characteristic-curve-054.eps eaton-circuit-breaker-curve-current-nzm-mccb-
	characteristic-curve- 007.eps
DECLARATIONS OF CONFORMITY	eaton-molded-case-circuit- breaker-declaration-of- conformity- eu250291en.pdf
DRAWINGS	eaton-circuit-breaker- switch-nzm-mccb- dimensions-017.eps eaton-circuit-breaker-nzm-
INSTALLATION INSTRUCTIONS	eaton-circuit-breakers-basic-device-nzm2-il01206006z.pdf
INSTALLATION VIDEOS	Introduction of the new digital circuit breaker NZM The new digital NZM Range
MCAD MODEL	DA-CD-nzm2 3p DA-CS-nzm2 3p
TECHNICAL DATA SHEETS	eaton-nzm-technical- information-sheet

	be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	ls the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	Is the panel builder's responsibility.
10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH	ls the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	Is the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	ls the panel builder's responsibility.
POLLUTION DEGREE	3
MOUNTING METHOD	DIN rail (top hat rail) mounting optional Fixed Built-in device fixed built- in technique
CLIMATIC PROOFING	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78
EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT	51.56 W
UTILIZATION CATEGORY	A (IEC/EN 60947-2)
ISOLATION	300 V AC (between the auxiliary contacts) 500 V AC (between auxiliary contacts and main contacts)
AMBIENT OPERATING TEMPERATURE - MAX	70 °C
AMBIENT OPERATING	-25 °C

TEMPERATURE - MIN	
AMBIENT STORAGE TEMPERATURE - MAX	70 °C
AMBIENT STORAGE TEMPERATURE - MIN	40 °C
LOW-VOLTAGE HBC FUSE - MAX	355 A gG/gL
NUMBER OF AUXILIARY CONTACTS (CHANGE- OVER CONTACTS)	0
NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)	0
NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)	0
PROTECTION AGAINST DIRECT CONTACT	Finger and back-of-hand proof to DIN EN 50274/VDE 0106 part 110
DEGREE OF PROTECTION	IP20 IP20 (basic degree of protection, in the operating controls area)
DIRECTION OF INCOMING SUPPLY	As required
ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT	Frame clamp
LIFESPAN, MECHANICAL	20000 operations
OVERVOLTAGE CATEGORY	III
RATED OPERATIONAL CURRENT	250 A (690 V AC-1, making and breaking capacity) 300 A (380/400 V AC-1, making and breaking capacity) 300 A (415 V AC-1, making and breaking capacity) 250 A (660-690 V AC-3, making and breaking capacity)
DEGREE OF PROTECTION (IP), FRONT SIDE	IP66 (with door coupling rotary handle) IP40 (with insulating surround)
DEGREE OF PROTECTION (TERMINATIONS)	IP00 (terminations, phase isolator and strip terminal)
NUMBER OF DOI: 50	IP10 (tunnel terminal)
NUMBER OF POLES	Three-pole

TERMINAL CAPACITY (COPPER STRIP)	Min. 2 segments of 9 mm x 0.8 mm at box terminal Min. 2 segements of 16 mm x 0.8 mm at rear-side connection (punched) Max. 10 segments of 16 mm x 0.8 mm at box terminal Max. 10 segments of 16 mm x 0.8 mm at rear-side connection (punched)
LIFESPAN, ELECTRICAL	6500 operations at 415 V AC-3 5000 operations at 690 V AC-3 10000 operations at 400 V AC-1 7500 operations at 690 V AC-1 6500 operations at 400 V AC-3
FUNCTIONS	Systems, cable, selectivity and generator protection Current limiting circuit breaker
ТҮРЕ	Circuit breaker
SPECIAL FEATURES	 Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit breaking capacity lcn) Rated current = rated uninterrupted current: 250 A Switches conform to UL/CSA as well as the IEC regulations. IEC switching performance values are contained on the rating plate. Fixed overload releases Ir R.m.s. value

	measurement and "thermal memory" adjustable time delay setting to overcome current peaks tr: 2 - 20 s at 6 x lr Adjustable delay time tsd: Steps: 0, 20, 60, 100, 200, 300, 500, 750, 1000 ms i²t constant function: fixed OFF
APPLICATION	 Branch circuits, feeder circuits Use in unearthed supply systems at 690 V
SHOCK RESISTANCE	20 g (half-sinusoidal shock 20 ms)
POSITION OF CONNECTION FOR MAIN CURRENT CIRCUIT	
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	250 A
POWER LOSS	51.56 W
RELEASE SYSTEM	Electronic release
SHORT-CIRCUIT TOTAL BREAKTIME	< 10 ms
RATED SHORT-TIME WITHSTAND CURRENT (T = 0.3 S)	1.9 kA
RATED SHORT-TIME WITHSTAND CURRENT (T = 1 S)	1.9 kA
SHORT-CIRCUIT RELEASE DELAYED SETTING - MAX	2500 A
SHORT-CIRCUIT RELEASE DELAYED SETTING - MIN	500 A
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MAX	3000 A
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MIN	3000 A
TERMINAL CAPACITY	14 mm ² - 18 mm ² (1x)

(CONTROL CABLE)	16 mm ² - 18 mm ² (2x)
TERMINAL CAPACITY (COPPER BUSBAR)	Max. 20 mm x 5 mm direct at switch rear-side connection Min. 16 mm x 5 mm direct at switch rear-side connection M8 at rear-side screw connection
TERMINAL CAPACITY (COPPER SOLID CONDUCTOR/CABLE)	16 mm² (1x) at tunnel terminal 6 mm² - 12 mm² (1x) at box terminal 6 mm² - 11 mm² (1x) direct at switch rear-side connection
TERMINAL CAPACITY (ALUMINUM SOLID CONDUCTOR/CABLE)	16 mm² (1x) at tunnel terminal
TERMINAL CAPACITY (COPPER STRANDED CONDUCTOR/CABLE)	4 mm ² - 350 mm ² (1x) at tunnel terminal 4 mm ² - 3/0 mm ² (1x) direct at switch rear-side connection 4 mm ² - 350 mm ² (1x) at box terminal
HANDLE TYPE	Da alvari lavvari
MAINULE ITPE	Rocker lever
SHORT DELAY CURRENT SETTING (ISD) - MAX	2500 A
SHORT DELAY CURRENT	
SHORT DELAY CURRENT SETTING (ISD) - MAX SHORT DELAY CURRENT	2500 A
SHORT DELAY CURRENT SETTING (ISD) - MAX SHORT DELAY CURRENT SETTING (ISD) - MIN INSTANTANEOUS CURRENT SETTING (II) -	2500 A 500 A 3000 A
SHORT DELAY CURRENT SETTING (ISD) - MAX SHORT DELAY CURRENT SETTING (ISD) - MIN INSTANTANEOUS CURRENT SETTING (II) - MAX INSTANTANEOUS CURRENT SETTING (II) -	2500 A 500 A 3000 A
SHORT DELAY CURRENT SETTING (ISD) - MAX SHORT DELAY CURRENT SETTING (ISD) - MIN INSTANTANEOUS CURRENT SETTING (II) - MAX INSTANTANEOUS CURRENT SETTING (II) - MIN NUMBER OF OPERATIONS PER HOUR -	2500 A 500 A 3000 A
SHORT DELAY CURRENT SETTING (ISD) - MAX SHORT DELAY CURRENT SETTING (ISD) - MIN INSTANTANEOUS CURRENT SETTING (II) - MAX INSTANTANEOUS CURRENT SETTING (II) - MIN NUMBER OF OPERATIONS PER HOUR - MAX OVERLOAD CURRENT	2500 A 500 A 3000 A 3000 A
SHORT DELAY CURRENT SETTING (ISD) - MAX SHORT DELAY CURRENT SETTING (ISD) - MIN INSTANTANEOUS CURRENT SETTING (II) - MAX INSTANTANEOUS CURRENT SETTING (II) - MIN NUMBER OF OPERATIONS PER HOUR - MAX OVERLOAD CURRENT SETTING (IR) - MAX OVERLOAD CURRENT	2500 A 500 A 3000 A 3000 A 120 250 A

400/415 V, 50/60 HZ	
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 440 V, 50/60 HZ	130 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 525 V, 50/60 HZ	37.5 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 690 V, 50/60 HZ	5 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 400/415 V, 50/60 HZ	330 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 440 V, 50/60 HZ	286 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 525 V, 50/60 HZ	105 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 690 V, 50/60 HZ	40 kA
STANDARD TERMINALS	Box terminal
RATED OPERATING VOLTAGE UE (UL) - MAX	600Y/347 V, 480 V
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 240 V, 50/60 HZ	330 kA
RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT AUXILIARY CONTACTS	6000 V
RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT MAIN CONTACTS	8000 V
RATED INSULATION VOLTAGE (UI)	1000 V AC
TO 2 17 10 2 (O.)	

PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	
DATE:	



Eaton Corporation plc

Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









