

Specifications



Eaton 108115

Eaton Moeller series xPole - PKP62/M2 RCBO - residual-current circuit breaker with overcurrent protection. RCD/MCB, 16A, 100mA, MCB trip curve B, 2 p, RCCB trip char.: A

General specifications

PRODUCT NAME	Eaton Moeller series xPole - PKP62/M2 RCBO - residual-current circuit breaker with overcurrent protection
CATALOG NUMBER	108115
EAN	4015081077694
PRODUCT LENGTH/DEPTH	86 mm
PRODUCT HEIGHT	75 mm
PRODUCT WIDTH	37 mm
PRODUCT WEIGHT	0.25 kg
COMPLIANCES	CE Marked RoHS conform
CERTIFICATIONS	CE
MODEL CODE	PKPM2-16/2/B/01-A

Delivery program

APPLICATION	Switchgear for residential and commercial applications
PRODUCT RANGE	PKPM2
BASIC FUNCTION	Combined RCD/MCB devices
PRODUCT APPLICATION	Switchgear for industrial and advanced commercial applications
NUMBER OF POLES	Two-pole
NUMBER OF POLES (PROTECTED)	2
NUMBER OF POLES (TOTAL)	2
TRIPPING CHARACTERISTIC	B
RELEASE CHARACTERISTIC	B
AMPERAGE RATING	16 A
RATED CURRENT	16 A
FAULT CURRENT RATING	0.1 A
SENSITIVITY TYPE	Type A, pulse-current sensitive
TYPE	RCBO

Technical data - electrical

VOLTAGE TYPE	AC
VOLTAGE RATING	230 V
RATED OPERATIONAL VOLTAGE (UE) - MAX	230 V
RATED INSULATION VOLTAGE (UI)	250 V
RATED IMPULSE WITHSTAND VOLTAGE (UIMP)	4 kV
IMPULSE WITHSTAND CURRENT	Partly surge-proof, 250 A
FREQUENCY RATING	50 Hz
LEAKAGE CURRENT TYPE	A
RATED SWITCHING CAPACITY	10 kA
RATED SWITCHING CAPACITY (IEC/EN 61009)	10 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY (EN 60947-2)	0 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY (EN 61009)	10 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY (EN 61009-1)	10 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY (IEC 60947-2)	0 kA
SURGE CURRENT CAPACITY	0.25 kA
DISCONNECTION CHARACTERISTIC	Undelayed
TRIPPING	Non-delayed
OVERVOLTAGE CATEGORY	III
POLLUTION DEGREE	2

Technical data - mechanical

WIDTH IN NUMBER OF MODULAR SPACINGS	2
--	---

BUILT-IN DEPTH	70 mm
-----------------------	-------

MOUNTING METHOD	DIN rail
------------------------	----------

DEGREE OF PROTECTION	IP20
-----------------------------	------

CONNECTABLE CONDUCTOR CROSS SECTION (SOLID-CORE) - MIN	1 mm ²
---	-------------------

CONNECTABLE CONDUCTOR CROSS SECTION (SOLID-CORE) - MAX	25 mm ²
---	--------------------

CONNECTABLE CONDUCTOR CROSS SECTION (MULTI-WIRED) - MIN	1 mm ²
--	-------------------

CONNECTABLE CONDUCTOR CROSS SECTION (MULTI-WIRED) - MAX	25 mm ²
--	--------------------

Design verification as per IEC/EN 61439 - technical data

RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	16 A
--	------

HEAT DISSIPATION PER POLE, CURRENT-DEPENDENT	0 W
---	-----

EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT	5 W
--	-----

STATIC HEAT DISSIPATION, NON-CURRENT-DEPENDENT	0 W
---	-----

HEAT DISSIPATION CAPACITY	0 W
----------------------------------	-----

AMBIENT OPERATING TEMPERATURE - MIN	-25 °C
--	--------

AMBIENT OPERATING TEMPERATURE - MAX	40 °C
--	-------

Design verification as per IEC/EN 61439

10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
------------------------------------	--

10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
---	--

10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
---	--

10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
---	--

10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Meets the product standard's requirements.
---	--

10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
-----------------------	--

10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.
---------------------------------	--

10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
----------------------------	--

10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
--	--

10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
---	--

10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
---	--

10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
---	--

10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	Is the panel builder's responsibility.
--	--

10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	Is the panel builder's responsibility.
---	--

10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH	Is the panel builder's responsibility.
---	--

10.9.3 IMPULSE WITHSTAND VOLTAGE	Is the panel builder's responsibility.
---	--

10.9.4 TESTING OF ENCLOSURES MADE OF	Is the panel builder's responsibility.
---	--

Additional information

CURRENT LIMITING CLASS	3
-------------------------------	---

INSULATING MATERIAL

10.10 TEMPERATURE RISE

The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.

10.11 SHORT-CIRCUIT RATING

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.12 ELECTROMAGNETIC COMPATIBILITY

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.13 MECHANICAL FUNCTION

The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Resources

CATALOGUES

[eaton-xpole-protective-devices-catalog-ca019014en-en-us.pdf](#)

[eaton-xpole-pkp62-rcbo-catalog-ca019054en-en-us.pdf](#)

[eaton-xpole-pkpm2-rcbo-catalog-ca019053en-en-us.pdf](#)

CHARACTERISTIC CURVE

[eaton-xpole-afdd-characteristic-curve-002.jpg](#)

DECLARATIONS OF CONFORMITY

[DA-DC-03_PKP.2](#)

DRAWINGS

[eaton-xeffect-frbm6m-3d-drawing-016.jpg](#)

[eaton-xeffect-frbm6m-characteristic-curve-003.jpg](#)

[eaton-xeffect-frbm6m-dimensions-002.jpg](#)

ECAD MODEL

[ETN.PKPM2-16_2_B_01-A](#)

INSTALLATION INSTRUCTIONS

[eaton-rccb-rcbo-g9-il019140zu.pdf](#)

MCAD MODEL

[eaton-rcd-with-overcurrent-protection-3d-models-fi4001.stp](#)

[eaton-rcd-with-overcurrent-protection-drawings-fi4001.dwg](#)

WIRING DIAGRAMS

[PKPM2_2p](#)

PROJECT NAME:

PROJECT NUMBER:

PREPARED BY:

DATE:



Eaton Corporation plc

Eaton House
30 Pembroke Road
Dublin 4, Ireland
Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.

