Specifikace



Eaton 110846

Eaton Moeller series NZM - Molded Case Circuit Breaker. Circuit-breaker, 3p, 220A, withdrawable unit, NZMN3-ME220-AVE

General specifications	
PRODUCT NAME	Eaton Moeller series NZM molded case circuit breaker electronic
CATALOG NUMBER	110846
EAN	4015081103751
PRODUCT LENGTH/DEPTH	260 mm
PRODUCT HEIGHT	346 mm
PRODUCT WIDTH	185 mm
PRODUCT WEIGHT	17.887 kg
COMPLIANCES	RoHS conform
CERTIFICATIONS	IEC IEC/EN 60947
MODEL CODE	NZMN3-ME220-AVE



Technické údaje produktu	
AMPERAGE RATING	220 A
VOLTAGE RATING	690 V - 690 V
CIRCUIT BREAKER FRAME TYPE	NZM3
ACCESSORIES REQUIRED	NZM3-XAVS
10.10 TEMPERATURE RISE	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Meets the product standard's requirements.
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.

Zdroje	
DECLARATIONS OF CONFORMITY	eaton-molded-case-circuit- breaker-declaration-of- conformity- eu250293en.pdf
CHARACTERISTIC CURVE	eaton-circuit-breaker-nzm- mccb-characteristic-curve- 056.eps
	eaton-circuit-breaker-let- through-current-nzm- mccb-characteristic-curve- 006.eps
	eaton-circuit-breaker-nzm- mccb-characteristic-curve- 017.eps
INSTALAČNÍ NÁVODY	eaton-circuit-breaker- basic-device-nzmn-b- il01208009z.pdf
MCAD MODEL	DA-CD-nzm3 xave
PEP ECO-PASSPORT	eaton-molded-case- switches-pep-eato-00244- v0101-en.pdf
VÝKRESY	eaton-circuit-breaker- switch-nzm-mccb- dimensions-016.eps
	eaton-circuit-breaker- withdrawable-unit-nzm- mccb-dimensions-002.eps
	eaton-circuit-breaker-nzm- mccb-dimensions-020.eps

10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	ls the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	ls the panel builder's responsibility.
10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH	ls the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	ls the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	ls the panel builder's responsibility.
FITTED WITH:	Thermal protection
POLLUTION DEGREE	3
MOUNTING METHOD	3 Withdrawable Built-in device slide-in technique (withdrawable)
	Withdrawable Built-in device slide-in
MOUNTING METHOD	Withdrawable Built-in device slide-in technique (withdrawable) Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC
MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT-	Withdrawable Built-in device slide-in technique (withdrawable) Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30
MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT	Withdrawable Built-in device slide-in technique (withdrawable) Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30
MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY	Withdrawable Built-in device slide-in technique (withdrawable) Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 14.52 W A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the
MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY ISOLATION AMBIENT OPERATING	Withdrawable Built-in device slide-in technique (withdrawable) Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 14.52 W A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts)
MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY ISOLATION AMBIENT OPERATING TEMPERATURE - MAX AMBIENT OPERATING	Withdrawable Built-in device slide-in technique (withdrawable) Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 14.52 W A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts)
MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY ISOLATION AMBIENT OPERATING TEMPERATURE - MAX AMBIENT OPERATING TEMPERATURE - MIN AMBIENT STORAGE	Withdrawable Built-in device slide-in technique (withdrawable) Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 14.52 W A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) 70 °C -25 °C
MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY ISOLATION AMBIENT OPERATING TEMPERATURE - MAX AMBIENT OPERATING TEMPERATURE - MIN AMBIENT STORAGE TEMPERATURE - MAX AMBIENT STORAGE	Withdrawable Built-in device slide-in technique (withdrawable) Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 14.52 W A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) 70 °C -25 °C

DIRECT CONTACT	proof to VDE 0106 part 100
RATED INSULATION VOLTAGE (UI)	1000 V
RATED OPERATING POWER AT AC-3, 230 V	55 kW
RATED OPERATING POWER AT AC-3, 400 V	110 kW
SWITCH OFF TECHNIQUE	Electronic
DEGREE OF PROTECTION	IP20 IP20 (basic degree of protection, in the operating controls area)
DIRECTION OF INCOMING SUPPLY	As required
ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT	Screw connection
LIFESPAN, MECHANICAL	15000 operations
OVERVOLTAGE CATEGORY	III
RATED OPERATIONAL CURRENT	196 A (400 V AC-3) 202 A (690 V AC-3)
DEGREE OF PROTECTION (IP), FRONT SIDE	IP66 (with door coupling rotary handle) IP40 (with insulating surround)
DEGREE OF PROTECTION (TERMINATIONS)	IP10 (tunnel terminal) IP00 (terminations, phase isolator and strip terminal)
NUMBER OF POLES	Three-pole
TERMINAL CAPACITY (COPPER STRIP)	Max. 10 segments of 24 mm x 1 mm + 5 segments of 24 mm x 1 mm at box terminal 10 segments of 50 mm x 1 mm (2x) at rear-side width extension Max. 8 segments of 24 mm x 1 mm (2x) at box terminal Min. 6 segments of 16 mm x 0.8 mm at rear-side connection (punched) Max. 10 segments of 32 mm x 1 mm + 5 segments of 32 mm x 1 mm at rear-side connection (punched) Min. 6 segments of 16 mm x 0.8 mm at box terminal
LIFESPAN, ELECTRICAL	2000 operations at 400 V AC-3 2000 operations at 690 V

	AC-3 3000 operations at 690 V AC-1 5000 operations at 400 V AC-1 2000 operations at 415 V AC-3 5000 operations at 415 V AC-1
FUNCTIONS	Phase failure sensitive Motor protection

Motor protection

TYPE

Circuit breaker

- IEC/EN 60947-4-1, IEC/EN 60947-2
- The circuit-breaker fulfills all requirements for AC-3 switching category.
- R.m.s. value measurement and "thermal memory"
- · Adjustable time delay setting to overcome current peaks tr at 6 x Ir also infinity (without overload releases)
- All AC-3 rating data applies to direct switching by the circuit-breaker under normal operating conditions. If, for example, a contactor takes over AC-3 switching under normal operating conditions, the full rated uninterrupted current applies to the circuit-breaker, In = lu.
- Maximum back-up fuse, if the expected shortcircuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit

SPECIAL FEATURES

	rated uninterrupted current: 220 A • Terminal capacity hint: Up to 240 mm² can be connected depending on the cable manufacturer.
APPLICATION	Use in unearthed supply systems at 690 V
SHOCK RESISTANCE	20 g (half-sinusoidal shock 20 ms)
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	220 A
RATED SHORT-TIME WITHSTAND CURRENT (T = 0.3 S)	3.3 kA
RATED SHORT-TIME WITHSTAND CURRENT (T = 1 S)	3.3 kA
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MAX	3080 A
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MIN	440 A
HANDLE TYPE	Rocker lever
INSTANTANEOUS CURRENT SETTING (II) - MAX	3080 A
INSTANTANEOUS CURRENT SETTING (II) - MIN	220 A
NUMBER OF OPERATIONS PER HOUR - MAX	60
OVERLOAD CURRENT SETTING (IR) - MAX	220 A
OVERLOAD CURRENT SETTING (IR) - MIN	110 A
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 230 V, 50/60 HZ	85 kA

35 kA

RATED SHORT-CIRCUIT

BREAKING CAPACITY ICS

breaking capacity

• Rated current = rated

(IEC/EN 60947) AT 400/415 V, 50/60 HZ	
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 440 V, 50/60 HZ	35 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 525 V, 50/60 HZ	13 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 690 V, 50/60 HZ	5 kA
STANDARD TERMINALS	Screw terminal
OPTIONAL TERMINALS	Box terminal. Connection on rear. Tunnel terminal
RELEASE SYSTEM	Electronic release
SHORT-CIRCUIT TOTAL BREAKTIME	< 10 ms
TERMINAL CAPACITY (ALUMINUM SOLID CONDUCTOR/CABLE)	16 mm² (1x) at tunnel terminal
TERMINAL CAPACITY (ALUMINUM STRANDED CONDUCTOR/CABLE)	50 mm ² - 240 mm ² (2x) at 2-hole tunnel terminal 50 mm ² - 240 mm ² (1x) at 2-hole tunnel terminal 25 mm ² - 185 mm ² (1x) at tunnel terminal
TERMINAL CAPACITY (CONTROL CABLE)	0.75 mm ² - 1.5 mm ² (2x) 0.75 mm ² - 2.5 mm ² (1x)
TERMINAL CAPACITY (COPPER BUSBAR)	Max. 30 mm x 10 mm + 30 mm x 5 mm direct at switch rear-side connection M10 at rear-side screw connection Max. 10 mm x 50 mm (2x) at rear-side width extension Min. 20 mm x 5 mm direct at switch rear-side connection
TERMINAL CAPACITY (COPPER SOLID CONDUCTOR/CABLE)	16 mm² (2x) direct at switch rear-side connection 300 mm² (2x) at rear-side width extension 16 mm² (2x) at box terminal 16 mm² (1x) at tunnel terminal 16 mm² (1x) direct at switch rear-side connection

TERMINAL CAPACITY (COPPER STRANDED CONDUCTOR/CABLE)	25 mm² - 120 mm² (2x) at box terminal 16 mm² - 185 mm² (1x) at 1-hole tunnel terminal 25 mm² - 240 mm² (2x) direct at switch rear-side connection 25 mm² - 240 mm² (1x) direct at switch rear-side connection 35 mm² - 240 mm² (1x) at box terminal
RATED SHORT-CIRCUIT BREAKING CAPACITY ICU (IEC/EN 60947) AT 400/415 V, 50/60 HZ	35 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 400/415 V, 50/60 HZ	105 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 440 V, 50/60 HZ	74 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 525 V, 50/60 HZ	53 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 690 V, 50/60 HZ	40 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 240 V, 50/60 HZ	187 kA
RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT AUXILIARY CONTACTS	6000 V
RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT MAIN CONTACTS	8000 V
PROJECT NAME:	



PROJECT NUMBER: PREPARED BY:

DATUM:

Eaton Corporation Plc.

Eaton House 30 Pembroke Road Dublin 4, Irsko Eaton.com

© 2025 Eaton. Všechna práva vyhrazena.

Follow us on social media to get the latest product and support information.









