## Specifications



## Photo is representative



## Eaton 111790

Eaton Moeller® series M22 Key-operated actuator, momentary, 2 positions, MS2, Key withdrawable: 0, Bezel: titanium

General specification	ıs
PRODUCT NAME	Eaton Moeller® series M22 Key-operated actuator
CATALOG NUMBER	111790
MODEL CODE	M22-WS-MS2
EAN	4015081113408
PRODUCT LENGTH/DEPTH	70 mm
PRODUCT HEIGHT	30 mm
PRODUCT WIDTH	30 mm
PRODUCT WEIGHT	0.034 kg
CERTIFICATIONS	CSA Class No.: 3211-03 CSA-C22.2 No. 94-91 CSA-C22.2 No. 14-05 UL File No.: E29184 CSA CSA File No.: 012528 UL IEC/EN 60947 IEC/EN 60947-5 VDE 0660 CE UL 508 UL Category Control No.: NKCR
GLOBAL CATALOG	111790



Product specifications	S
SPECIAL FEATURES	Includes one key
ТҮРЕ	Key-operated button
ACCESSORIES	1 key included with supplied equipment.
ACTUATOR COLOR	Black
BEZEL	Silver
ACTUATOR FUNCTION	Spring-return Momentary Key withdrawable in position 0
10.10 TEMPERATURE RISE	Not applicable.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Please enquire
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to

Resources	
CATALOGS	eaton-rmq-titan-brochure- br047004en-en-us.pdf
	eaton-pushbuttons-signal- towers-sensors- assortment-overview- catalog-ca047003en-en- us.pdf
	Flip catalog - Product Range Catalog - Command and indication
DECLARATIONS OF CONFORMITY	eaton-pushbutton- declaration-of-conformity- eu250858en.pdf
	eaton-key-operated- actuator-declaration-of- conformity- eu250865en.pdf
DRAWINGS	eaton-operating-key- operated-actuator- dimensions-005.eps
	eaton-general-m22- symbol.eps
	eaton-general-m22- standards.eps
	eaton-general-approval- m22-symbol.eps
ECAD MODEL	ETN.111790.edz
FLYERS	eaton-rmq-titan-selection- aid-brochure-fl047002-en- us.pdf
INSTALLATION INSTRUCTIONS	<u>IL04716002Z</u>
INSTALLATION VIDEOS	RMQ Flat Design
MCAD MODEL	DA-CD-schluesseltaste ms
	DA-CS-schluesseltaste ms
MULTIMEDIA	MCI MultiColor Light Indicator RMQ compact solution
	RMQ small E-Stop emergency-stop button
	MCI Multicolor Light Indicator M22 with SmartWire-DT

	la a la colo cada al
	be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	ls the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	ls the panel builder's responsibility.
10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH	ls the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	ls the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	ls the panel builder's responsibility.
FITTED WITH:	Front ring
OPERATING FREQUENCY	100 Operations/h
	100 operations/11
POLLUTION DEGREE	3
POLLUTION DEGREE  CLIMATIC PROOFING	
	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to
CLIMATIC PROOFING  CONNECTION TO	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 Yes With SWD-RMQ
CLIMATIC PROOFING  CONNECTION TO SMARTWIRE-DT	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 Yes With SWD-RMQ connections
CLIMATIC PROOFING  CONNECTION TO SMARTWIRE-DT  ACTUATOR TYPE  AMBIENT OPERATING	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78  Yes With SWD-RMQ connections  Key
CLIMATIC PROOFING  CONNECTION TO SMARTWIRE-DT  ACTUATOR TYPE  AMBIENT OPERATING TEMPERATURE - MAX  AMBIENT OPERATING	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78  Yes With SWD-RMQ connections  Key  70 °C
CONNECTION TO SMARTWIRE-DT  ACTUATOR TYPE  AMBIENT OPERATING TEMPERATURE - MAX  AMBIENT OPERATING TEMPERATURE - MIN  EQUIPMENT HEAT DISSIPATION, CURRENT-	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78  Yes With SWD-RMQ connections  Key  70 °C  -25 °C
CLIMATIC PROOFING  CONNECTION TO SMARTWIRE-DT  ACTUATOR TYPE  AMBIENT OPERATING TEMPERATURE - MAX  AMBIENT OPERATING TEMPERATURE - MIN  EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID  FORCE FOR POSITIVE	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78  Yes With SWD-RMQ connections  Key  70 °C  -25 °C

	easyE4 SmartWire-DT module with Remote Touch Display and RMQ multi color indicator
	eaton-control circuit- devices rmq-titan- fl144090en-en-us.pdf eaton-rmq-flat-enclosure-
SALES NOTES	flyer-fl047003en-en-us.pdf  eaton-rmq-mci-multi- color-light-indicator-flyer- fl047005en-en-us.pdf
	eaton-rmq-small-e-stop- flyer-fl047006en-en-us.pdf

CAPACITY PDISS	
HEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID	0 W
OPENING DIAMETER	22.5 mm
OPENING HEIGHT	0 mm
OPERATING TORQUE	0.5 Nm
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	0 A
STATIC HEAT DISSIPATION, NON- CURRENT-DEPENDENT PVS	0 W
SWITCHING ANGLE	40 °
WIDTH OPENING	0 mm
BEZEL COLOR	Titanium
SHOCK RESISTANCE	Mechanical, According to IEC/EN 60068-2-27 30 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms
KEY CODE	MS2
BEZEL MATERIAL	Plastic
DESIGN	Plastic Key operated
DESIGN	Key operated
DESIGN  MOUNTING POSITION  OVERVOLTAGE	Key operated As required
DESIGN  MOUNTING POSITION  OVERVOLTAGE CATEGORY	Key operated As required
DESIGN  MOUNTING POSITION  OVERVOLTAGE CATEGORY  DEGREE OF PROTECTION  DEGREE OF PROTECTION	Key operated As required III NEMA 4X, 13
DESIGN  MOUNTING POSITION  OVERVOLTAGE CATEGORY  DEGREE OF PROTECTION  DEGREE OF PROTECTION  (FRONT SIDE)	Key operated  As required  III  NEMA 4X, 13  IP66  Stay-put/spring-return function, can be changed with coding parts M22-XC-
DESIGN  MOUNTING POSITION  OVERVOLTAGE CATEGORY  DEGREE OF PROTECTION  DEGREE OF PROTECTION  (FRONT SIDE)  FUNCTIONS	Key operated  As required  III  NEMA 4X, 13  IP66  Stay-put/spring-return function, can be changed with coding parts M22-XC-Y
DESIGN  MOUNTING POSITION  OVERVOLTAGE CATEGORY  DEGREE OF PROTECTION  DEGREE OF PROTECTION  (FRONT SIDE)  FUNCTIONS  INDICATOR COLOR	Key operated  As required  III  NEMA 4X, 13  IP66  Stay-put/spring-return function, can be changed with coding parts M22-XC-Y  Other
DESIGN  MOUNTING POSITION  OVERVOLTAGE CATEGORY  DEGREE OF PROTECTION  (FRONT SIDE)  FUNCTIONS  INDICATOR COLOR  LENS TYPE	Key operated  As required  III  NEMA 4X, 13  IP66  Stay-put/spring-return function, can be changed with coding parts M22-XC-Y  Other  Round
DESIGN  MOUNTING POSITION  OVERVOLTAGE CATEGORY  DEGREE OF PROTECTION  DEGREE OF PROTECTION (FRONT SIDE)  FUNCTIONS  INDICATOR COLOR  LENS TYPE  LIFESPAN, MECHANICAL  NUMBER OF SWITCH	Key operated  As required  III  NEMA 4X, 13  IP66  Stay-put/spring-return function, can be changed with coding parts M22-XC-Y  Other  Round  100,000 Operations

PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	
DATE:	



## **Eaton Corporation plc**

Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









