## Specifications

## Eaton 173026

Eaton Moeller® series M22 Combination of contact element and self-monitoring contact element M22-K01SMC10 with screw terminals, M22-A mounting adapter, and M22-XSMC signaling contact actuator, 1 N/O, 3 NC

| General specification   | ns   |
|-------------------------|--|
| PRODUCT NAME            | Eaton Moeller® series<br>M22 Accessory Contact<br>element  |
| CATALOG NUMBER          | 173026   |
| MODEL CODE              | M22-AK03SMC10  |
| EAN                     | 4015081696178  |
| PRODUCT<br>LENGTH/DEPTH | 40.2 mm  |
| PRODUCT HEIGHT          | 32.5 mm  |
| PRODUCT WIDTH           | 47 mm  |
| PRODUCT WEIGHT          | 0.047 kg   |
| CERTIFICATIONS          | CSA-C22.2 No. 14-05 IEC 60947-5-1 IEC/EN 60947-5 UL CE UL 508 CSA Class No.: 3211-03 CSA-C22.2 No. 94-91 UL File No.: E340491 CSA CSA File No.: 012528_C_000 UL Category Control No.: NISD |



| Features & Functions     |                  |
|--------------------------|------------------|
| ELECTRIC CONNECTION TYPE | Screw connection |

| General                                      |                 |
|--|-----------------|
| DEGREE OF PROTECTION                         | IP20            |
| MODEL  | Top mounting    |
| MOUNTING METHOD                              | Front fastening |
| OPERATING TORQUE                             | 0.8 Nm          |
| OVERVOLTAGE<br>CATEGORY                      | III             |
| POLLUTION DEGREE                             | 3               |
| RATED IMPULSE<br>WITHSTAND VOLTAGE<br>(UIMP) | 6000 V AC       |

| Climatic environmental conditions      |  |
|--|--|
| AMBIENT OPERATING<br>TEMPERATURE - MIN | -25 °C   |
| AMBIENT OPERATING<br>TEMPERATURE - MAX | 70 °C  |
| AMBIENT STORAGE<br>TEMPERATURE - MIN   | -25 °C   |
| AMBIENT STORAGE<br>TEMPERATURE - MAX   | 85 °C  |
| CLIMATIC PROOFING                      | Damp heat, cyclic, to IEC<br>60068-2-30<br>Damp heat, constant, to<br>IEC 60068-2-78 |

| Terminal capacities                             |                |
|---|----------------|
| TERMINAL CAPACITY<br>(FLEXIBLE WITH<br>FERRULE) | 0.5 - 1.5 mm²  |
| TERMINAL CAPACITY (SOLID)                       | 0.75 - 2.5 mm² |
| TERMINAL CAPACITY (STRANDED)                    | 0.5 - 2.5 mm²  |
|   |                |

| Electrical rating  |       |
|--|-------|
| RATED INSULATION VOLTAGE (UI)                                      | 500 V |
| RATED OPERATIONAL<br>CURRENT (IE) AT AC-15,<br>115 V               | 6 A   |
| RATED OPERATIONAL<br>CURRENT (IE) AT AC-15,<br>220 V, 230 V, 240 V | 6 A   |
| RATED OPERATIONAL<br>CURRENT (IE) AT AC-15,<br>380 V, 400 V, 415 V | 4 A   |
| RATED OPERATIONAL<br>CURRENT (IE) AT AC-15,<br>500 V               | 2 A   |
| RATED OPERATIONAL<br>CURRENT (IE) AT DC-13,<br>110 V               | 0.6 A |
| RATED OPERATIONAL<br>CURRENT (IE) AT DC-13,<br>220 V, 230 V        | 0.3 A |
| RATED OPERATIONAL<br>CURRENT (IE) AT DC-13,<br>24 V                | 3 A   |
| RATED OPERATIONAL<br>CURRENT (IE) AT DC-13,<br>42 V                | 1.7 A |
| RATED OPERATIONAL<br>CURRENT (IE) AT DC-13,<br>60 V                | 1.2 A |
| RATED OPERATIONAL<br>CURRENT (IE) AT DC-13,                        | 0.1 A |

| Short-circuit rating               |   |
|------------------------------------|---|
| SHORT-CIRCUIT<br>PROTECTION        | PKZM0-10/FAZ-B6/1,<br>Contacts, Max. short-<br>circuit protective device,<br>Fuseless |
| SHORT-CIRCUIT<br>PROTECTION RATING | Max. 10 A gG/gL, Fuse,<br>Contacts  |

| Communication              |                                  |
|----------------------------|----------------------------------|
| CONNECTION TO SMARTWIRE-DT | No                               |
| CONNECTION TYPE            | Front fixing<br>Screw connection |

500 V

| ACTUATING FORCE - MAX 15 N | _ |
|----------------------------|---|

| Contacts  |     |
|---|-----|
| FORCE FOR POSITIVE OPENING - MIN                    | 0 N |
| NUMBER OF CONTACTS<br>(CHANGE-OVER<br>CONTACTS)     | 0   |
| NUMBER OF CONTACTS<br>(NORMALLY CLOSED<br>CONTACTS) | 3   |
| NUMBER OF CONTACTS<br>(NORMALLY OPEN<br>CONTACTS)   | 1   |

| Design verification   |  |
|---|--|
| EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID                                 | 0 W  |
| HEAT DISSIPATION CAPACITY PDISS   | 0 W  |
| HEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID                                  | 0.11 W   |
| RATED OPERATIONAL<br>CURRENT FOR SPECIFIED<br>HEAT DISSIPATION (IN)                 | 6 A  |
| STATIC HEAT<br>DISSIPATION, NON-<br>CURRENT-DEPENDENT<br>PVS                        | 0 W  |
| 10.2.2 CORROSION<br>RESISTANCE  | Meets the product standard's requirements.                         |
| 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES                            | Meets the product standard's requirements.                         |
| 10.2.3.2 VERIFICATION OF<br>RESISTANCE OF<br>INSULATING MATERIALS<br>TO NORMAL HEAT | Meets the product standard's requirements.                         |
| 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS    | Meets the product standard's requirements.                         |
| 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION                                    | Meets the product standard's requirements.                         |
| 10.2.5 LIFTING  | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 MECHANICAL<br>IMPACT   | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 INSCRIPTIONS   | Meets the product standard's requirements.                         |
| 10.3 DEGREE OF PROTECTION OF ASSEMBLIES   | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 CLEARANCES AND CREEPAGE DISTANCES  | Meets the product standard's requirements.                         |
| 10.5 PROTECTION<br>AGAINST ELECTRIC<br>SHOCK  | Does not apply, since the entire switchgear needs to be evaluated. |

| 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS         | Does not apply, since the entire switchgear needs to be evaluated.   |
|--|--|
| 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS              | ls the panel builder's responsibility.   |
| 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS                       | ls the panel builder's responsibility.   |
| 10.9.2 POWER-<br>FREQUENCY ELECTRIC<br>STRENGTH                | ls the panel builder's responsibility.   |
| 10.9.3 IMPULSE<br>WITHSTAND VOLTAGE                            | Is the panel builder's responsibility.   |
| 10.9.4 TESTING OF<br>ENCLOSURES MADE OF<br>INSULATING MATERIAL | ls the panel builder's responsibility.   |
| 10.10 TEMPERATURE RISE   | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 SHORT-CIRCUIT<br>RATING                                  | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.12 ELECTROMAGNETIC COMPATIBILITY                            | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.13 MECHANICAL<br>FUNCTION                                   | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |

| Resources                  |  |
|----------------------------|--|
| CATALOGUES                 | eaton-rmq-titan-brochure-<br>br047004en-en-us.pdf  |
|                            | Flip catalog - Product Range Catalog - Command and indication  |
|                            | eaton-pushbuttons-signal-<br>towers-sensors-<br>assortment-overview-<br>catalog-ca047003en-en-<br>us.pdf |
| CERTIFICATION REPORTS      | <u>000Z425</u>   |
| CONTROL TRAVEL DIAGRAM     | eaton-operating-diagram-<br>m22-contact-element-<br>contact-travel-diagram-<br>009.eps                   |
| DECLARATIONS OF CONFORMITY | eaton-accessory-<br>declaration-of-conformity-<br>uk251351en.pdf   |
|                            | eaton-accessory-<br>declaration-of-conformity-<br>eu250868en.pdf   |
|                            | DA-DC-00004971.pdf   |
|                            | DA-DC-00004134.pdf   |
|                            | DA-DC-00004157.pdf   |
|                            | DA-DC-00004176.pdf   |
|                            | DA-DC-00004135.pdf   |
|                            | DA-DC-00004975.pdf   |
| DRAWINGS                   | eaton-general-standards-<br>000Z425.jpg  |
| ECAD MODEL                 | DA-CE-ETN.M22-<br>AK03SMC10  |
| FLYERS                     | eaton-rmq-titan-selection-<br>aid-brochure-fl047002-en-<br>us.pdf  |
| INSTALLATION               | <u>IL04716002Z</u>   |
| INSTRUCTIONS               | <u>IL04716005Z.pdf</u>   |
| INSTALLATION VIDEOS        | RMQ Flat Design  |
| MULTIMEDIA                 | MCI Multicolor Light Indicator M22 with SmartWire-DT   |
|                            | RMQ small E-Stop<br>emergency-stop button  |

|                 | MCI MultiColor Light Indicator RMQ compact solution   |  |
|-----------------|---|--|
|                 | easyE4 SmartWire-DT<br>module with Remote<br>Touch Display and RMQ<br>multi color indicator |  |
|                 | eaton-control circuit-<br>devices rmq-titan-<br>fl144090en-en-us.pdf                        |  |
| SALES NOTES     | eaton-rmq-small-e-stop-<br>flyer-fl047006en-en-us.pdf                                       |  |
|                 | eaton-rmq-flat-enclosure-<br>flyer-fl047003en-en-us.pdf                                     |  |
|                 | eaton-rmq-mci-multi-<br>color-light-indicator-flyer-<br>fl047005en-en-us.pdf                |  |
| WIRING DIAGRAMS | eaton-operating-m22-<br>contact-element-wiring-<br>diagram-003.eps                          |  |

**PROJECT NAME: PROJECT NUMBER:** 

**PREPARED BY:** 

DATE:



**Eaton Corporation plc** 

Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









