Specifications



Eaton 179675

Eaton Moeller® series LS Position switch, Actuating rod, Complete unit, 1 N/O, 1 NC, Snap-action contact - Yes, Cage Clamp, Yellow, -40 - +70 °C

General specifications	
PRODUCT NAME	Eaton Moeller® series LS Position switch
CATALOG NUMBER	179675
MODEL CODE	LS-11S-CC/RR
EAN	4015081747351
PRODUCT LENGTH/DEPTH	255 mm
PRODUCT HEIGHT	46 mm
PRODUCT WIDTH	31 mm
PRODUCT WEIGHT	0.078 kg
CERTIFICATIONS	IEC/EN 60947
CATALOG NOTES	 Contacts with safety function, by positive opening to IEC/EN 60947-5-1 Contains a silicone seal to increase resistance to ozone, detergents and disinfectants.



Features & Functions	5
ELECTRIC CONNECTION TYPE	Cable entry metrical
ENCLOSURE COLOR	Yellow Cover
ENCLOSURE MATERIAL	Plastic
LINCLOSORE WATERIAL	T lastic
FEATURES	Forced opening Snap-action contact Positive opening

General	
CONNECTION TYPE	Cage Clamp
DEGREE OF PROTECTION	IP66/IP67 NEMA Other
OPERATING FREQUENCY	6000 Operations/h
OVERVOLTAGE CATEGORY	III
POLLUTION DEGREE	3
PRODUCT CATEGORY	Actuating rod
RATED IMPULSE WITHSTAND VOLTAGE (UIMP)	4000 V AC
REPETITION ACCURACY	0.15 mm (Contacts/switching capacity)
SUITABLE FOR	Safety functions
ТҮРЕ	Safety position switch

Ambient conditions, mechanical	
MOUNTING POSITION	As required
SHOCK RESISTANCE	25 g, Standard-action contact, Mechanical, Half- sinusoidal shock 20 ms

	Climatic environmental conditions	
	AMBIENT OPERATING TEMPERATURE - MIN	-40 °C
-	AMBIENT OPERATING TEMPERATURE - MAX	70 °C
_	CLIMATIC PROOFING	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78
	TEMPERATURE - MIN AMBIENT OPERATING TEMPERATURE - MAX	70 °C Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to

Terminal capacities	
TERMINAL CAPACITY (FLEXIBLE WITH FERRULE)	1 x (0.5 - 1.5) mm²
TERMINAL CAPACITY (SOLID)	1 x (0.5 - 2.5) mm ²

Electrical rating	
RATED INSULATION VOLTAGE (UI)	400 V
RATED OPERATIONAL CURRENT (IE) AT AC-15, 220 V, 230 V, 240 V	6 A
RATED OPERATIONAL CURRENT (IE) AT AC-15, 24 V	6 A
RATED OPERATIONAL CURRENT (IE) AT AC-15, 380 V, 400 V, 415 V	4 A
RATED OPERATIONAL CURRENT (IE) AT DC-13, 110 V	0.6 A
RATED OPERATIONAL CURRENT (IE) AT DC-13,	0.8 A

125 V	
RATED OPERATIONAL CURRENT (IE) AT DC-13, 220 V, 230 V	0.3 A
RATED OPERATIONAL CURRENT (IE) AT DC-13, 24 V	3 A
SHORT-CIRCUIT PROTECTION RATING	Max. 6 A gG/gL, Fuse, Contacts
SUPPLY FREQUENCY	Max. 400 Hz, Contacts

Actuator	
ACTUATING TORQUE OF ROTARY DRIVES	0.2 Nm
ACTUATOR TYPE	Actuating rod
OPERATING SPEED	Max. 1.5 m/s (with DIN cam, mechanical actuation) L = 130 mm

Contacts	
CONTROL CIRCUIT RELIABILITY	1 failure per 5,000,000 switching operations (statistically determined, at 5 V DC/1 mA) 1 failure per 10,000,000 switching operations (Statistically determined, at 24 V DC/5 mA)
NUMBER OF CONTACTS (CHANGE-OVER CONTACTS)	0
NUMBER OF CONTACTS (NORMALLY CLOSED CONTACTS)	1
NUMBER OF CONTACTS (NORMALLY OPEN CONTACTS)	1

Safety	
EXPLOSION SAFETY CATEGORY FOR GAS	None
EXPLOSION SAFETY CATEGORY FOR DUST	None

Design verification	
EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID	0 W
HEAT DISSIPATION CAPACITY PDISS	0 W
HEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID	0.17 W
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	6 A
STATIC HEAT DISSIPATION, NON- CURRENT-DEPENDENT PVS	0 W
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.

10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Meets the product standard's requirements.
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	ls the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	ls the panel builder's responsibility.
10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH	ls the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	Is the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	ls the panel builder's responsibility.
	The panel builder is

	calculation. Eaton will provide heat dissipation data for the devices.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Resources	
CATALOGUES	eaton-pushbuttons-signal- towers-sensors- assortment-overview- catalog-ca047003en-en- us.pdf
	eaton-product-overview- for-machinery-catalogue- ca08103003zen-en-us.pdf
CONTROL TRAVEL DIAGRAM	eaton-position-switches- diagram-ls-contact-travel- diagram-018.eps
DECLARATIONS OF CONFORMITY	eaton-position-switch- declaration-of-conformity- uk251032en.pdf
	DA-DC-00004160.pdf
	eaton-position-switch- declaration-of-conformity- eu250549en.pdf
	DA-DC-00004133.pdf
DRAWINGS	eaton-position-switches- actuation-ls-dimensions- 002.eps eaton-operating-button-
	symbol-008.eps
ECAD MODEL	ETN.179675.edz
INSTALLATION INSTRUCTIONS	<u>IL053001ZU</u>
MCAD MODEL	DA-CD-ls rr DA-CS-ls rr
SALES NOTES	eaton-safety-switches-rs- titan-flyer-fl053001en-en- us.pdf
WIRING DIAGRAMS	eaton-position-switches- contact-ls-wiring- diagram.eps

PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	
DATE:	



Eaton Corporation plc

Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









