Specifications



Eaton 183596

Eaton Moeller series IZMX/INX - ACB. Circuitbreaker, 3 pole, 1000A, 85 kA, P measurement, IEC, Withdrawable

| General specifications | |
|-------------------------|--|
| PRODUCT NAME | Eaton Moeller series IZMX/INX circuit-breaker |
| CATALOG NUMBER | 183596 |
| MODEL CODE | IZMX40N3-P10W-1 |
| EAN | 4015081793327 |
| PRODUCT LENGTH/DEPTH | 584 mm |
| PRODUCT HEIGHT | 597 mm |
| PRODUCT WIDTH | 521 mm |
| PRODUCT WEIGHT | 69 kg |
| COMPLIANCES | IEC IEC/EN 60947 RoHS conform |
| GLOBAL CATALOG | 183596 |



| Air circuit breakers/switch-disconnector Open circuit breaker AMPERAGE RATING 1000 A Complete device with protection unit Motor drive optional The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSULATING MATERIALS TO NORMAL HEAT 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION AMPORTAL ELECT. EFFECTS 10.2.5 LIFTING AMPORTAL STABILITY OF Enclosures Meets the product standard's requirements. | Product specifications | |
|---|--|---|
| The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT /FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Compatibility Protection and the product standard's requirements. Compatible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. Meets the product standard's requirements. Meets the product standard's requirements. | USED WITH | disconnector |
| The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.3 RESIST. OF INSULATING MATERIALS TO NORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Does not apply, since the entire switchgear needs to Dasa very some and apply, since the entire switchgear needs to Dasa very some and apply, since the entire switchgear needs to | AMPERAGE RATING | 1000 A |
| 10.10 TEMPERATURE RISE 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING 10.10 TEMPERATURE RISE Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. In the device meets the requirements, provided the information in the instruction leaflet (IL) is observed. Meets the product standard's requirements. | FEATURES | protection unit |
| 10.11 SHORT-CIRCUIT RATING responsibility. The specifications for the switchgear must be observed. 10.12 ELECTROMAGNETIC COMPATIBILITY ls the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION Meets the product standard's requirements. 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE Meets the product standard's requirements. 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. Does not apply, since the entire switchgear needs to | 10.10 TEMPERATURE RISE | responsible for the temperature rise calculation. Eaton will provide heat dissipation |
| 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Presponsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to | | responsibility. The specifications for the switchgear must be |
| 10.13 MECHANICAL FUNCTION requirements, provided the information in the instruction leaflet (IL) is observed. 10.2.2 CORROSION RESISTANCE Meets the product standard's requirements. 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. | | responsibility. The specifications for the switchgear must be |
| RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. | | requirements, provided the information in the instruction leaflet (IL) is |
| THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. | | • |
| RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to | THERMAL STABILITY OF | - |
| INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to | RESISTANCE OF INSULATING MATERIALS | - |
| ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. Does not apply, since the entire switchgear needs to | INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. | - |
| 10.2.5 LIFTING entire switchgear needs to | | |
| | ULTRA-VIOLET (UV) | - |
| 10.2.6 MECHANICAL Does not apply, since the | ULTRA-VIOLET (UV) RADIATION | Does not apply, since the entire switchgear needs to |

| Resources | |
|----------------------------|---|
| CATALOGS | eaton-acb-izm63-catalog- ca0135003en-en-us.pdf |
| DECLARATIONS OF CONFORMITY | eaton-circuit-breaker- declaration-of-conformity- eu250301en.pdf |
| DRAWINGS | eaton-circuit-breaker- izmx-inx-mccb- dimensions-015.eps |
| | eaton-circuit-breaker- izmx-inx-mccb- dimensions-014.eps |
| | eaton-circuit-breaker- mounting-izmx-inx-mccb- dimensions.eps |
| | eaton-circuit-breaker- mounting-izmx-inx-mccb- dimensions-002.eps |
| ECAD MODEL | DA-CE-ETN.IZMX40N3- P10W-1 |
| INSTALLATION VIDEOS | Air Circuit Breakers Series IZMX |
| MANUALS AND USER GUIDES | MN013002_EN |
| MCAD MODEL | DA-CD-izmx40 3pol w DA-CS-izmx40 3pol w |

| IMPACT | entire switchgear needs to be evaluated. |
|--|--|
| 10.2.7 INSCRIPTIONS | Meets the product standard's requirements. |
| 10.3 DEGREE OF PROTECTION OF ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 CLEARANCES AND CREEPAGE DISTANCES | Meets the product standard's requirements. |
| 10.5 PROTECTION AGAINST ELECTRIC SHOCK | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS | Is the panel builder's responsibility. |
| 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS | ls the panel builder's responsibility. |
| 10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH | Is the panel builder's responsibility. |
| 10.9.3 IMPULSE WITHSTAND VOLTAGE | Is the panel builder's responsibility. |
| 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL | ls the panel builder's responsibility. |
| FITTED WITH: | Switched-off indicator |
| FRAME | IZMX40 |
| POLLUTION DEGREE | 3 |
| RATED UNINTERRUPTED CURRENT (IU) | 1000 A |
| MOUNTING METHOD | Withdrawable |
| EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT | 55 W |
| RATED IMPULSE WITHSTAND VOLTAGE (UIMP) | 12 kV AC |
| UTILIZATION CATEGORY | В |
| DEVICE CONSTRUCTION | Built-in device slide-in technique (withdrawable) |
| DIRECTION OF INCOMING SUPPLY | As required |
| ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT | Rail connection |

| ACTUATOR TYPE | Push button |
|--|---------------|
| SHORT-CIRCUIT RELEASE NON-DELAYED SETTING | 1.5 - 10 x lr |
| ADJUSTMENT RANGE SHORT-TERM DELAYED SHORT-CIRCUIT RELEASE - MAX | 10000 A |
| ADJUSTMENT RANGE SHORT-TERM DELAYED SHORT-CIRCUIT RELEASE - MIN | 600 A |
| ADJUSTMENT RANGE UNDELAYED SHORT- CIRCUIT RELEASE - MAX | 15000 A |
| ADJUSTMENT RANGE UNDELAYED SHORT- CIRCUIT RELEASE - MIN | 2000 A |
| AMBIENT OPERATING TEMPERATURE - MAX | 70 °C |
| AMBIENT OPERATING TEMPERATURE - MIN | -20 °C |
| AMBIENT STORAGE TEMPERATURE - MAX | 70 °C |
| AMBIENT STORAGE TEMPERATURE - MIN | -20 °C |
| NUMBER OF AUXILIARY CONTACTS (CHANGE- OVER CONTACTS) | 2 |
| NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS) | 0 |
| NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS) | 0 |
| NUMBER OF STANDARD MECHANICAL OPERATIONS PER HOUR - MAX | 60 |
| OPERATING SEQUENCE UP TO 690 V, 50/60 HZ (IEC/EN 60947) | 75 kA |
| OVERLOAD RELEASE CURRENT SETTING - MAX | 1000 A |
| OVERLOAD RELEASE CURRENT SETTING - MIN | 400 A |
| POWER OF WITHDRAWABLE SWITCH WITH CASSETTE | 55 W |
| RATED INSULATION | 1000 V |

| VOLTAGE (UI) | |
|---|--|
| LIFESPAN, MECHANICAL | 12500 switching cycles (ON/OFF) 25000 operations (switching capacity, with maintenance) |
| OVERVOLTAGE CATEGORY | III |
| SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MIN | 0 A |
| WEIGHT OF CASSETTE VERSION (3-POLE) | 29 kg |
| WEIGHT OF FIXED WITHDRAWABLE VERSION (3-POLE) | 69 kg |
| AMBIENT OPERATING TEMPERATURE DETAILS | -20 °C - 70 °C |
| PROTECTION | P measurement |
| VOLTAGE RATING AT AC | 690 V AC |
| SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MAX | 15000 A |
| SHORT-CIRCUIT RELEASE DELAYED SETTING - MAX | 10000 A |
| NUMBER OF POLES | Three-pole |
| DEGREE OF PROTECTION | IP31 with door seals IP55 with protective cover IP31 |
| CLOSING DELAY VIA SPRING RELEASE | 35 ms |
| LIFESPAN, ELECTRICAL | 10000 operations (switching capacity) 20000 operations (switching cycles ON/OFF, with maintenance) |
| ТҮРЕ | Air circuit breakers/switch- disconnectorOpen circuit breaker |
| SPECIAL FEATURES | Cassette must be separately ordered. External IZMX-DTP- PTM-1 voltage measuring module required (1 module |

- is suitable for 16 circuit breakers)
- IZMX-DTP-PTM external voltage measuring module required
- suitable for zone selectivity
- suitable for communication
- with integrated system monitor
- with integrated test possibility
- With graphic LCD display
- optionally fittable by user with comprehensive accessories
- Terminal capacity hint: These are values used in separate switchgear. The actual values will depend on the temperature around the circuit breaker, which is influenced by the ambient temperature, the degree of protection (IP), the mounting height, the partitions, and any external ventilation. Depending on the specific switchgear design, this may result in derating, which can then be compensated for by increasing the cross-sectional area. Temperature rise tests in the specific switchgear can provide specific and detailed information.

| CURRENT CIRCUIT | |
|---|---|
| RELEASE SYSTEM | Electronic release |
| RATED OPERATING VOLTAGE (UE) - MAX | 690 V |
| RATED OPERATING VOLTAGE (UE) - MIN | 690 V |
| RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN) | 1000 A |
| RATED SHORT-CIRCUIT BREAKING CAPACITY AT 400 V, 50 HZ | 85 kA |
| RATED SHORT-CIRCUIT MAKING CAPACITY UP TO 440 V, 50/60 HZ | 187 kA |
| RATED SHORT-CIRCUIT MAKING CAPACITY UP TO 690 V, 50/60 HZ | 166 kA |
| RATED SHORT-TIME WITHSTAND CURRENT (T = 1 S) | 85 kA |
| RATED SHORT-TIME WITHSTAND CURRENT AT 50/60 HZ (T = 3 S) | 66 kA |
| RATED UNINTERRUPTED CURRENT (IU) AT 50°C | 1000 A |
| RATED UNINTERRUPTED CURRENT (IU) AT 60°C | 1000 A |
| RATED UNINTERRUPTED CURRENT (IU) AT 70°C | 1000 A |
| SHORT-CIRCUIT RELEASE DELAYED SETTING - MIN | 750 A |
| TERMINAL CAPACITY (COPPER BAR) | 60 mm x 10 mm (1x) for withdrawable units (black) |
| POWER LOSS | 55 W |
| PROJECT NAME: | |
| PROJECT NUMBER: | |
| PREPARED BY: | |
| | |



DATE:

Eaton Corporation plc

Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









