## Specifications



Photo is representative





## Eaton 187033

Eaton Moeller® series M30 Potentiometer, flat front, M30, 30.5 mm, R 470 k $\Omega$ , P 0.5 W, Metal bezel

General specifications	
PRODUCT NAME	Eaton Moeller® series M30 Potentiometer
CATALOG NUMBER	187033
MODEL CODE	M30C-FR470K
EAN	4015081820993
PRODUCT LENGTH/DEPTH	36 mm
PRODUCT HEIGHT	63 mm
PRODUCT WIDTH	46 mm
PRODUCT WEIGHT	0.055 kg
CERTIFICATIONS	VDE 0660 IEC/EN 60947
GLOBAL CATALOG	187033



Product specification	S
ТҮРЕ	Potentiometer
10.10 TEMPERATURE RISE	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Please enquire
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF	Does not apply, since the entire switchgear needs to

CATALOGSeaton-rmq-titan-brochure-br047004en-en-us.pdfElip catalog - Product Range Catalog - Command and indicationeaton-pushbuttons-signal-towers-sensors-assortment-overview-catalog-ca047003en-en-us.pdfDECLARATIONS OF CONFORMITYeaton-key-operated-actuator-declaration-of-conformity-eu250863en.pdfCONFORMITYeaton-key-operated-actuator-declaration-of-conformity-eu250864en.pdfEaton-operating-m30-dimensions-004.epseaton-operating-m30-potentiometer-dimensions-epseaton-operating-m30-potentiometer-dimensions-epseaton-operating-m30-dimensions-005.epseaton-operating-m30-dimensions-005.epseaton-operating-m30-dimensions-006.epseaton-operating-m30-potentiometer-3d-drawing.epseaton-operating-m30-potentiometer-3d-drawing.epseaton-general-approval-m22-symbol.epseaton-general-approval-m22-symbol.epsECAD MODELDA-CE-ETN.M30C-FR470KFLYERSeaton-rmq-titan-selection-aid-brochure-fl047002-en-us.pdfINSTALLATIONeaton-operating-devices-m30-rmq-titan-flat-front-instruction-leaflet-il047019zu.pdfINSTALLATION VIDEOSRMO Flat Design	Resources	
CATALOGS  Range Catalog - Command and indication  eaton-pushbuttons-signal-towers-sensors-assortment-overview-catalog-ca047003en-enus.pdf  eaton-key-operated-actuator-declaration-of-conformity-eu250863en.pdf  eaton-key-operated-actuator-declaration-of-conformity-eu250864en.pdf  eaton-operating-m30-dimensions-004.eps  eaton-operating-m30-potentiometer-dimensions-eps  eaton-operating-m30-dimensions-005.eps  eaton-operating-m30-dimensions-006.eps  eaton-operating-m30-dimensions-006.eps  eaton-operating-m30-gotentiometer-3d-drawing.eps  eaton-operating-m30-potentiometer-3d-drawing.eps  eaton-operating-m30-potentiometer-3d-drawing.eps  eaton-operating-m30-potentiometer-3d-drawing.eps  eaton-operating-m30-potentiometer-3d-drawing.eps  eaton-operating-m30-potentiometer-3d-drawing.eps  eaton-operating-m30-potentiometer-3d-drawing.eps  eaton-operating-m30-potentiometer-3d-drawing.eps  eaton-operating-devices-mid-brochure-fl047002-enus.pdf  ILO47030ZU  INSTALLATION INSTRUCTIONS  INSTRUCTIONS	CATALOGS	
towers-sensors- assortment-overview- catalog-ca047003en-en- us.pdf  eaton-key-operated- actuator-declaration-of- conformity- eu250863en.pdf  eaton-key-operated- actuator-declaration-of- conformity- eu250864en.pdf  eaton-operating-m30- dimensions-004.eps  eaton-operating-m30- dimensions-005.eps  eaton-operating-m30- dimensions-006.eps  eaton-operating-m30- dimensions-006.eps  eaton-operating-m30- dimensions-006.eps  eaton-operating-m30- dimensions-006.eps  eaton-operating-m30- dimensions-006.eps  eaton-operating-m30- potentiometer-3d- drawing.eps  eaton-operating-devices- mid-brochure-fl047002-en- us.pdf  ILO47030ZU  INSTALLATION INSTRUCTIONS  INSTRUCTIONS		Range Catalog - Command
DECLARATIONS OF CONFORMITY  actuator-declaration-of- conformity- eu250863en.pdf  eaton-key-operated- actuator-declaration-of- conformity- eu250864en.pdf  eaton-operating-m30- dimensions-004.eps  eaton-operating-m30- potentiometer- dimensions-005.eps  eaton-operating-m30- dimensions-006.eps  eaton-operating-m30- dimensions-006.eps  eaton-operating-m30- dimensions-006.eps  eaton-operating-m30- potentiometer-3d- drawing.eps  eaton-operating-devices- ms0-rmq-titan-selection- aid-brochure-fl047002-en- us.pdf  IL047030ZU  INSTALLATION INSTRUCTIONS  INSTRUCTIONS		towers-sensors- assortment-overview- catalog-ca047003en-en-
eaton-key-operated-actuator-declaration-of-conformity-eu250864en.pdf  eaton-operating-m30-dimensions-004.eps  eaton-operating-m30-potentiometer-dimensions.eps  eaton-operating-m30-dimensions-005.eps  eaton-operating-m30-dimensions-006.eps  eaton-operating-m30-dimensions-006.eps  eaton-operating-m30-potentiometer-3d-drawing.eps  eaton-operating-m30-potentiometer-3d-drawing.eps  eaton-general-approval-m22-symbol.eps  ECAD MODEL  DA-CE-ETN.M30C-FR470K  eaton-rmq-titan-selection-aid-brochure-fl047002-en-us.pdf  IL047030ZU  INSTALLATION INSTRUCTIONS  m30-rmq-titan-flat-front-instruction-leaflet-il047019zu.pdf		actuator-declaration-of- conformity-
dimensions-004.eps  eaton-operating-m30- potentiometer- dimensions.eps  eaton-operating-m30- dimensions-005.eps  eaton-operating-m30- dimensions-006.eps  eaton-operating-m30- dimensions-006.eps  eaton-operating-m30- potentiometer-3d- drawing.eps  eaton-operating-m30- potentiometer-3d- drawing.eps  eaton-general-approval- m22-symbol.eps  ECAD MODEL  DA-CE-ETN.M30C-FR470K  eaton-rmq-titan-selection- aid-brochure-fl047002-en- us.pdf  IL047030ZU  INSTALLATION INSTRUCTIONS  m30-rmq-titan-flat-front- instruction-leaflet- il047019zu.pdf		actuator-declaration-of- conformity-
potentiometer- dimensions.eps  eaton-operating-m30- dimensions-005.eps  eaton-operating-m30- dimensions-006.eps  eaton-general-m22- symbol.eps  eaton-operating-m30- potentiometer-3d- drawing.eps  eaton-general-approval- m22-symbol.eps  ECAD MODEL  DA-CE-ETN.M30C-FR470K  eaton-rmq-titan-selection- aid-brochure-fl047002-en- us.pdf  IL047030ZU  INSTALLATION INSTRUCTIONS  m30-rmq-titan-flat-front- instruction-leaflet- il047019zu.pdf	DRAWINGS	
DRAWINGS  eaton-operating-m30- dimensions-006.eps  eaton-general-m22- symbol.eps  eaton-operating-m30- potentiometer-3d- drawing.eps  eaton-general-approval- m22-symbol.eps  ECAD MODEL  DA-CE-ETN.M30C-FR470K  eaton-rmq-titan-selection- aid-brochure-fl047002-en- us.pdf  IL047030ZU  INSTALLATION INSTRUCTIONS  m30-rmq-titan-flat-front- instruction-leaflet- il047019zu.pdf		potentiometer-
dimensions-006.eps  eaton-general-m22- symbol.eps  eaton-operating-m30- potentiometer-3d- drawing.eps  eaton-general-approval- m22-symbol.eps  ECAD MODEL  DA-CE-ETN.M30C-FR470K  eaton-rmq-titan-selection- aid-brochure-fl047002-en- us.pdf  IL047030ZU  INSTALLATION INSTRUCTIONS  eaton-operating-devices- m30-rmq-titan-flat-front- instruction-leaflet- il047019zu.pdf		
eaton-operating-m30- potentiometer-3d- drawing.eps  eaton-general-approval- m22-symbol.eps  ECAD MODEL  DA-CE-ETN.M30C-FR470K  eaton-rmq-titan-selection- aid-brochure-fl047002-en- us.pdf  IL047030ZU  INSTALLATION INSTRUCTIONS  eaton-operating-devices- m30-rmq-titan-flat-front- instruction-leaflet- il047019zu.pdf		
potentiometer-3d- drawing.eps  eaton-general-approval- m22-symbol.eps  ECAD MODEL  DA-CE-ETN.M30C-FR470K  eaton-rmq-titan-selection- aid-brochure-fl047002-en- us.pdf  IL047030ZU  INSTALLATION INSTRUCTIONS  eaton-operating-devices- m30-rmq-titan-flat-front- instruction-leaflet- il047019zu.pdf		
ECAD MODEL  DA-CE-ETN.M30C-FR470K  eaton-rmq-titan-selection- aid-brochure-fl047002-en- us.pdf  IL047030ZU  INSTALLATION INSTRUCTIONS  m30-rmq-titan-flat-front- instruction-leaflet- il047019zu.pdf		potentiometer-3d-
eaton-rmq-titan-selection- aid-brochure-fl047002-en- us.pdf  IL047030ZU  INSTALLATION INSTRUCTIONS  m30-rmq-titan-flat-front- instruction-leaflet- il047019zu.pdf		=
INSTALLATION eaton-operating-devices-m30-rmq-titan-flat-front-instruction-leaflet-il047019zu.pdf	ECAD MODEL	DA-CE-ETN.M30C-FR470K
INSTALLATION INSTRUCTIONS  m30-rmq-titan-flat-front-instruction-leaflet-il047019zu.pdf	FLYERS	aid-brochure-fl047002-en-
INSTRUCTIONS  m30-rmq-titan-flat-front- instruction-leaflet- il047019zu.pdf		<u>IL047030ZU</u>
INSTALLATION VIDEOS RMQ Flat Design		m30-rmq-titan-flat-front- instruction-leaflet-
	INSTALLATION VIDEOS	RMQ Flat Design

ASSEMBLIES	be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	Is the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	ls the panel builder's responsibility.
10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH	ls the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	ls the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	ls the panel builder's responsibility.
ELECTRIC CONNECTION TYPE	Screw connection
FITTED WITH:	3 individual screw terminals
FITTED WITH: POLLUTION DEGREE	
	terminals
POLLUTION DEGREE	terminals  3  ± 10 % (linear), Resistance
POLLUTION DEGREE ACCURACY	terminals  3  ± 10 % (linear), Resistance value  Damp heat, cyclic, to IEC 60068-2-30  Damp heat, constant, to
POLLUTION DEGREE  ACCURACY  CLIMATIC PROOFING  CONNECTION TO	terminals  3  ± 10 % (linear), Resistance value  Damp heat, cyclic, to IEC 60068-2-30  Damp heat, constant, to IEC 60068-2-78
POLLUTION DEGREE  ACCURACY  CLIMATIC PROOFING  CONNECTION TO SMARTWIRE-DT  RATED IMPULSE WITHSTAND VOLTAGE	terminals  3  ± 10 % (linear), Resistance value  Damp heat, cyclic, to IEC 60068-2-30  Damp heat, constant, to IEC 60068-2-78  No
POLLUTION DEGREE  ACCURACY  CLIMATIC PROOFING  CONNECTION TO SMARTWIRE-DT  RATED IMPULSE WITHSTAND VOLTAGE (UIMP)	terminals  3  ± 10 % (linear), Resistance value  Damp heat, cyclic, to IEC 60068-2-30  Damp heat, constant, to IEC 60068-2-78  No  4000 V AC
POLLUTION DEGREE  ACCURACY  CLIMATIC PROOFING  CONNECTION TO SMARTWIRE-DT  RATED IMPULSE WITHSTAND VOLTAGE (UIMP)  BEZEL COLOR  AMBIENT OPERATING	terminals  3  ± 10 % (linear), Resistance value  Damp heat, cyclic, to IEC 60068-2-30  Damp heat, constant, to IEC 60068-2-78  No  4000 V AC  Titanium
POLLUTION DEGREE  ACCURACY  CLIMATIC PROOFING  CONNECTION TO SMARTWIRE-DT  RATED IMPULSE WITHSTAND VOLTAGE (UIMP)  BEZEL COLOR  AMBIENT OPERATING TEMPERATURE - MAX  AMBIENT OPERATING	terminals  3  ± 10 % (linear), Resistance value  Damp heat, cyclic, to IEC 60068-2-30  Damp heat, constant, to IEC 60068-2-78  No  4000 V AC  Titanium  70 °C

MCAD MODEL	<u>DA-CD-</u> <u>potentiometer_flatfront</u>
	<u>DA-CS-</u> <u>potentiometer_flatfront</u>
MULTIMEDIA	easyE4 SmartWire-DT module with Remote Touch Display and RMQ multi color indicator
	MCI MultiColor Light Indicator RMQ compact solution
	RMQ small E-Stop emergency-stop button
	MCI Multicolor Light Indicator M22 with SmartWire-DT
SALES NOTES	<u>eaton-rmq-flat-enclosure-flyer-fl047003en-en-us.pdf</u>
	eaton-rmq-small-e-stop- flyer-fl047006en-en-us.pdf
	eaton-rmq-mci-multi- color-light-indicator-flyer- fl047005en-en-us.pdf
	eaton-control circuit- devices rmq-titan- fl144090en-en-us.pdf
WIRING DIAGRAMS	eaton-operating- potentiometer-m30- wiring-diagram.eps

HEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID	0 W
NUMBER OF REVOLUTIONS - MAX	1
NUMBER OF REVOLUTIONS - MIN	1
OPENING DIAMETER	30 mm
RATED INSULATION VOLTAGE (UI)	250 V
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	0 A
RATED POWER	0.5 VA
STATIC HEAT DISSIPATION, NON- CURRENT-DEPENDENT PVS	0.5 W
DESIGN	Flat front
MOUNTING POSITION	As required
OVERVOLTAGE CATEGORY	Ш
DEGREE OF PROTECTION	IP66 NEMA Other
POWER CONSUMPTION	0.5 W
LIFESPAN, MECHANICAL	25,000 Operations
SHOCK RESISTANCE	Not planned
RESISTANCE	470000 Ohm
TERMINAL CAPACITY (SOLID)	0.5 - 1.5 mm <sup>2</sup>
TERMINAL CAPACITY (STRANDED)	0.5 - 1.5 mm <sup>2</sup>
TIGHTENING TORQUE	0.5 Nm, Screw terminals

PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	
DATE:	



## **Eaton Corporation plc**

Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









