## Specifications

Photo is representative

## Eaton 187174

Eaton Moeller series xPole - AFDD+ Arc Fault Detection Device, 2 poles, C10A, 30mA, type A

General specifications	
PRODUCT NAME	Eaton Moeller series xPole - AFDD+ Arc fault detection device
CATALOG NUMBER	187174
EAN	4015081822232
PRODUCT LENGTH/DEPTH	80 mm
PRODUCT HEIGHT	73 mm
PRODUCT WIDTH	52.5 mm
PRODUCT WEIGHT	0.277 kg
COMPLIANCES	CE Marked RoHS conform
CERTIFICATIONS	CE
MODEL CODE	AFDD-10/2/C/003-A



Delivery programme	
APPLICATION	Switchgear for residential and commercial applications
PRODUCT RANGE	AFDD
BASIC FUNCTION	Arc fault circuit interrupter
PRODUCT APPLICATION	Switchgear for residential and commercial applications
NUMBER OF POLES	Two-pole
NUMBER OF POLES (PROTECTED)	2
NUMBER OF POLES (TOTAL)	2
RELEASE CHARACTERISTIC	С
TRIPPING CHARACTERISTIC	С
RATED CURRENT	10 A
RATED CURRENT OF PRODUCT RANGE	10-40 Ampere
FAULT CURRENT RATING	0.03 A
SENSITIVITY TYPE	Type A Pulse-current sensitive
ТҮРЕ	AFDD+

Technical data - electrical	
VOLTAGE RATING	230 V
RATED IMPULSE WITHSTAND VOLTAGE (UIMP)	4
CURRENT TEST MARKS	As per inscription
IMPULSE WITHSTAND CURRENT	Partly surge-proof, 250 A
FREQUENCY	50 Hz
LEAKAGE CURRENT TYPE	A
RATED SWITCHING CAPACITY (IEC/EN 61009)	10 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY	10 Kilo Ampere
RATED SHORT-CIRCUIT BREAKING CAPACITY (EN 60947-2)	0 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY (EN 61009)	10 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY (EN 61009-1)	10 kA
TEST CIRCUIT AC	170 - 264 Voltage AC
TRIPPING	Non-delayed
CONTROL VOLTAGE TYPE AUXILIARY EQUIPMENT	AC
RATED VOLTAGE AUXILIARY DEVICE	230 V
RATED SWITCH CURRENT AUXILIARY DEVICE	0 A
OVERVOLTAGE CATEGORY	III
POLLUTION DEGREE	2
LIFESPAN, ELECTRICAL	4000 operations

Technical data - mechanical	
FRAME	45 mm
WIDTH IN NUMBER OF MODULAR SPACINGS	3
BUILT-IN WIDTH	54 mm
DEVICE HEIGHT	80 mm
BUILT-IN DEPTH	67 mm
MOUNTING STYLE	Tri-stable slide catch - enables removal from existing busbar combination
DEGREE OF PROTECTION	IP20
DEGREE OF PROTECTION (BUILT IN)	IP40
TERMINALS (TOP AND BOTTOM)	Twin-purpose
TERMINAL PROTECTION	Busbar tag shroud as per VBG4, ÖVE-EN 6
PERMISSIBLE STORAGE AND TRANS TEMP. MIN	-35 °C
PERMISSIBLE STORAGE AND TRANS TEMP. MAX	60 °C
CONTACT POSITION INDICATOR	red / green
THICKNESS OF BUSBAR MATERIAL	0.8 - 2 Square Millimeter
CLIMATIC PROOFING	IEC/EN 61009
LIFESPAN, MECHANICAL	20000 operations

## Design verification as per IEC/EN 61439 - technical data

RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	10 A
EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT	5.5 W
AMBIENT OPERATING TEMPERATURE - MIN	-25 °C
AMBIENT OPERATING TEMPERATURE - MAX	40 °C

Design verification as per IEC/EN 61439	
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Meets the product standard's requirements.
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	ls the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	ls the panel builder's responsibility.
10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH	ls the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	Is the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF	Is the panel builder's responsibility.

Additional information	
CURRENT LIMITING CLASS	3
ADDITIONAL EQUIPMENT ATTACHED AT DELIVERY	Fire protection switch
TYPES CONFORM TO	IEC/EN 61009 IEC/EN 62606

INSULATING MATERIAL	
10.10 TEMPERATURE RISE	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Resources	
BROCHURES	eaton-afdd-guidance- brochure-br003010en-en- us.pdf
CATALOGUES	eaton-2020-es-emea-uk- pdd-catalogue-update- july-2020.pdf
CHARACTERISTIC CURVE	eaton-xpole-afdd- characteristic-curve.jpg eaton-xpole-afdd- characteristic-curve- 002.jpg
DECLARATIONS OF CONFORMITY	DA-DC-03 AFDD
DRAWINGS	eaton-xpole-afdd-dimensions.jpg  eaton-xpole-afdd-3d-drawing-004.jpg  eaton-xpole-afdd-3d-
	drawing-002.jpg
ECAD MODEL	ETN.AFDD-10 2 C 003-A
INSTALLATION INSTRUCTIONS	<u>IL019126ZU</u> <u>IL019125ZU</u>
INSTALLATION VIDEOS	Arc Fault Detection Device - AFDD+
MCAD MODEL	eaton-afdd-in- combination-with-rcbos- drawings-afdd.dwg  eaton-afdd-in- combination-with-rcbos- 3d-models-afdd.stp
TECHNICAL DATA SHEETS	eaton-afdd-catalog-tech- en-us.pdf
WIRING DIAGRAMS	eaton-xpole-afdd-wiring- diagram.jpg

PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	
DATE:	



## **Eaton Corporation plc**

Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









