

# Specifications



Photo is representative



## Eaton 188257

Eaton Moeller® series MSC-DM DOL starter,  
380 V 400 V 415 V: 0.12, 0.18 kW, Ir= 0.4 -  
0.63 A, 24 V DC, DC

### General specifications

PRODUCT NAME	Eaton Moeller® series MSC-DM DOL starter
CATALOG NUMBER	188257
MODEL CODE	MSC-DM-0,63-M7(24VDC)
EAN	4015081861422
PRODUCT LENGTH/DEPTH	76 mm
PRODUCT HEIGHT	170 mm
PRODUCT WIDTH	45 mm
PRODUCT WEIGHT	0.602 kg
CERTIFICATIONS	CSA UL File No.: E123500 CE CSA File No.: 012528 IEC/EN 60947-4-1 UL CSA-C22.2 No. 14-10 UL Category Control No.: NKJH VDE 0660 CSA Class No.: 3211-04 UL60947-4-1A

## Features & Functions

<b>FITTED WITH:</b>	Short-circuit release
<b>FUNCTIONS</b>	Temperature compensated overload protection

## Climatic environmental conditions

<b>ALTITUDE</b>	Max. 2000 m
<b>AMBIENT OPERATING TEMPERATURE - MIN</b>	-25 °C
<b>AMBIENT OPERATING TEMPERATURE - MAX</b>	55 °C

## General

<b>CLASS</b>	CLASS 10 A
<b>CONNECTION</b>	Screw terminals
<b>CONNECTION TO SMARTWIRE-DT</b>	No
<b>COORDINATION TYPE</b>	2
<b>DEGREE OF PROTECTION</b>	IP20 NEMA Other
<b>MODEL</b>	IEC/UL starter
<b>MOUNTING METHOD</b>	DIN rail
<b>NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)</b>	0
<b>NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)</b>	1
<b>OVERLOAD RELEASE CURRENT SETTING - MIN</b>	0.4 A
<b>OVERLOAD RELEASE CURRENT SETTING - MAX</b>	0.63 A
<b>OVERVOLTAGE CATEGORY</b>	III
<b>POLLUTION DEGREE</b>	3
<b>RATED IMPULSE WITHSTAND VOLTAGE (UIMP)</b>	6000 V AC
<b>SUITABLE FOR</b>	Also motors with efficiency class IE3
<b>TYPE</b>	Starter with Bi-Metal release
<b>VOLTAGE TYPE</b>	DC

## Electrical rating

<b>RATED OPERATIONAL CURRENT (IE)</b>	0.6 A
<b>RATED OPERATIONAL CURRENT (IE) AT AC-3, 380 V, 400 V, 415 V</b>	0.63 A
<b>RATED OPERATIONAL POWER AT AC-3, 220/230 V, 50 HZ</b>	0.09 kW
<b>RATED OPERATIONAL POWER AT AC-3, 380/400 V, 50 HZ</b>	0.18 kW
<b>RATED OPERATIONAL</b>	230 - 415 V AC

## Short-circuit rating

**RATED CONDITIONAL  
SHORT-CIRCUIT CURRENT  
(IQ), TYPE 2, 380 V, 400 V,  
415 V**

50000 A

**SHORT-CIRCUIT RELEASE  
(IRM) - MAX**

9.8 A

## VOLTAGE

**SWITCHING CAPACITY  
(AUXILIARY CONTACTS,  
GENERAL USE)**

1 A, 250 V DC, (UL/CSA)  
15 A, 600 V AC, (UL/CSA)

**SWITCHING CAPACITY  
(AUXILIARY CONTACTS,  
PILOT DUTY)**

A600, AC operated  
(UL/CSA)  
P300, DC operated  
(UL/CSA)

## Magnet system

**POWER CONSUMPTION  
(SEALING) AT DC**

2.6 W

**RATED CONTROL SUPPLY  
VOLTAGE (US) AT AC, 50  
HZ - MIN**

0 V

**RATED CONTROL SUPPLY  
VOLTAGE (US) AT AC, 50  
HZ - MAX**

0 V

**RATED CONTROL SUPPLY  
VOLTAGE (US) AT AC, 60  
HZ - MIN**

0 V

**RATED CONTROL SUPPLY  
VOLTAGE (US) AT AC, 60  
HZ - MAX**

0 V

**RATED CONTROL SUPPLY  
VOLTAGE (US) AT DC -  
MIN**

24 V

**RATED CONTROL SUPPLY  
VOLTAGE (US) AT DC -  
MAX**

24 V

## Design verification

**10.2.2 CORROSION RESISTANCE** Meets the product standard's requirements.

**10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES** Meets the product standard's requirements.

**10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT** Meets the product standard's requirements.

**10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS** Meets the product standard's requirements.

**10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION** Meets the product standard's requirements.

**10.2.5 LIFTING** Does not apply, since the entire switchgear needs to be evaluated.

**10.2.6 MECHANICAL IMPACT** Does not apply, since the entire switchgear needs to be evaluated.

**10.2.7 INSCRIPTIONS** Meets the product standard's requirements.

**10.3 DEGREE OF PROTECTION OF ASSEMBLIES** Does not apply, since the entire switchgear needs to be evaluated.

**10.4 CLEARANCES AND CREEPAGE DISTANCES** Meets the product standard's requirements.

**10.5 PROTECTION AGAINST ELECTRIC SHOCK** Does not apply, since the entire switchgear needs to be evaluated.

**10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS** Does not apply, since the entire switchgear needs to be evaluated.

**10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS** Is the panel builder's responsibility.

**10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS** Is the panel builder's responsibility.

**10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH** Is the panel builder's responsibility.

**10.9.3 IMPULSE WITHSTAND VOLTAGE** Is the panel builder's responsibility.

**10.9.4 TESTING OF ENCLOSURES MADE OF** Is the panel builder's responsibility.

## Resources

### BROCHURES

[eaton-msfs-motor-starter-feeder-system-brochure-br034005en-en-us.pdf](#)

[eaton-motor-starters-system-xstart-brochure-br03407001en-en-us.pdf](#)

### CATALOGUES

[eaton-product-overview-for-machinery-catalogue-ca08103003zen-en-us.pdf](#)

[Product Range Catalog Switching and protecting motors](#)

### DECLARATIONS OF CONFORMITY

[eaton-dol-starter-declaration-of-conformity-uk251157en.pdf](#)

[eaton-dol-starter-declaration-of-conformity-eu250674en.pdf](#)

### DRAWINGS

[eaton-manual-motor-starters-msc-d-dol-starter-dimensions-002.eps](#)

[eaton-manual-motor-starters-mounting-msc-d-dol-starter-3d-drawing.eps](#)

[eaton-manual-motor-starters-msc-d-dol-starter-3d-drawing-002.eps](#)

[eaton-general-ie-ready-dilm-contactor-standards.eps](#)

### ECAD MODEL

[ETN.188257.edz](#)

### INSTALLATION INSTRUCTIONS

[IL034030ZU](#)

### INSTALLATION VIDEOS

[WIN-WIN with push-in technology](#)

### MCAD MODEL

[DA-CD-msc\\_dm](#)

[DA-CS-msc\\_dm](#)

### SALES NOTES

[eaton-link-module-for-motor-starters-pkz-flyer-fl034003en-en-us.pdf](#)

### WIRING DIAGRAMS

[eaton-manual-motor-starters-device-msc-d-dol-starter-wiring-diagram.eps](#)

INSULATING MATERIAL	
10.10 TEMPERATURE RISE	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

PROJECT NAME:
PROJECT NUMBER:
PREPARED BY:
DATE:



**Eaton Corporation plc**  
Eaton House  
30 Pembroke Road  
Dublin 4, Ireland  
Eaton.com

Follow us on social media to get the latest product and support information.

