## Specifications



## Photo is representative





## Eaton 188283

Eaton Moeller® series MSC-DM DOL starter, 380 V 400 V 415 V: 0.37, 0.55 kW, Ir= 1 - 1.6 A, 230 V 50 Hz, 240 V 60 Hz, AC

| General specifications  |  |
|-------------------------|--|
| PRODUCT NAME            | Eaton Moeller® series<br>MSC-DM DOL starter  |
| CATALOG NUMBER          | 188283   |
| MODEL CODE              | MSC-DM-1,6-<br>M7(230V50HZ)  |
| EAN                     | 4015081861682  |
| PRODUCT<br>LENGTH/DEPTH | 76 mm  |
| PRODUCT HEIGHT          | 170 mm   |
| PRODUCT WIDTH           | 45 mm  |
| PRODUCT WEIGHT          | 0.58 kg  |
| CERTIFICATIONS          | CSA-C22.2 No. 14-10<br>VDE 0660<br>CSA Class No.: 3211-04<br>CSA File No.: 012528<br>IEC/EN 60947-4-1<br>UL60947-4-1A<br>UL<br>CE<br>UL File No.: E123500<br>CSA<br>UL Category Control No.:<br>NKJH |



| Features & Functions |   |
|----------------------|---|
| FITTED WITH:         | Short-circuit release                       |
| FUNCTIONS            | Temperature compensated overload protection |

| General   |                                       |
|---|---------------------------------------|
| CLASS   | CLASS 10 A                            |
| CONNECTION  | Screw terminals                       |
| CONNECTION TO<br>SMARTWIRE-DT                           | No                                    |
| COORDINATION TYPE                                       | 2                                     |
| DEGREE OF PROTECTION                                    | IP20<br>NEMA Other                    |
| MODEL   | IEC/UL starter                        |
| MOUNTING METHOD   | DIN rail                              |
| NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS) | 0                                     |
| NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)   | 1                                     |
| OVERLOAD RELEASE<br>CURRENT SETTING - MIN               | 1 A                                   |
| OVERLOAD RELEASE<br>CURRENT SETTING - MAX               | 1.6 A                                 |
| OVERVOLTAGE<br>CATEGORY                                 | III                                   |
| POLLUTION DEGREE  | 3                                     |
| RATED IMPULSE<br>WITHSTAND VOLTAGE<br>(UIMP)            | 6000 V AC                             |
| SUITABLE FOR  | Also motors with efficiency class IE3 |
| ТҮРЕ  | Starter with Bi-Metal release         |
| VOLTAGE TYPE  | AC                                    |

| Climatic environmental conditions      |             |
|--|-------------|
| ALTITUDE                               | Max. 2000 m |
| AMBIENT OPERATING TEMPERATURE - MIN    | -25 °C      |
| AMBIENT OPERATING<br>TEMPERATURE - MAX | 55 °C       |

| Electrical rating   |                |
|---|----------------|
| RATED OPERATIONAL CURRENT (IE)                                    | 1.5 A          |
| RATED OPERATIONAL<br>CURRENT (IE) AT AC-3,<br>380 V, 400 V, 415 V | 1.6 A          |
| RATED OPERATIONAL<br>POWER AT AC-3, 220/230<br>V, 50 HZ           | 0.25 kW        |
| RATED OPERATIONAL<br>POWER AT AC-3, 380/400<br>V, 50 HZ           | 0.55 kW        |
| RATED OPERATIONAL   | 230 - 415 V AC |

| VOLTAGE  |  |
|--|--|
| SWITCHING CAPACITY<br>(AUXILIARY CONTACTS,<br>GENERAL USE) | 15 A, 600 V AC, (UL/CSA)<br>1 A, 250 V DC, (UL/CSA)            |
| SWITCHING CAPACITY<br>(AUXILIARY CONTACTS,<br>PILOT DUTY)  | A600, AC operated<br>(UL/CSA)<br>P300, DC operated<br>(UL/CSA) |

| Short-circuit rating   |         |
|--|---------|
| RATED CONDITIONAL<br>SHORT-CIRCUIT CURRENT<br>(IQ), TYPE 2, 380 V, 400 V,<br>415 V | 50000 A |
| SHORT-CIRCUIT RELEASE<br>(IRM) - MAX   | 24.8 A  |

| Magnet system  |   |
|--|---|
| POWER CONSUMPTION,<br>SEALING, 50 HZ                       | 1.4 W, Dual-frequency coil<br>in a cold state and 1.0 x<br>Us, at 50 Hz |
| RATED CONTROL SUPPLY<br>VOLTAGE (US) AT AC, 50<br>HZ - MIN | 230 V   |
| RATED CONTROL SUPPLY<br>VOLTAGE (US) AT AC, 50<br>HZ - MAX | 230 V   |
| RATED CONTROL SUPPLY<br>VOLTAGE (US) AT AC, 60<br>HZ - MIN | 0 V   |
| RATED CONTROL SUPPLY<br>VOLTAGE (US) AT AC, 60<br>HZ - MAX | 0 V   |
| RATED CONTROL SUPPLY<br>VOLTAGE (US) AT DC -<br>MIN        | 0 V   |
| RATED CONTROL SUPPLY<br>VOLTAGE (US) AT DC -<br>MAX        | 0 V   |

| Design verification   |  |
|---|--|
| 10.2.2 CORROSION<br>RESISTANCE  | Meets the product standard's requirements.                         |
| 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES                            | Meets the product standard's requirements.                         |
| 10.2.3.2 VERIFICATION OF<br>RESISTANCE OF<br>INSULATING MATERIALS<br>TO NORMAL HEAT | Meets the product standard's requirements.                         |
| 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS    | Meets the product standard's requirements.                         |
| 10.2.4 RESISTANCE TO<br>ULTRA-VIOLET (UV)<br>RADIATION                              | Meets the product standard's requirements.                         |
| 10.2.5 LIFTING  | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 MECHANICAL<br>IMPACT   | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 INSCRIPTIONS   | Meets the product standard's requirements.                         |
| 10.3 DEGREE OF PROTECTION OF ASSEMBLIES   | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 CLEARANCES AND CREEPAGE DISTANCES  | Meets the product standard's requirements.                         |
| 10.5 PROTECTION<br>AGAINST ELECTRIC<br>SHOCK  | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS                              | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS                                   | ls the panel builder's responsibility.                             |
| 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS  | Is the panel builder's responsibility.                             |
| 10.9.2 POWER-<br>FREQUENCY ELECTRIC<br>STRENGTH                                     | ls the panel builder's responsibility.                             |
| 10.9.3 IMPULSE<br>WITHSTAND VOLTAGE   | ls the panel builder's responsibility.                             |
| 10.9.4 TESTING OF<br>ENCLOSURES MADE OF   | Is the panel builder's responsibility.                             |
|   |  |

| Resources                    |  |
|------------------------------|--|
| BROCHURES                    | eaton-msfs-motor-starter-feeder-system-brochure-br034005en-en-us.pdf  eaton-motor-starters-system-xstart-brochure-br03407001en-en-us.pdf   |
| CATALOGUES                   | eaton-product-overview-for-machinery-catalogue-ca08103003zen-en-us.pdf  Product Range Catalog Switching and protecting motors  |
| DECLARATIONS OF CONFORMITY   | eaton-dol-starter-<br>declaration-of-conformity-<br>uk251157en.pdf<br>eaton-dol-starter-<br>declaration-of-conformity-<br>eu250674en.pdf   |
| DRAWINGS                     | eaton-manual-motor-starters-msc-d-dol-starter-dimensions-002.eps  eaton-general-ie-ready-dilm-contactor-standards.eps  eaton-manual-motor-starters-msc-d-dol-starter-3d-drawing-002.eps  eaton-manual-motor-starters-mounting-msc-d-dol-starter-3d-drawing.eps |
| ECAD MODEL                   | ETN.188283.edz   |
| INSTALLATION<br>INSTRUCTIONS | <u>IL034030ZU</u>  |
| INSTALLATION VIDEOS          | WIN-WIN with push-in technology  |
| MCAD MODEL                   | DA-CS-msc dm  DA-CD-msc dm   |
| SALES NOTES                  | eaton-link-module-for-<br>motor-starters-pkz-flyer-<br>fl034003en-en-us.pdf  |
| WIRING DIAGRAMS              | eaton-manual-motor-<br>starters-device-msc-d-dol-<br>starter-wiring-diagram.eps  |

| INSULATING MATERIAL                 |  |
|-------------------------------------|--|
| 10.10 TEMPERATURE RISE              | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 SHORT-CIRCUIT<br>RATING       | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.12 ELECTROMAGNETIC COMPATIBILITY | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.13 MECHANICAL<br>FUNCTION        | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |

| PROJECT NAME:   |  |
|-----------------|--|
| PROJECT NUMBER: |  |
| PREPARED BY:    |  |
| DATE:           |  |



## **Eaton Corporation plc**

Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









