

Specifikace



Foto je ilustrační



Eaton 191582

Eaton Moeller series NZM - Molded Case Circuit Breaker. NZM3 PXR20 circuit breaker, 450A, 3p, withdrawable unit, N, 3

General specifications

| | |
|-----------------------------|---|
| PRODUCT NAME | Eaton Moeller series NZM molded case circuit breaker electronic |
| CATALOG NUMBER | 191582 |
| EAN | 4015081920945 |
| PRODUCT LENGTH/DEPTH | 260 mm |
| PRODUCT HEIGHT | 346 mm |
| PRODUCT WIDTH | 185 mm |
| PRODUCT WEIGHT | 18.07 kg |
| COMPLIANCES | RoHS conform |
| CERTIFICATIONS | IEC/EN 60947 IEC |
| MODEL CODE | NZMN3-MX450-AVE |



Powering Business Worldwide

Technické údaje produktu

| | |
|---|--|
| AMPERAGE RATING | 450 A |
| VOLTAGE RATING | 690 V - 690 V |
| CIRCUIT BREAKER FRAME TYPE | NZM3 |
| ACCESSORIES REQUIRED | NZM3-XAVS |
| 10.10 TEMPERATURE RISE | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 SHORT-CIRCUIT RATING | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 ELECTROMAGNETIC COMPATIBILITY | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 MECHANICAL FUNCTION | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |
| 10.2.2 CORROSION RESISTANCE | Meets the product standard's requirements. |
| 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES | Meets the product standard's requirements. |
| 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT | Meets the product standard's requirements. |
| 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS | Meets the product standard's requirements. |
| 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION | Meets the product standard's requirements. |
| 10.2.5 LIFTING | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 MECHANICAL IMPACT | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 INSCRIPTIONS | Meets the product standard's requirements. |

Zdroje

| | |
|----------------------------|---|
| DECLARATIONS OF CONFORMITY | eaton-molded-case-circuit-breaker-declaration-of-conformity-eu250293en.pdf |
| CHARACTERISTIC CURVE | eaton-circuit-breaker-nzm-mccb-characteristic-curve-029.eps eaton-circuit-breaker-nzm-mccb-characteristic-curve-011.eps eaton-circuit-breaker-nzm-mccb-characteristic-curve-015.eps |
| INSTALAČNÍ NÁVODY | eaton-circuit-breaker-basic-unit-bg3-il012100zu.pdf |
| MCAD MODEL | DA-CD-nzm3_xave DA-CS-nzm3_xave |
| VÝKRESY | eaton-circuit-breaker-switch-nzm-mccb-dimensions-016.eps eaton-circuit-breaker-nzm-mccb-dimensions-020.eps |

| | |
|---|--|
| 10.3 DEGREE OF PROTECTION OF ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 CLEARANCES AND CREEPAGE DISTANCES | Meets the product standard's requirements. |
| 10.5 PROTECTION AGAINST ELECTRIC SHOCK | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS | Is the panel builder's responsibility. |
| 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS | Is the panel builder's responsibility. |
| 10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH | Is the panel builder's responsibility. |
| 10.9.3 IMPULSE WITHSTAND VOLTAGE | Is the panel builder's responsibility. |
| 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL | Is the panel builder's responsibility. |
| FITTED WITH: | Thermal protection |
| POLLUTION DEGREE | 3 |
| MOUNTING METHOD | Withdrawable Built-in device slide-in technique (withdrawable) |
| CLIMATIC PROOFING | Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 |
| EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT | 60.75 W |
| UTILIZATION CATEGORY | A (IEC/EN 60947-2) |
| ISOLATION | 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) |
| AMBIENT OPERATING TEMPERATURE - MAX | 70 °C |
| AMBIENT OPERATING TEMPERATURE - MIN | -25 °C |
| AMBIENT STORAGE TEMPERATURE - MAX | 70 °C |
| AMBIENT STORAGE TEMPERATURE - MIN | 40 °C |
| PROTECTION AGAINST | Finger and back-of-hand |

| | |
|---|--|
| DIRECT CONTACT | proof to VDE 0106 part 100 |
| RATED INSULATION VOLTAGE (UI) | 690 V |
| RATED OPERATING POWER AT AC-3, 230 V | 132 kW |
| RATED OPERATING POWER AT AC-3, 400 V | 250 kW |
| SWITCH OFF TECHNIQUE | Electronic |
| DEGREE OF PROTECTION | IP20 (basic degree of protection, in the operating controls area) IP20 |
| DIRECTION OF INCOMING SUPPLY | As required |
| ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT | Other |
| LIFESPAN, MECHANICAL | 15000 operations |
| OVERVOLTAGE CATEGORY | III |
| RATED OPERATIONAL CURRENT | 437 A (400 V AC-3) |
| DEGREE OF PROTECTION (IP), FRONT SIDE | IP66 (with door coupling rotary handle) IP40 (with insulating surround) |
| DEGREE OF PROTECTION (TERMINATIONS) | IP10 (tunnel terminal) IP00 (terminations, phase isolator and strip terminal) |
| NUMBER OF POLES | Three-pole |
| TERMINAL CAPACITY (COPPER STRIP) | <p>Max. 10 segments of 24 mm x 1 mm + 5 segments of 24 mm x 1 mm at box terminal</p> <p>Min. 6 segments of 16 mm x 0.8 mm at rear-side connection (punched)</p> <p>Max. 8 segments of 24 mm x 1 mm (2x) at box terminal</p> <p>Min. 6 segments of 16 mm x 0.8 mm at box terminal</p> <p>10 segments of 50 mm x 1 mm (2x) at rear-side width extension</p> <p>Max. 10 segments of 32 mm x 1 mm + 5 segments of 32 mm x 1 mm at rear-side connection (punched)</p> |
| LIFESPAN, ELECTRICAL | 3000 operations at 690 V AC-1 2000 operations at 400 V AC-3 |

| | |
|------------------|--|
| | 5000 operations at 400 V AC-1 2000 operations at 415 V AC-3 2000 operations at 690 V AC-3 5000 operations at 415 V AC-1 |
| FUNCTIONS | Phase failure sensitive Motor protection |
| TYPE | Circuit breaker |

SPECIAL FEATURES

- IEC/EN 60947-2 with characteristic conforming to IEC/EN 60947-4-1 with phase failure sensitivity
- The circuit-breaker fulfills all requirements for AC-3 switching category.
- R.m.s. value measurement and "thermal memory"
- Adjustable time delay setting to overcome current peaks I_r at $6 \times I_r$ also infinity (without overload releases)
- All AC-3 rating data applies to direct switching by the circuit-breaker under normal operating conditions. If, for example, a contactor takes over AC-3 switching under normal operating conditions, the full rated uninterrupted current applies to the circuit-breaker, $I_n = I_u$.
- Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity

of the circuit breaker (Rated short-circuit breaking capacity I_{cn})

- Rated current = rated uninterrupted current: 450 A
- Terminal capacity hint: Up to 240 mm² can be connected depending on the cable manufacturer.

| | |
|---|--|
| APPLICATION | Use in unearthed supply systems at 690 V |
| SHOCK RESISTANCE | 20 g (half-sinusoidal shock 20 ms) |
| RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (I_N) | 450 A |
| RATED SHORT-TIME WITHSTAND CURRENT (T = 0.3 S) | 3.3 kA |
| RATED SHORT-TIME WITHSTAND CURRENT (T = 1 S) | 3.3 kA |
| SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MAX | 5400 A |
| SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MIN | 900 A |
| HANDLE TYPE | Rocker lever |
| INSTANTANEOUS CURRENT SETTING (II) - MAX | 12 A |
| INSTANTANEOUS CURRENT SETTING (II) - MIN | 2 A |
| NUMBER OF OPERATIONS PER HOUR - MAX | 60 |
| OVERLOAD CURRENT SETTING (IR) - MAX | 450 A |
| OVERLOAD CURRENT SETTING (IR) - MIN | 180 A |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 230 V, | 85 kA |

| | |
|--|---|
| 50/60 HZ | |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 400/415 V, 50/60 HZ | 35 kA |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 440 V, 50/60 HZ | 35 kA |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 525 V, 50/60 HZ | 13 kA |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 690 V, 50/60 HZ | 5 kA |
| STANDARD TERMINALS | Screw terminal |
| OPTIONAL TERMINALS | Box terminal. Connection on rear. Tunnel terminal |
| RELEASE SYSTEM | Electronic release |
| SHORT-CIRCUIT TOTAL BREAKTIME | < 10 ms |
| TERMINAL CAPACITY (ALUMINUM SOLID CONDUCTOR/CABLE) | 16 mm ² (1x) at tunnel terminal |
| TERMINAL CAPACITY (ALUMINUM STRANDED CONDUCTOR/CABLE) | 50 mm ² - 240 mm ² (2x) at 2-hole tunnel terminal 50 mm ² - 240 mm ² (1x) at 2-hole tunnel terminal 25 mm ² - 185 mm ² (1x) at tunnel terminal |
| TERMINAL CAPACITY (CONTROL CABLE) | 0.75 mm ² - 2.5 mm ² (1x) 0.75 mm ² - 1.5 mm ² (2x) |
| TERMINAL CAPACITY (COPPER BUSBAR) | Max. 30 mm x 10 mm + 30 mm x 5 mm direct at switch rear-side connection M10 at rear-side screw connection Min. 20 mm x 5 mm direct at switch rear-side connection Max. 10 mm x 50 mm (2x) at rear-side width extension |
| TERMINAL CAPACITY (COPPER SOLID CONDUCTOR/CABLE) | 300 mm ² (2x) at rear-side width extension 16 mm ² (1x) at tunnel terminal 16 mm ² (1x) direct at switch rear-side connection 16 mm ² (2x) at box |

| | |
|--|--|
| | terminal 16 mm ² (2x) direct at switch rear-side connection |
| TERMINAL CAPACITY (COPPER STRANDED CONDUCTOR/CABLE) | 16 mm ² - 185 mm ² (1x) at 1-hole tunnel terminal 35 mm ² - 240 mm ² (1x) at box terminal 25 mm ² - 240 mm ² (1x) direct at switch rear-side connection 25 mm ² - 120 mm ² (2x) at box terminal 25 mm ² - 240 mm ² (2x) direct at switch rear-side connection |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICU (IEC/EN 60947) AT 400/415 V, 50/60 HZ | 35 kA |
| RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 400/415 V, 50/60 HZ | 105 kA |
| RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 440 V, 50/60 HZ | 74 kA |
| RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 525 V, 50/60 HZ | 53 kA |
| RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 690 V, 50/60 HZ | 40 kA |
| RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 240 V, 50/60 HZ | 187 kA |
| RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT AUXILIARY CONTACTS | 6000 V |
| RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT MAIN CONTACTS | 8000 V |

PROJECT NAME:

PROJECT NUMBER:

PREPARED BY:

DATUM:



Eaton Corporation Plc.

Eaton House
30 Pembroke Road
Dublin 4, Irsko
Eaton.com

Follow us on social media to get the latest product and support information.



© 2025 Eaton. Všechna práva vyhrazena.