Specifications



Photo is representative





Eaton 192064

Eaton Moeller series NZM - Molded Case Circuit Breaker. NZM2 PXR25, class 1, 100A, 4p, variable, Screw terminal, plug-in technology, N, 2

General specifications	
PRODUCT NAME	Eaton Moeller series NZM molded case circuit breaker electronic
CATALOG NUMBER	192064
MODEL CODE	NZMN2-4-PX100/VAR-SVE
EAN	4015081926152
PRODUCT LENGTH/DEPTH	190 mm
PRODUCT HEIGHT	160 mm
PRODUCT WIDTH	145 mm
PRODUCT WEIGHT	3 kg
COMPLIANCES	RoHS conform
CERTIFICATIONS	IEC/EN 60947 IEC
GLOBAL CATALOG	192064



Product specification	S
AMPERAGE RATING	100 A
VOLTAGE RATING	690 V - 690 V
CIRCUIT BREAKER FRAME TYPE	NZM2
FEATURES	Protection unit Motor drive optional
ACCESSORIES REQUIRED	NZM2-4-XSVS
10.10 TEMPERATURE RISE	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	ls the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Meets the product standard's requirements.
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.

Resources	
BROCHURES	eaton-digital-nzm- brochure-br013003en-en- us.pdf
	eaton-feerum-the-whole- grain-solution-success- story-en-us.pdf
CATALOGS	eaton-digital-nzm-catalog- ca013003en-en-us.pdf
CHARACTERISTIC CURVE	eaton-circuit-breaker-nzm- mccb-characteristic-curve- 060.eps
	eaton-circuit-breaker-nzm- mccb-characteristic-curve- 059.eps
DECLARATIONS OF CONFORMITY	eaton-molded-case-circuit- breaker-declaration-of- conformity- eu250291en.pdf
	eaton-circuit-breaker- switch-nzm-mccb- dimensions-017.eps
DRAWINGS	eaton-circuit-breaker- adapter-nzm-mccb- dimensions-002.eps
	eaton-circuit-breaker-nzm- mccb-dimensions-035.eps
INSTALLATION INSTRUCTIONS	eaton-circuit-breakers- nzmb-nzmn-basic-unit- bg2-instruction-leaflet- il012099zu.pdf
	eaton-circuit-breaker-plug- in-adapter-nzm2- il01219023z.pdf
INSTALLATION VIDEOS	The new digital NZM Range
	Introduction of the new digital circuit breaker NZM
MCAD MODEL	DA-CS-nzm2 4p DA-CD-nzm2 4p
PEP ECO-PASSPORT	eaton-molded-case- switches-pep-eato-00185- v0101-en.pdf
TECHNICAL DATA SHEETS	eaton-nzm-technical- information-sheet

10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	ls the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	ls the panel builder's responsibility.
10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH	ls the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	ls the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	ls the panel builder's responsibility.
ENCLOSURES MADE OF	· ·
ENCLOSURES MADE OF INSULATING MATERIAL	responsibility.
ENCLOSURES MADE OF INSULATING MATERIAL POLLUTION DEGREE	responsibility. 3 Built-in device plug-in technique
ENCLOSURES MADE OF INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD	responsibility. 3 Built-in device plug-in technique Plug-in unit Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to
ENCLOSURES MADE OF INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT-	responsibility. 3 Built-in device plug-in technique Plug-in unit Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78
ENCLOSURES MADE OF INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT	responsibility. 3 Built-in device plug-in technique Plug-in unit Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 8.25 W
ENCLOSURES MADE OF INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT UTILIZATION CATEGORY	responsibility. 3 Built-in device plug-in technique Plug-in unit Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 8.25 W A (IEC/EN 60947-2) 300 V AC (between the auxiliary contacts) 500 V AC (between auxiliary contacts and
ENCLOSURES MADE OF INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT UTILIZATION CATEGORY ISOLATION AMBIENT OPERATING	responsibility. 3 Built-in device plug-in technique Plug-in unit Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 8.25 W A (IEC/EN 60947-2) 300 V AC (between the auxiliary contacts) 500 V AC (between auxiliary contacts and main contacts)
ENCLOSURES MADE OF INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT UTILIZATION CATEGORY ISOLATION AMBIENT OPERATING TEMPERATURE - MAX AMBIENT OPERATING	responsibility. 3 Built-in device plug-in technique Plug-in unit Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 8.25 W A (IEC/EN 60947-2) 300 V AC (between the auxiliary contacts) 500 V AC (between auxiliary contacts and main contacts) 70 °C

NUMBER OF AUXILIARY CONTACTS (CHANGE-OVER CONTACTS)	0
NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)	0
NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)	0
PROTECTION AGAINST DIRECT CONTACT	Finger and back-of-hand proof to DIN EN 50274/VDE 0106 part 110
DEGREE OF PROTECTION	IP20 (basic degree of protection, in the operating controls area) IP20
DIRECTION OF INCOMING SUPPLY	As required
ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT	Other
CURRENT RATING OF NEUTRAL CONDUCTOR	0 - 60% - 100% of phase conductor
LIFESPAN, MECHANICAL	20000 operations
OVERVOLTAGE CATEGORY	III
DEGREE OF PROTECTION (IP), FRONT SIDE	IP40 (with insulating surround) IP66 (with door coupling rotary handle)
DEGREE OF PROTECTION (TERMINATIONS)	IP00 (terminations, phase isolator and strip terminal)
	IP10 (tunnel terminal)
NUMBER OF POLES	Four-pole
TERMINAL CAPACITY (COPPER STRIP)	Min. 2 segements of 16 mm x 0.8 mm at rear-side connection (punched) Min. 2 segments of 9 mm x 0.8 mm at box terminal Max. 10 segments of 24 mm x 0.8 mm at rear-side connection (punched) Max. 10 segments of 16 mm x 0.8 mm at box terminal Max. 8 segments of 24 mm x 1 mm (2x) at box terminal
LIFESPAN, ELECTRICAL	10000 operations at 400 V AC-1 7500 operations at 690 V AC-1 10000 operations at 415 V

FUNCTIONS Systems, cable, selectivity and generator protection TYPE Circuit breaker LSI overload protection and delayed and non-delayed short-circuit protective device energy measurement, r.m.s. value measurement, r.m.s. value measurement, or configuration and test function with Power Xpert Protection Manager software Interface module in equipment supplied. Optionally communication-capable with internal Modbus RTU module or CAM Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit urrents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit urrents at the installation location exceed the switching capacity lcn) Rated current = rated uninterrupted current: 100 A APPLICATION Use in unearthed supply systems at 690 V SHOCK RESISTANCE 20 g (half-sinusoidal shock 20 ms) POSITION OF CONNECTION FOR MAIN CURRENT CIRCUIT RATED OPERATIONAL CURRENT FOR SPECIFIED		
TYPE Circuit breaker - LSI overload protection and delayed and non-delayed short-circuit protective device - energy measurement, and "thermal memory" - USB interface for configuration and test function with Power Xpert Protection Manager software - Interface module in equipment supplied. - Optionally communication-capable with internal Modbus RTU module or CAM - Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit brea		AC-1
LSI overload protection and delayed and non-delayed short-circuit protective device energy measurement, r.m.s. value measurement, and "thermal memory" USB interface for configuration and test function with Power Xpert Protection Manager software Interface module in equipment supplied. Optionally communication-capable with internal Modbus RTU module or CAM Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit breaking capacity lcn) Rated current = rated uninterrupted current: 100 A APPLICATION Use in unearthed supply systems at 690 V SHOCK RESISTANCE 20 g (half-sinusoidal shock 20 ms) POSITION OF CONNECTION FOR MAIN CURRENT CIRCUIT RATED OPERATIONAL	FUNCTIONS	-
protection and delayed and non-delayed short-circuit protective device energy measurement, r.m.s. value measurement, and "thermal memory" USB interface for configuration and test function with Power Xpert Protection Manager software Interface module in equipment supplied. Optionally communication- capable with internal Modbus RTU module or CAM Maximum back-up fuse, if the expected short- circuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit breaking capacity lcn) Rated current = rated uninterrupted current: 100 A APPLICATION Use in unearthed supply systems at 690 V SHOCK RESISTANCE 20 g (half-sinusoidal shock 20 ms) POSITION OF CONNECTION FOR MAIN CURRENT CIRCUIT RATED OPERATIONAL	TYPE	Circuit breaker
SHOCK RESISTANCE 20 g (half-sinusoidal shock 20 ms) POSITION OF CONNECTION FOR MAIN CURRENT CIRCUIT RATED OPERATIONAL systems at 690 V Connection at separate chassis part	SPECIAL FEATURES	protection and delayed and non-delayed short-circuit protective device energy measurement, r.m.s. value measurement, and "thermal memory" USB interface for configuration and test function with Power Xpert Protection Manager software Interface module in equipment supplied. Optionally communication-capable with internal Modbus RTU module or CAM Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit breaking capacity lcn) Rated current = rated uninterrupted
POSITION OF CONNECTION FOR MAIN CURRENT CIRCUIT RATED OPERATIONAL 20 ms) Connection at separate chassis part	APPLICATION	
CONNECTION FOR MAIN CURRENT CIRCUIT RATED OPERATIONAL 100 A	SHOCK RESISTANCE	_
100 A	CONNECTION FOR MAIN	
		100 A

HEAT DISSIPATION (IN)	
RELEASE SYSTEM	Electronic release
SHORT-CIRCUIT TOTAL BREAKTIME	< 10 ms
RATED SHORT-TIME WITHSTAND CURRENT (T = 0.3 S)	1.9 kA
RATED SHORT-TIME WITHSTAND CURRENT (T = 1 S)	1.9 kA
SHORT-CIRCUIT RELEASE DELAYED SETTING - MAX	1000 A
SHORT-CIRCUIT RELEASE DELAYED SETTING - MIN	80 A
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MAX	1800 A
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MIN	200 A
TERMINAL CAPACITY (CONTROL CABLE)	0.75 mm ² - 1.5 mm ² (2x) 0.75 mm ² - 2.5 mm ² (1x)
TERMINAL CAPACITY (COPPER BUSBAR)	Min. 16 mm x 5 mm direct at switch rear-side connection Max. 24 mm x 8 mm direct at switch rear-side connection M8 at rear-side screw connection
TERMINAL CAPACITY (COPPER SOLID CONDUCTOR/CABLE)	6 mm² - 16 mm² (2x) direct at switch rear-side connection 16 mm² (1x) at tunnel terminal 10 mm² - 16 mm² (1x) at box terminal 6 mm² - 16 mm² (2x) at box terminal 10 mm² - 16 mm² (1x) direct at switch rear-side connection
TERMINAL CAPACITY (ALUMINUM SOLID CONDUCTOR/CABLE)	16 mm² (1x) at tunnel terminal
TERMINAL CAPACITY (COPPER STRANDED CONDUCTOR/CABLE)	25 mm² - 70 mm² (2x) at box terminal 25 mm² - 185 mm² (1x) at 1-hole tunnel terminal 25 mm² - 185 mm² (1x) direct at switch rear-side connection 25 mm² - 70 mm² (2x) direct at switch rear-side

	connection 25 mm² - 185 mm² (1x) at box terminal
TERMINAL CAPACITY (ALUMINUM STRANDED CONDUCTOR/CABLE)	25 mm² - 185 mm² (1x) at tunnel terminal
HANDLE TYPE	Rocker lever
SHORT DELAY CURRENT SETTING (ISD) - MAX	10 A
SHORT DELAY CURRENT SETTING (ISD) - MIN	2 A
INSTANTANEOUS CURRENT SETTING (II) - MAX	18 A
INSTANTANEOUS CURRENT SETTING (II) - MIN	2 A
NUMBER OF OPERATIONS PER HOUR - MAX	120
OVERLOAD CURRENT SETTING (IR) - MAX	100 A
OVERLOAD CURRENT SETTING (IR) - MIN	40 A
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 230 V, 50/60 HZ	85 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 400/415 V, 50/60 HZ	50 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 440 V, 50/60 HZ	35 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 525 V, 50/60 HZ	25 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 690 V, 50/60 HZ	3 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 400/415 V, 50/60 HZ	105 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 440 V, 50/60 HZ	74 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 525 V, 50/60 HZ	53 kA

RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 690 V, 50/60 HZ	40 kA
STANDARD TERMINALS	Screw terminal
OPTIONAL TERMINALS	Box terminal. Connection on rear. Tunnel terminal
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 240 V, 50/60 HZ	187 kA
RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT AUXILIARY CONTACTS	6000 V
RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT MAIN CONTACTS	8000 V
RATED INSULATION VOLTAGE (UI)	690 V AC

PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	
DATE:	



Eaton Corporation plc Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









