

# Specifications



Photo is representative



## Eaton 192314

Eaton Moeller series NZM - Molded Case Circuit Breaker. NZM3 PXR25, class 1, 400A, 4p, variable, earth-fault protection, ARMS and zone selectivity, withdrawable unit, N, 3

### General specifications

<b>PRODUCT NAME</b>	Eaton Moeller series NZM molded case circuit breaker electronic
<b>CATALOG NUMBER</b>	192314
<b>EAN</b>	4015081928651
<b>PRODUCT LENGTH/DEPTH</b>	346 mm
<b>PRODUCT HEIGHT</b>	260 mm
<b>PRODUCT WIDTH</b>	230 mm
<b>PRODUCT WEIGHT</b>	6.65 kg
<b>COMPLIANCES</b>	RoHS conform
<b>CERTIFICATIONS</b>	IEC IEC/EN 60947
<b>MODEL CODE</b>	NZMN3-4-PX400/VAR-TAZ-AVE

## Product specifications

<b>AMPERAGE RATING</b>	400 A
<b>VOLTAGE RATING</b>	690 V - 690 V
<b>CIRCUIT BREAKER FRAME TYPE</b>	NZM3
<b>FEATURES</b>	Motor drive optional Protection unit
<b>ACCESSORIES REQUIRED</b>	NZM3-4-XAVS
<b>10.10 TEMPERATURE RISE</b>	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
<b>10.11 SHORT-CIRCUIT RATING</b>	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
<b>10.12 ELECTROMAGNETIC COMPATIBILITY</b>	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
<b>10.13 MECHANICAL FUNCTION</b>	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
<b>10.2.2 CORROSION RESISTANCE</b>	Meets the product standard's requirements.
<b>10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES</b>	Meets the product standard's requirements.
<b>10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT</b>	Meets the product standard's requirements.
<b>10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS</b>	Meets the product standard's requirements.
<b>10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION</b>	Meets the product standard's requirements.
<b>10.2.5 LIFTING</b>	Does not apply, since the entire switchgear needs to be evaluated.
<b>10.2.6 MECHANICAL IMPACT</b>	Does not apply, since the entire switchgear needs to be evaluated.

## Resources

### BROCHURES

[eaton-digital-nzm-brochure-br013003en-en-us.pdf](#)

### CATALOGUES

[eaton-digital-nzm-catalog-ca013003en-en-us.pdf](#)

### CHARACTERISTIC CURVE

[eaton-circuit-breaker-nzm-mccb-characteristic-curve-011.eps](#)

[eaton-circuit-breaker-nzm-mccb-characteristic-curve-015.eps](#)

### DECLARATIONS OF CONFORMITY

[eaton-molded-case-circuit-breaker-declaration-of-conformity-eu250293en.pdf](#)

### DRAWINGS

[eaton-circuit-breaker-withdrawable-unit-nzm-mccb-dimensions-002.eps](#)

[eaton-circuit-breaker-switch-nzm-mccb-dimensions-016.eps](#)

[eaton-circuit-breaker-nzm-mccb-dimensions-021.eps](#)

### INSTALLATION INSTRUCTIONS

[eaton-circuit-breaker-basic-unit-bg3-il012100zu.pdf](#)

### INSTALLATION VIDEOS

[The new digital NZM Range](#)

[Introduction of the new digital circuit breaker NZM](#)

### MCAD MODEL

[DA-CD-nzm3\\_3p](#)

[DA-CS-nzm3\\_3p](#)

### PEP ECO-PASSPORT

[eaton-molded-case-switches-pep-eato-00252-v0101-en.pdf](#)

### TECHNICAL DATA SHEETS

[eaton-nzm-technical-information-sheet](#)

<b>10.2.7 INSCRIPTIONS</b>	Meets the product standard's requirements.
<b>10.3 DEGREE OF PROTECTION OF ASSEMBLIES</b>	Does not apply, since the entire switchgear needs to be evaluated.
<b>10.4 CLEARANCES AND CREEPAGE DISTANCES</b>	Meets the product standard's requirements.
<b>10.5 PROTECTION AGAINST ELECTRIC SHOCK</b>	Does not apply, since the entire switchgear needs to be evaluated.
<b>10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS</b>	Does not apply, since the entire switchgear needs to be evaluated.
<b>10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS</b>	Is the panel builder's responsibility.
<b>10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS</b>	Is the panel builder's responsibility.
<b>10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH</b>	Is the panel builder's responsibility.
<b>10.9.3 IMPULSE WITHSTAND VOLTAGE</b>	Is the panel builder's responsibility.
<b>10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL</b>	Is the panel builder's responsibility.
<b>POLLUTION DEGREE</b>	3
<b>MOUNTING METHOD</b>	Withdrawable Built-in device slide-in technique (withdrawable)
<b>CLIMATIC PROOFING</b>	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78
<b>EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT</b>	72 W
<b>UTILIZATION CATEGORY</b>	A (IEC/EN 60947-2)
<b>ISOLATION</b>	500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts)
<b>AMBIENT OPERATING TEMPERATURE - MAX</b>	70 °C
<b>AMBIENT OPERATING TEMPERATURE - MIN</b>	-25 °C
<b>AMBIENT STORAGE TEMPERATURE - MAX</b>	70 °C
<b>AMBIENT STORAGE TEMPERATURE - MIN</b>	40 °C

**NUMBER OF AUXILIARY****CONTACTS (CHANGE-OVER CONTACTS)**

0

**NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)**

0

**NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)**

0

**PROTECTION AGAINST DIRECT CONTACT**

Finger and back-of-hand proof to DIN EN 50274/VDE 0106 part 110

IP20

**DEGREE OF PROTECTION**

IP20 (basic degree of protection, in the operating controls area)

**DIRECTION OF INCOMING SUPPLY**

As required

**ELECTRICAL****CONNECTION TYPE OF MAIN CIRCUIT**

Other

**CURRENT RATING OF NEUTRAL CONDUCTOR**

0 - 60% - 100% of phase conductor

**LIFESPAN, MECHANICAL**

15000 operations

**OVERVOLTAGE CATEGORY**

III

**DEGREE OF PROTECTION (IP), FRONT SIDE**IP66 (with door coupling rotary handle)  
IP40 (with insulating surround)**DEGREE OF PROTECTION (TERMINATIONS)**IP00 (terminations, phase isolator and strip terminal)  
IP10 (tunnel terminal)**NUMBER OF POLES**

Four-pole

**TERMINAL CAPACITY (COPPER STRIP)**Max. 10 segments of 24 mm x 1 mm + 5 segments of 24 mm x 1 mm  
Min. 6 segments of 16 mm x 0.8 mm at rear-side connection (punched)  
10 segments of 50 mm x 1 mm (2x) at rear-side width extension  
Max. 10 segments of 32 mm x 1 mm + 5 segments of 32 mm x 1 mm at rear-side connection (punched)Max. 8 segments of 24 mm x 1 mm (2x) at box terminal  
Min. 6 segments of 16 mm x 0.8 mm at box terminal

<b>LIFESPAN, ELECTRICAL</b>	3000 operations at 690 V AC-1 5000 operations at 400 V AC-1 5000 operations at 415 V AC-1
<b>FUNCTIONS</b>	Systems, cable, selectivity and generator protection Integrated earth fault protection Earth-fault protection Zone selectivity ARMS maintenance mode
<b>EARTH-FAULT CURRENT SETTING (IG) - MAX</b>	400 x In
<b>TYPE</b>	Circuit breaker
<b>SPECIAL FEATURES</b>	<ul style="list-style-type: none"> <li>• LSIG overload protection and delayed and non-delayed short-circuit protective device, earth-fault protection</li> <li>• Class 1 energy measurement, r.m.s. value measurement, and "thermal memory"</li> <li>• USB interface for configuration and test function with Power Xpert Protection Manager software</li> <li>• Zone selectivity ZSI</li> <li>• Maintenance Mode ARMS</li> <li>• Interface module in equipment supplied.</li> <li>• Optionally communication-capable with internal Modbus RTU module or CAM</li> <li>• Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit breaking capacity)</li> </ul>

Icn)

- Rated current =  
rated  
uninterrupted  
current: 400 A
- Terminal capacity  
hint: Up to 240  
mm<sup>2</sup> can be  
connected  
depending on the  
cable  
manufacturer.

<b>APPLICATION</b>	Use in unearthed supply systems at 690 V
<b>SHOCK RESISTANCE</b>	20 g (half-sinusoidal shock 20 ms)
<b>EARTH-FAULT CURRENT SETTING (IG) - MIN</b>	80 x In
<b>POSITION OF CONNECTION FOR MAIN CURRENT CIRCUIT</b>	Connection at separate chassis part
<b>RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)</b>	400 A
<b>RELEASE SYSTEM</b>	Electronic release
<b>SHORT-CIRCUIT TOTAL BREAKTIME</b>	< 10 ms
<b>RATED SHORT-TIME WITHSTAND CURRENT (T = 0.3 S)</b>	3.3 kA
<b>RATED SHORT-TIME WITHSTAND CURRENT (T = 1 S)</b>	3.3 kA
<b>SHORT-CIRCUIT RELEASE DELAYED SETTING - MAX</b>	4000 A
<b>SHORT-CIRCUIT RELEASE DELAYED SETTING - MIN</b>	320 A
<b>SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MAX</b>	4800 A
<b>SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MIN</b>	800 A
<b>TERMINAL CAPACITY (CONTROL CABLE)</b>	0.75 mm <sup>2</sup> - 1.5 mm <sup>2</sup> (2x) 0.75 mm <sup>2</sup> - 2.5 mm <sup>2</sup> (1x)
<b>TERMINAL CAPACITY (COPPER BUSBAR)</b>	Max. 10 mm x 50 mm (2x) at rear-side width extension Min. 20 mm x 5 mm direct at switch rear-side connection M10 at rear-side screw

	connection Max. 30 mm x 10 mm + 30 mm x 5 mm direct at switch rear-side connection
<b>TERMINAL CAPACITY (COPPER SOLID CONDUCTOR/CABLE)</b>	16 mm <sup>2</sup> (1x) at tunnel terminal 16 mm <sup>2</sup> (2x) direct at switch rear-side connection 16 mm <sup>2</sup> (1x) direct at switch rear-side connection 16 mm <sup>2</sup> (2x) at box terminal 300 mm <sup>2</sup> (2x) at rear-side width extension
<b>TERMINAL CAPACITY (ALUMINUM SOLID CONDUCTOR/CABLE)</b>	16 mm <sup>2</sup> (1x) at tunnel terminal
<b>TERMINAL CAPACITY (COPPER STRANDED CONDUCTOR/CABLE)</b>	35 mm <sup>2</sup> - 240 mm <sup>2</sup> (1x) at box terminal 16 mm <sup>2</sup> - 185 mm <sup>2</sup> (1x) at 1-hole tunnel terminal 25 mm <sup>2</sup> - 240 mm <sup>2</sup> (1x) direct at switch rear-side connection 25 mm <sup>2</sup> - 240 mm <sup>2</sup> (2x) direct at switch rear-side connection 25 mm <sup>2</sup> - 120 mm <sup>2</sup> (2x) at box terminal
<b>TERMINAL CAPACITY (ALUMINUM STRANDED CONDUCTOR/CABLE)</b>	50 mm <sup>2</sup> - 240 mm <sup>2</sup> (2x) at 2-hole tunnel terminal 50 mm <sup>2</sup> - 240 mm <sup>2</sup> (1x) at 2-hole tunnel terminal 25 mm <sup>2</sup> - 185 mm <sup>2</sup> (1x) at tunnel terminal
<b>HANDLE TYPE</b>	Rocker lever
<b>SHORT DELAY CURRENT SETTING (ISD) - MAX</b>	10 A
<b>SHORT DELAY CURRENT SETTING (ISD) - MIN</b>	2 A
<b>INSTANTANEOUS CURRENT SETTING (II) - MAX</b>	12 A
<b>INSTANTANEOUS CURRENT SETTING (II) - MIN</b>	2 A
<b>NUMBER OF OPERATIONS PER HOUR - MAX</b>	60
<b>OVERLOAD CURRENT SETTING (IR) - MAX</b>	400 A
<b>OVERLOAD CURRENT</b>	160 A

**SETTING (IR) - MIN**

**RATED SHORT-CIRCUIT  
BREAKING CAPACITY ICS  
(IEC/EN 60947) AT 230 V,  
50/60 Hz**

85 kA

**RATED SHORT-CIRCUIT  
BREAKING CAPACITY ICS  
(IEC/EN 60947) AT  
400/415 V, 50/60 Hz**

50 kA

**RATED SHORT-CIRCUIT  
BREAKING CAPACITY ICS  
(IEC/EN 60947) AT 440 V,  
50/60 Hz**

35 kA

**RATED SHORT-CIRCUIT  
BREAKING CAPACITY ICS  
(IEC/EN 60947) AT 525 V,  
50/60 Hz**

13 kA

**RATED SHORT-CIRCUIT  
BREAKING CAPACITY ICS  
(IEC/EN 60947) AT 690 V,  
50/60 Hz**

5 kA

**RATED SHORT-CIRCUIT  
MAKING CAPACITY ICM  
AT 400/415 V, 50/60 Hz**

105 kA

**RATED SHORT-CIRCUIT  
MAKING CAPACITY ICM  
AT 440 V, 50/60 Hz**

74 kA

**RATED SHORT-CIRCUIT  
MAKING CAPACITY ICM  
AT 525 V, 50/60 Hz**

53 kA

**RATED SHORT-CIRCUIT  
MAKING CAPACITY ICM  
AT 690 V, 50/60 Hz**

40 kA

**STANDARD TERMINALS**

Screw terminal

**OPTIONAL TERMINALS**

Box terminal. Connection  
on rear. Tunnel terminal

**RATED SHORT-CIRCUIT  
MAKING CAPACITY ICM  
AT 240 V, 50/60 Hz**

187 kA

**RATED IMPULSE  
WITHSTAND VOLTAGE  
(UIMP) AT AUXILIARY  
CONTACTS**

6000 V

**RATED IMPULSE  
WITHSTAND VOLTAGE  
(UIMP) AT MAIN  
CONTACTS**

8000 V

**RATED INSULATION  
VOLTAGE (UI)**

690 V AC

---

**PROJECT NAME:**

**PROJECT NUMBER:**

**PREPARED BY:**

**DATE:**

---



**Eaton Corporation plc**

Eaton House  
30 Pembroke Road  
Dublin 4, Ireland  
Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.

