Specifications



Photo is representative

Eaton 192396

Eaton Moeller® series EMS2 Reversing starter, 24 V DC, 1,5 - 6,5 (AC-53a), 9 (AC-51) A, Push in terminals

| General specification | าร |
|-------------------------|---|
| PRODUCT NAME | Eaton Moeller® series EMS2 Reversing starter |
| CATALOG NUMBER | 192396 |
| MODEL CODE | EMS2-RO-T-9-24VDC |
| EAN | 4015081930937 |
| PRODUCT LENGTH/DEPTH | 114.5 mm |
| PRODUCT HEIGHT | 99 mm |
| PRODUCT WIDTH | 22.5 mm |
| PRODUCT WEIGHT | 0.287 kg |
| CERTIFICATIONS | UL508 IEC/EN 60947-4-2 UL File No.: E29096 UL Category Control No.: NLDX, NLDX7 UL 60947-4-1 CSA-C22.2 No. 60947-4-1- 14 CE marking UL listed Certified by UL for use in Canada UL report applies to both US and Canada |



| Features & Functions | |
|--|--|
| FUNCTIONS DOL start Tempera compens protectio Motor pro Reversing | ture ated overload n otection |

| General | |
|---|--|
| CLASS | CLASS 10 A |
| CONNECTION TO SMARTWIRE-DT | No |
| DEGREE OF PROTECTION | IP20 NEMA Other |
| MODEL | Reversing starter |
| MOUNTING METHOD | Rail mounting possible Top-hat rail fixing (according to IEC/EN 60715, 35 mm) |
| MOUNTING POSITION | Motor feeder at bottom Vertical |
| OVERLOAD RELEASE CURRENT SETTING - MIN | 1.5 A |
| OVERLOAD RELEASE CURRENT SETTING - MAX | 9 A |
| PRODUCT CATEGORY | Electronic motor starter |
| RESIDUAL RIPPLE | ≤ 5 % (input voltage) |
| TERMINAL CAPACITY | 0.14 - 2.5 mm², Control circuit cables 0.2 - 2.5 mm², Main cables, Push-in terminals 0.2 - 2.5 mm², Main cables |
| TERMINAL CAPACITY (AWG) | 24 - 14, Main cables 26 - 14, Control circuit cables 24 - 14, Main cables, Push- in terminals |
| ТҮРЕ | Reversing starter (complete device) |
| VOLTAGE TYPE | DC |

| Climatic environmental conditions | |
|--|--------|
| AMBIENT OPERATING TEMPERATURE - MIN | -25 °C |
| AMBIENT OPERATING TEMPERATURE - MAX | 70 °C |
| AMBIENT STORAGE TEMPERATURE - MIN | 40 °C |
| AMBIENT STORAGE TEMPERATURE - MAX | 80 °C |

| Electro magnetic compatibility | | |
|---|--|--|
| Class A (EN 61000-6-3, emitted interference, radiated) EN 55011 | | |
| | | |

| Electrical rating | |
|--|--------------------------------------|
| RATED ACTUATING CURRENT (IC) | 5 mA |
| RATED CONDITIONAL SHORT-CIRCUIT CURRENT (IQ), TYPE 2, 380 V, 400 V, 415 V | 0 A |
| RATED CONTROL SUPPLY CURRENT IS | 40 mA |
| RATED CONTROL SUPPLY VOLTAGE | 19.2 - 30 V DC |
| RATED CONTROL VOLTAGE (UC) | 24 V (Actuating circuit ON, L, R) |
| RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MIN | 0 V |
| RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MAX | 0 V |
| RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MIN | 0 V |
| RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MAX | 0 V |
| RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MIN | 24 V |
| RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MAX | 24 V |
| RATED OPERATIONAL CURRENT (IE) | 9 A |
| RATED OPERATIONAL CURRENT (IE) AT AC-15, 220 V, 230 V, 240 V | 3 A |
| RATED OPERATIONAL CURRENT (IE) AT AC-3, 380 V, 400 V, 415 V | 6.5 A |
| RATED OPERATIONAL CURRENT (IE) AT AC-51 | 9 A |
| RATED OPERATIONAL CURRENT (IE) AT AC-53A - MAX | 6.5 A |
| RATED OPERATIONAL CURRENT (IE) AT DC-13, 24 V | 2 A |
| RATED OPERATIONAL POWER AT AC-3, 220/230 | 1.5 kW |

| Contacts | |
|---|---|
| NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS) | 1 |
| NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS) | 1 |
| NUMBER OF CONTACTS (CHANGE-OVER CONTACTS) | 1 |
| | |

| V, 50 HZ | |
|---|--|
| RATED OPERATIONAL POWER AT AC-3, 380/400 V, 50 HZ | 3 kW |
| RATED OPERATIONAL POWER AT AC-53A, 380/400 V, 50 HZ | 3 kW |
| RATED OPERATIONAL VOLTAGE | 42 - 550 V 500 V AC |
| SWITCHING LEVEL | 19.2 - 30 V DC, Switching level "High", Actuating circuit (ON, L, R) -3 - 9.6 V DC, Switching level "Low", Actuating circuit (ON, L, R) |

| Design verification | |
|--|--|
| EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID | 14.6 W |
| HEAT DISSIPATION CAPACITY PDISS | 0 W |
| HEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID | 0 W |
| RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN) | 9 A |
| STATIC HEAT DISSIPATION, NON- CURRENT-DEPENDENT PVS | 1 W |
| HEAT DISSIPATION DETAILS | If necessary, Allow for derating |
| 10.2.2 CORROSION RESISTANCE | Meets the product standard's requirements. |
| 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES | Meets the product standard's requirements. |
| 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT | Meets the product standard's requirements. |
| 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS | Meets the product standard's requirements. |
| 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION | Meets the product standard's requirements. |
| 10.2.5 LIFTING | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 MECHANICAL IMPACT | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 INSCRIPTIONS | Meets the product standard's requirements. |
| 10.3 DEGREE OF PROTECTION OF ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 CLEARANCES AND CREEPAGE DISTANCES | Meets the product standard's requirements. |
| | Does not apply, since the |

| Resources | |
|------------------------------|---|
| APPLICATION NOTES | eaton-motor-starter-ems2- setting-motor-protection- twincat3-ap034001-en- us.pdf |
| BROCHURES | eaton-ems2-electronic- motorstarter-brochure- br034001en-en-us.pdf |
| CHARACTERISTIC CURVE | eaton-contactors-ems2- reversing-starter- characteristic-curve- 002.eps |
| | eaton-contactors-ems2- reversing-starter- characteristic-curve.eps |
| | eaton-contactors-ems2- reversing-starter- characteristic-curve- 004.eps |
| DECLARATIONS OF | DA-DC-00004192.pdf |
| CONFORMITY | DA-DC-00003980.pdf |
| DRAWINGS | eaton-contactors-ems2- reversing-starter- dimensions-003.eps eaton-contactors-ems2- reversing-starter-3d- |
| | drawing-003.eps DA-CE-ETN.EMS2-RO-T-9- |
| ECAD MODEL | 24VDC |
| INSTALLATION INSTRUCTIONS | <u>IL034064ZU</u> |
| INSTALLATION VIDEOS | Eaton's electronic motor starter EMS2 |
| MANUALS AND USER GUIDES | eaton-electronic-motor- starter-ems2-manual- mn034003en-us.pdf |
| MCAD MODEL | DA-CD- ems2 dos ros t 24vdc DA-CS- ems2 dos ros t 24vdc |
| SALES NOTES | eaton-ems2-electronic- motorstarter-flyer- fl034007en-en-us.pdf |
| | |

| AGAINST ELECTRIC SHOCK | entire switchgear needs to be evaluated. |
|--|--|
| 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS | ls the panel builder's responsibility. |
| 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS | ls the panel builder's responsibility. |
| 10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH | ls the panel builder's responsibility. |
| 10.9.3 IMPULSE WITHSTAND VOLTAGE | ls the panel builder's responsibility. |
| 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL | ls the panel builder's responsibility. |
| 10.10 TEMPERATURE RISE | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 SHORT-CIRCUIT RATING | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 ELECTROMAGNETIC COMPATIBILITY | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 MECHANICAL FUNCTION | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

| PROJECT NAME: | |
|-----------------|--|
| PROJECT NUMBER: | |
| PREPARED BY: | |
| DATE: | |



Eaton Corporation plc

Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









