

Specifications



Photo is representative



Eaton 197164

Eaton Moeller® series EMS2 DOL starter, 24 V DC, 1,5 - 6,5 (AC-53a), 9 (AC-51) A, Screw terminals

General specifications

| | |
|---------------------|--|
| PRODUCT NAME | Eaton Moeller® series EMS2 DOL starter |
|---------------------|--|

| | |
|-----------------------|--------|
| CATALOG NUMBER | 197164 |
|-----------------------|--------|

| | |
|-------------------|-------------------|
| MODEL CODE | EMS2-DO-Z-9-24VDC |
|-------------------|-------------------|

| | |
|------------|---------------|
| EAN | 4015080896050 |
|------------|---------------|

| | |
|-----------------------------|----------|
| PRODUCT LENGTH/DEPTH | 114.5 mm |
|-----------------------------|----------|

| | |
|-----------------------|-------|
| PRODUCT HEIGHT | 99 mm |
|-----------------------|-------|

| | |
|----------------------|---------|
| PRODUCT WIDTH | 22.5 mm |
|----------------------|---------|

| | |
|-----------------------|----------|
| PRODUCT WEIGHT | 0.287 kg |
|-----------------------|----------|

| | |
|-----------------------|---|
| CERTIFICATIONS | IEC/EN 60947-4-2 UL508 UL File No.: E29096 UL Category Control No.: NLDX, NLDX7 UL 60947-4-1 CSA-C22.2 No. 60947-4-1-14 CE marking UL listed Certified by UL for use in Canada UL report applies to both US and Canada |
|-----------------------|---|

Features & Functions

| | |
|------------------|---------------------------------|
| FUNCTIONS | Motor protection |
| | DOL starting |
| | Temperature |
| | compensated overload protection |

General

| | |
|---|--|
| CLASS | CLASS 10 A |
| CONNECTION TO SMARTWIRE-DT | No |
| DEGREE OF PROTECTION | IP20 NEMA Other |
| MODEL | Direct starter |
| MOUNTING METHOD | Top-hat rail fixing (according to IEC/EN 60715, 35 mm) Rail mounting possible |
| MOUNTING POSITION | Motor feeder at bottom Vertical |
| OVERLOAD RELEASE CURRENT SETTING - MIN | 1.5 A |
| OVERLOAD RELEASE CURRENT SETTING - MAX | 9 A |
| PRODUCT CATEGORY | Electronic motor starter |
| RESIDUAL RIPPLE | ≤ 5 % (input voltage) |
| TERMINAL CAPACITY | 0.2 - 2.5 mm ² , Main cables, Push-in terminals 0.14 - 2.5 mm ² , Control circuit cables 0.2 - 2.5 mm ² , Main cables |
| TERMINAL CAPACITY (AWG) | 24 - 14, Main cables 26 - 14, Control circuit cables |
| TYPE | DOL starter (complete device) |
| VOLTAGE TYPE | DC |

Climatic environmental conditions

| | |
|--|--------|
| AMBIENT OPERATING TEMPERATURE - MIN | -25 °C |
|--|--------|

| | |
|--|-------|
| AMBIENT OPERATING TEMPERATURE - MAX | 70 °C |
|--|-------|

| | |
|--|-------|
| AMBIENT STORAGE TEMPERATURE - MIN | 40 °C |
|--|-------|

| | |
|--|-------|
| AMBIENT STORAGE TEMPERATURE - MAX | 80 °C |
|--|-------|

Electro magnetic compatibility

| | |
|---------------------------------|--|
| RADIO INTERFERENCE CLASS | EN 55011 Class A (EN 61000-6-3, emitted interference, radiated) |
|---------------------------------|--|

Electrical rating

**RATED ACTUATING
CURRENT (IC)** 5 mA

**RATED CONDITIONAL
SHORT-CIRCUIT CURRENT
(IQ), TYPE 2, 380 V, 400 V,
415 V** 0 A

**RATED CONTROL SUPPLY
CURRENT IS** 40 mA

**RATED CONTROL SUPPLY
VOLTAGE** 19.2 - 30 V DC

**RATED CONTROL
VOLTAGE (UC)** 24 V (Actuating circuit ON,
L, R)

**RATED CONTROL SUPPLY
VOLTAGE (US) AT AC, 50
HZ - MIN** 0 V

**RATED CONTROL SUPPLY
VOLTAGE (US) AT AC, 50
HZ - MAX** 0 V

**RATED CONTROL SUPPLY
VOLTAGE (US) AT AC, 60
HZ - MIN** 0 V

**RATED CONTROL SUPPLY
VOLTAGE (US) AT AC, 60
HZ - MAX** 0 V

**RATED CONTROL SUPPLY
VOLTAGE (US) AT DC -
MIN** 24 V

**RATED CONTROL SUPPLY
VOLTAGE (US) AT DC -
MAX** 24 V

**RATED OPERATIONAL
CURRENT (IE)** 9 A

**RATED OPERATIONAL
CURRENT (IE) AT AC-15,
220 V, 230 V, 240 V** 3 A

**RATED OPERATIONAL
CURRENT (IE) AT AC-3,
380 V, 400 V, 415 V** 6.5 A

**RATED OPERATIONAL
CURRENT (IE) AT AC-51** 9 A

**RATED OPERATIONAL
CURRENT (IE) AT AC-53A -
MAX** 6.5 A

**RATED OPERATIONAL
CURRENT (IE) AT DC-13,
24 V** 2 A

**RATED OPERATIONAL
POWER AT AC-3, 220/230** 1.5 kW

Contacts

**NUMBER OF AUXILIARY
CONTACTS (NORMALLY
CLOSED CONTACTS)** 1

**NUMBER OF AUXILIARY
CONTACTS (NORMALLY
OPEN CONTACTS)** 1

**NUMBER OF CONTACTS
(CHANGE-OVER
CONTACTS)** 1

| | |
|--|--|
| V, 50 HZ | |
| RATED OPERATIONAL POWER AT AC-3, 380/400 V, 50 HZ | 3 kW |
| RATED OPERATIONAL POWER AT AC-53A, 380/400 V, 50 HZ | 3 kW |
| RATED OPERATIONAL VOLTAGE | 500 V AC 42 - 550 V |
| SWITCHING LEVEL | 19.2 - 30 V DC, Switching level "High", Actuating circuit (ON, L, R) -3 - 9.6 V DC, Switching level "Low", Actuating circuit (ON, L, R) |

Design verification

EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID 14.6 W

HEAT DISSIPATION CAPACITY PDISS 0 W

HEAT DISSIPATION PER POLE, CURRENT-DEPENDENT PVID 0 W

RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN) 9 A

STATIC HEAT DISSIPATION, NON-CURRENT-DEPENDENT PVS 1 W

HEAT DISSIPATION DETAILS If necessary, Allow for derating

10.2.2 CORROSION RESISTANCE Meets the product standard's requirements.

10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES Meets the product standard's requirements.

10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT Meets the product standard's requirements.

10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS Meets the product standard's requirements.

10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements.

10.2.5 LIFTING Does not apply, since the entire switchgear needs to be evaluated.

10.2.6 MECHANICAL IMPACT Does not apply, since the entire switchgear needs to be evaluated.

10.2.7 INSCRIPTIONS Meets the product standard's requirements.

10.3 DEGREE OF PROTECTION OF ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated.

10.4 CLEARANCES AND CREEPAGE DISTANCES Meets the product standard's requirements.

10.5 PROTECTION Does not apply, since the

Resources

APPLICATION NOTES [eaton-motor-starter-ems2-setting-motor-protection-twincat3-ap034001-en-us.pdf](#)

BROCHURES [eaton-ems2-electronic-motorstarter-brochure-br034001en-en-us.pdf](#)

[eaton-contactors-ems2-reversing-starter-characteristic-curve-002.eps](#)

CHARACTERISTIC CURVE [eaton-contactors-ems2-reversing-starter-characteristic-curve.eps](#)

[eaton-contactors-ems2-reversing-starter-characteristic-curve-004.eps](#)

DECLARATIONS OF CONFORMITY [DA-DC-00003980.pdf](#)
[DA-DC-00004192.pdf](#)

[eaton-contactors-ems2-reversing-starter-dimensions-002.eps](#)

DRAWINGS [eaton-contactors-ems2-reversing-starter-3d-drawing-002.eps](#)

ECAD MODEL [DA-CE-ETN.EMS2-DO-Z-9-24VDC](#)

INSTALLATION INSTRUCTIONS [IL034064ZU](#)

INSTALLATION VIDEOS [Eaton's electronic motor starter EMS2](#)

MANUALS AND USER GUIDES [eaton-electronic-motor-starter-ems2-manual-mn034003en-us.pdf](#)

MCAD MODEL [DA-CD-ems2_dos_ros_z_24_230v](#)
[DA-CS-ems2_dos_ros_z_24_230v](#)

SALES NOTES [eaton-ems2-electronic-motorstarter-flyer-fl034007en-en-us.pdf](#)

| | |
|---|--|
| AGAINST ELECTRIC SHOCK | entire switchgear needs to be evaluated. |
| 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS | Is the panel builder's responsibility. |
| 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS | Is the panel builder's responsibility. |
| 10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH | Is the panel builder's responsibility. |
| 10.9.3 IMPULSE WITHSTAND VOLTAGE | Is the panel builder's responsibility. |
| 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL | Is the panel builder's responsibility. |
| 10.10 TEMPERATURE RISE | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 SHORT-CIRCUIT RATING | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 ELECTROMAGNETIC COMPATIBILITY | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 MECHANICAL FUNCTION | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

| |
|-----------------|
| PROJECT NAME: |
| PROJECT NUMBER: |
| PREPARED BY: |
| DATE: |



Eaton Corporation plc
Eaton House
30 Pembroke Road
Dublin 4, Ireland
Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.

