Specifications



Photo is representative





Eaton 199068

Eaton Moeller® series Rapid Link - DOL starter, 6.6 A, Sensor input 2, 180/207 V DC, AS-Interface®, S-7.4 for 31 modules, HAN Q5, with manual override switch

General specifications

PRODUCT NAME	Eaton Rapid Link DOL starter	
CATALOG NUMBER	199068	
EAN	4015081971268	
PRODUCT LENGTH/DEPTH	120 mm	
PRODUCT HEIGHT	270 mm	
PRODUCT WIDTH	220 mm	
PRODUCT WEIGHT	1.8 kg	
CERTIFICATIONS	RoHS UL 60947-4-2 CE UL approval IEC/EN 60947-4-2 CCC UL 60947-4-2	
CATALOG NOTES	Assigned motor rating: for normal internally and externally ventilated 4 pole, three-phase asynchronous motors with 1500 rpm at 50 Hz or 1800 min at 60 Hz	
MODEL CODE	RAMO5-D201A31-512RS1	



Features & Functions

c C	Parameterization: drivesConnect Diagnostics and reset on device and via AS-Interface
C (Parameterization: drivesConnect mobile App) Parameterization: Keypad
FITTED WITH:	Thermistor monitoring PTC Electronic motor protection Thermo-click Key switch position DFF/RESET Key switch position HAND Two sensor inputs through M12 sockets (max. 150 mA) for quick stop and nterlocked manual operation Key switch position AUTO Manual override switch Short-circuit release
FUNCTIONS	For actuation of motors with mechanical brake External reset possible Femperature compensated overload protection

General		
CLASS	CLASS 10 A	
DEGREE OF PROTECTION	NEMA 12 IP65	
ELECTROMAGNETIC COMPATIBILITY	Class A	
LIFESPAN, ELECTRICAL	10,000,000 Operations (at AC-3)	
LIFESPAN, MECHANICAL	10,000,000 Operations (at AC-3)	
MODEL	Direct starter	
OVERLOAD RELEASE CURRENT SETTING - MIN	0.3 A	
OVERLOAD RELEASE CURRENT SETTING - MAX	6.6 A	
OVERVOLTAGE CATEGORY	Ш	
PRODUCT CATEGORY	Motor starter	
PROTOCOL	AS-Interface profile cable: S-7.4 for 31 modules ASI	
RATED IMPULSE WITHSTAND VOLTAGE (UIMP)	4000 V	
SYSTEM CONFIGURATION TYPE	Center-point earthed star network (TN-S network) Phase-earthed AC supply systems are not permitted. AC voltage	
ТҮРЕ	DOL starter	
VOLTAGE TYPE	DC	

Ambient conditions, mechanical

MOUNTING POSITION	Vertical	
SHOCK RESISTANCE	15 g, Mechanical, According to IEC/EN 60068-2-27, 11 ms, Half- sinusoidal shock 11 ms, 1000 shocks per shaft	
VIBRATION	Resistance: 57 Hz, Amplitude transition frequency on acceleration Resistance: 10 - 150 Hz, Oscillation frequency Resistance: 6 Hz, Amplitude 0.15 mm Resistance: According to IEC/EN 60068-2-6	

ALTITUDE	Above 1000 m with 1 % performance reduction per 100 m Max. 2000 m Max. 1000 m	
AMBIENT OPERATING TEMPERATURE - MIN	-10 °C	
AMBIENT OPERATING TEMPERATURE - MAX	55 °C	
AMBIENT STORAGE TEMPERATURE - MIN	-40 °C	
AMBIENT STORAGE TEMPERATURE - MAX	70 °C	
CLIMATIC PROOFING	< 95 %, no condensation In accordance with IEC/EN 50178	

Climatic environmental conditions

Main circuit

CURRENT LIMITATION	Adjustable, motor, main circuit 0.3 - 6.6 A, motor, main circuit		circuit 0.3 - 6.6 A, motor, main	
INPUT CURRENT	6.6 A (at 150 % Overload)			
MAINS SWITCH-ON FREQUENCY	Maximum of one time every 60 seconds			
MAINS VOLTAGE TOLERANCE	380 - 480 V (-15 %/+10 %, at 50/60 Hz)			
OFF-DELAY	20 - 35 ms			
ON-DELAY	20 - 35 ms			
OUTPUT FREQUENCY	50/60 Hz			
OVERLOAD CYCLE	AC-53a			
RATED FREQUENCY - MIN	47 Hz			
RATED FREQUENCY - MAX	63 Hz			
RATED OPERATIONAL CURRENT (IE)	6.6 A			
RATED OPERATIONAL CURRENT (IE) AT 150% OVERLOAD	6.6 A			
RATED OPERATIONAL CURRENT (IE) AT AC-3, 380 V, 400 V, 415 V	6.6 A			
RATED OPERATIONAL POWER AT 380/400 V, 50 HZ - MIN	0.09 kW			
RATED OPERATIONAL POWER AT 380/400 V, 50 HZ - MAX	3 kW			
RATED OPERATIONAL POWER AT AC-3, 220/230 V, 50 HZ	0 kW			
RATED OPERATIONAL POWER AT AC-3, 380/400 V, 50 HZ	3 kW			
RATED OPERATIONAL VOLTAGE	400 V AC, 3-phase 480 V AC, 3-phase			
SUPPLY FREQUENCY	50/60 Hz, fLN, Main circuit			
SYSTEM CONFIGURATION TYPE	Center-point earthed star network (TN-S network) Phase-earthed AC supply systems are not permitted. AC voltage			

Motor rating

ASSIGNED MOTOR POWER AT 460/480 V, 60 3 HP HZ, 3-PHASE

Braking function

BRAKING CURRENT	≤ 0.6 A (max. 6 A for 120 ms), Actuator for external motor brake
BRAKING VOLTAGE	180/215 V DC -15 % / +10 %, Actuator for external motor brake

Short-circuit rating

RATED CONDITIONAL SHORT-CIRCUIT CURRENT (IQ)	10 kA
RATED CONDITIONAL SHORT-CIRCUIT CURRENT (IQ), TYPE 2, 380 V, 400 V, 415 V	0 A
SHORT-CIRCUIT PROTECTION (EXTERNAL OUTPUT CIRCUITS)	Type 1 coordination via the power bus' feeder unit, Main circuit

Control circuit		
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MIN	0 V	
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MAX	0 V	
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MIN	0 V	
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MAX	0 V	
RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MIN	0 V	
RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MAX	0 V	
RATED CONTROL VOLTAGE (UC)	24 V DC (-15 %/+20 %, external via AS-Interface® plug) 180/207 V DC (external brake 50/60 Hz)	

0

0

Communication	
CONNECTION	Connections pluggable in power section
INTERFACES	Number of slave addresses: 31 (AS- Interface®) Max. total power consumption from AS- Interface® power supply unit (30 V): 190 mA Specification: S-7.4 (AS- Interface®)

Contacts

NUMBER OF AUXILIARY **CONTACTS (NORMALLY CLOSED CONTACTS)**

NUMBER OF AUXILIARY **CONTACTS (NORMALLY OPEN CONTACTS)**

Cable

CABLE LENGTH

10 m, Radio interference level, maximum motor cable length

Design verification

10.2.3.1 VERIFICATION OF ENCLOSURESMeets the product standard's requirements.10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEATMeets the product standard's requirements.10.2.3.3 RESIST. OF ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTSMeets the product standard's requirements.10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATIONMeets the product standard's requirements.10.2.5 LIFTINGDoes not apply, since the entire switchgear needs to be evaluated.10.2.7 INSCRIPTIONSMeets the product standard's requirements.10.3 DEGREE OF PROTECTION OF ASSEMBLIESDoes not apply, since the entire switchgear needs to be evaluated.10.4 CLEARANCES AND CREEPAGE DISTANCESDoes not apply, since the entire switchgear needs to be evaluated.10.5 PROTECTION OF AGAINST ELECTRIC SHOCKDoes not apply, since the entire switchgear needs to be evaluated.10.5 INCORPORATION OF SWITCHING DEVICES AND COMPONENTSDoes not apply, since the entire switchgear needs to be evaluated.10.7 INTERNAL CONNECTIONS FOR SHOCKIs the panel builder's responsibility.10.8 CONNECTIONS FOR REQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.3 IMPULSE FINCLOSURES MADE OFIs the panel builder's responsibility.	10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.	
RESISTANCE OF INSULATING MATERIALSMeets the product standard's requirements.10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTSMeets the product 	THERMAL STABILITY OF		
INSUL. MAT. TO BNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTSMeets the product standard's requirements.10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATIONMeets the product standard's requirements.10.2.5 LIFTINGDoes not apply, since the entire switchgear needs to be evaluated.10.2.6 MECHANICAL IMPACTDoes not apply, since the entire switchgear needs to be evaluated.10.2.7 INSCRIPTIONSMeets the product standard's requirements.10.3 DEGREE OF PROTECTION OF ASSEMBLIESDoes not apply, since the entire switchgear needs to be evaluated.10.4 CLEARANCES AND CREEPAGE DISTANCESMeets the product standard's requirements.10.5 PROTECTION AGAINST ELECTRIC SHOCKDoes not apply, since the entire switchgear needs to be evaluated.10.5 INCORPORATION OF SHOCKDoes not apply, since the entire switchgear needs to be evaluated.10.6 INCORPORATION OF SHOCKDoes not apply, since the entire switchgear needs to be evaluated.10.7 INTERNAL ELECTRIC AGAINST ELECTRIC SHOCKIs the panel builder's responsibility.10.8 CONNECTIONS FOR FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OFIs the panel builder's responsibility.	RESISTANCE OF INSULATING MATERIALS	•	
ULTRA-VIOLET (UV) RADIATIONMeets the product standard's requirements.10.2.5 LIFTINGDoes not apply, since the entire switchgear needs to 	INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT.	-	
10.2.5 LIFTINGentire switchgear needs to be evaluated.10.2.6 MECHANICAL IMPACTDoes not apply, since the entire switchgear needs to be evaluated.10.2.7 INSCRIPTIONSMeets the product standard's requirements.10.3 DEGREE OF PROTECTION OF 	ULTRA-VIOLET (UV)		
10.2.5 MECHANICAL IMPACTentire switchgear needs to be evaluated.10.2.7 INSCRIPTIONSMeets the product standard's requirements.10.3 DEGREE OF PROTECTION OF ASSEMBLIESDoes not apply, since the entire switchgear needs to be evaluated.10.4 CLEARANCES AND CREEPAGE DISTANCESMeets the product standard's requirements.10.5 PROTECTION AGAINST ELECTRIC SHOCKDoes not apply, since the entire switchgear needs to be evaluated.10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTSDoes not apply, since the entire switchgear needs to be evaluated.10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONSIs the panel builder's responsibility.10.8 CONNECTIONS FOR EXTERNAL CONDUCTORSIs the panel builder's responsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OFIs the panel builder's responsibility.	10.2.5 LIFTING	entire switchgear needs to	
10.2.7 INSCRIPTIONSstandard's requirements.10.3 DEGREE OF PROTECTION OF ASSEMBLIESDoes not apply, since the entire switchgear needs to be evaluated.10.4 CLEARANCES AND CREEPAGE DISTANCESMeets the product standard's requirements.10.5 PROTECTION AGAINST ELECTRIC SHOCKDoes not apply, since the entire switchgear needs to be evaluated.10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTSDoes not apply, since the entire switchgear needs to be evaluated.10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS FOR EXTERNAL CONDUCTORSIs the panel builder's responsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OFIs the panel builder's responsibility.		entire switchgear needs to	
PROTECTION OF ASSEMBLIESentire switchgear needs to be evaluated.10.4 CLEARANCES AND CREEPAGE DISTANCESMeets the product standard's requirements.10.5 PROTECTION AGAINST ELECTRIC SHOCKDoes not apply, since the entire switchgear needs to be evaluated.10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTSDoes not apply, since the entire switchgear needs to be evaluated.10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONSIs the panel builder's responsibility.10.8 CONNECTIONS FOR EXTERNAL CONDUCTORSIs the panel builder's responsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OFIs the panel builder's	10.2.7 INSCRIPTIONS	-	
CREEPAGE DISTANCESstandard's requirements.10.5 PROTECTION AGAINST ELECTRICDoes not apply, since the entire switchgear needs to be evaluated.10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTSDoes not apply, since the entire switchgear needs to be evaluated.10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONSIs the panel builder's responsibility.10.8 CONNECTIONS FOR EXTERNAL CONDUCTORSIs the panel builder's responsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OFIs the panel builder's	PROTECTION OF	entire switchgear needs to	
AGAINST ELECTRIC SHOCKentire switchgear needs to be evaluated.10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTSDoes not apply, since the entire switchgear needs to be evaluated.10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONSIs the panel builder's responsibility.10.8 CONNECTIONS FOR EXTERNAL CONDUCTORSIs the panel builder's responsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OFIs the panel builder's		-	
SWITCHING DEVICES AND COMPONENTSentire switchgear needs to be evaluated.10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONSIs the panel builder's responsibility.10.8 CONNECTIONS FOR EXTERNAL CONDUCTORSIs the panel builder's responsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OFIs the panel builder's	AGAINST ELECTRIC	entire switchgear needs to	
ELECTRICAL CIRCUITS AND CONNECTIONSIs the panel builder's responsibility.10.8 CONNECTIONS FOR EXTERNAL CONDUCTORSIs the panel builder's responsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OFIs the panel builder's	SWITCHING DEVICES AND	entire switchgear needs to	
EXTERNAL CONDUCTORSresponsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OFIs the panel builder's	ELECTRICAL CIRCUITS		
FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OFIs the panel builder's		-	
WITHSTAND VOLTAGEresponsibility.10.9.4 TESTING OFIs the panel builder's	FREQUENCY ELECTRIC		
		-	

Resources

APPLICATION NOTES

BROCHURES

eaton-rapid-link-5configuration-rockwell-plcap040195-en-us.pdf

eaton-rapid-linkgeneration-change-ramo4to-ramo5-ap040198-enus.pdf

Electromagnetic compatibility (EMC)

eaton-rapid-link-5-rasp5profinet-communicationap040215-en-us.pdf

eaton-powerxl-dx-comstick-3-ap040190-enus.pdf

eaton-powerxl-da1-dc1db1-de1-rapidlink5firmware-updateap040214-en-us.pdf

eaton-rapid-linkgeneration-change-rasp4to-rasp5-ap040197-enus.pdf

eaton-rapid-linkgeneration-change-ra-moto-ramo4-ap040081-enus.pdf

eaton-rapid-linkgeneration-change-ra-spto-rasp5-ap040196-enus.pdf

eaton-rapid-link-firmwareupdate-rasp4-ap040219en-us.pdf

eaton-rapid-linkgeneration-change-ra-spto-rasp4-ap040080-enus.pdf

eaton-powerxl-da1-dc1de1-internal-motorprotection-ap040016-enus.pdf

eaton-powerxl-variablefrequency-drives-materialhandling-brochurebr040017en-en-us.pdf

INSULATING MATERIAL			eaton-rapid-link-5-
provide heat dissipat	responsible for the		brochure-br040014en-en- us.pdf
	calculation. Eaton will provide heat dissipation data for the devices.	CATALOGUES	Product Range Catalog Drives Engineering
10.11 SHORT-CIRCUIT	ls the panel builder's responsibility. The		<u>eaton-rapid-link-5-drive-</u> <u>system-catalog-</u> <u>ca040002en-en-us</u>
RATING specifications for the switchgear must be observed.	DECLARATIONS OF	<u>DA-DC-00004523.pdf</u> <u>DA-DC-00004184.pdf</u>	
10.12 ELECTROMAGNETIC	Is the panel builder's responsibility. The specifications for the switchgear must be observed.	CONFORMITY	DA-DC-00004525.pdf DA-DC-00003964.pdf
			<u>eaton-bus-adapter-</u> <u>rapidlink-reversing-starter-</u>
10.13 MECHANICAL requirement: FUNCTION the informati	The device meets the requirements, provided	DRAWINGS	dimensions-002.eps
	the information in the instruction leaflet (IL) is observed.		<u>eaton-bus-adapter-</u> rapidlink-reversing-starter- dimensions-003.eps
		ECAD MODEL	ETN.RAMO5-D201A31- 512RS1.edz

INSTALLATION

INSTRUCTIONS

MCAD MODEL

INSTALLATION VIDEOS

SOFTWARE, FIRMWARE,

AND APPLICATIONS

PROJECT NAME.	
PROJECT NUMBER:	
PREPARED BY:	

DATE:

PROJECT NAME:



Eaton Corporation plc Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.



IL034084ZU

Rapid Link 5 ramo5_v4.stp

ramo5_v4.dwg

<u>us.pdf</u>

eaton-rapidlink5-firmware-

release-note-mz034006en-