

Specifications






Photo is representative



Eaton 199216

Eaton Moeller® series DILA Contactor relay,
24 V 50/60 Hz, 2 N/O, 2 NC, Push in
terminals, AC operation

General specifications

| | |
|---------------------|---|
| PRODUCT NAME | Eaton Moeller® series DILA Control relay |
|---------------------|---|

| | |
|-----------------------|--------|
| CATALOG NUMBER | 199216 |
|-----------------------|--------|

| | |
|-------------------|------------------------|
| MODEL CODE | DILA-22(24V50/60HZ)-PI |
|-------------------|------------------------|

| | |
|------------|---------------|
| EAN | 4015081973002 |
|------------|---------------|

| | |
|---------------------------------|-------|
| PRODUCT LENGTH/DEPTH | 75 mm |
|---------------------------------|-------|

| | |
|-----------------------|-------|
| PRODUCT HEIGHT | 68 mm |
|-----------------------|-------|

| | |
|----------------------|-------|
| PRODUCT WIDTH | 45 mm |
|----------------------|-------|

| | |
|-----------------------|----------|
| PRODUCT WEIGHT | 0.227 kg |
|-----------------------|----------|

CERTIFICATIONS

IEC/EN 60947
EN 60947-5-1
VDE 0660
CSA File No.: 012528
CSA Class No.: 3211-03
UL File No.: E29184
UL 508
CSA-C22.2 No. 14-05
CE marking
UL Category Control No.:
NKCR
UL
CSA



Powering Business Worldwide

Features & Functions

FEATURES

Positive operating contacts to EN 60947-5-1 appendix L, including auxiliary contact module

FITTED WITH:

Positive operation contacts

General

APPLICATION

Contactors relays

DEGREE OF PROTECTION

IP20

SHOCK RESISTANCE

7 g, N/O auxiliary contact, Basic unit with auxiliary contact module, Mechanical, according to IEC/EN 60068-2-27, Half-sinusoidal shock 10 ms
5 g, N/C auxiliary contact, Basic unit with auxiliary contact module, Mechanical, according to IEC/EN 60068-2-27, Half-sinusoidal shock 10 ms

LIFESPAN, MECHANICAL

20,000,000 Operations (AC operated)

MOUNTING METHOD

DIN-rail/screw

CONNECTION

Push in terminals

OPERATING FREQUENCY

9000 Operations/h

OVERVOLTAGE CATEGORY

III

POLLUTION DEGREE

3

PRODUCT CATEGORY

DILA relays

PROTECTION

Finger and back-of-hand proof, Protection against direct contact when actuated from front (EN 50274)

RATED IMPULSE WITHSTAND VOLTAGE (UIMP)

6000 V AC

VOLTAGE TYPE

AC

Climatic environmental conditions

| | |
|--|--------|
| AMBIENT OPERATING TEMPERATURE - MIN | -25 °C |
|--|--------|

| | |
|--|-------|
| AMBIENT OPERATING TEMPERATURE - MAX | 60 °C |
|--|-------|

| | |
|---|--------|
| AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN | -25 °C |
|---|--------|

| | |
|---|-------|
| AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX | 40 °C |
|---|-------|

| | |
|--|--------|
| AMBIENT STORAGE TEMPERATURE - MIN | -40 °C |
|--|--------|

| | |
|--|-------|
| AMBIENT STORAGE TEMPERATURE - MAX | 80 °C |
|--|-------|

| | |
|--------------------------|--|
| CLIMATIC PROOFING | Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 |
|--------------------------|--|

Terminal capacities

| | |
|--|--|
| TERMINAL CAPACITY (FLEXIBLE WITH FERRULE) | 2 x (0.5 - 1.5) mm ² 1 x (0.5 - 2.5) mm ² |
|--|--|

| | |
|----------------------------------|--|
| TERMINAL CAPACITY (SOLID) | 1 x (0.5 - 2.5) mm ² 2 x (0.5 - 2.5) mm ² |
|----------------------------------|--|

| | |
|---|---------|
| TERMINAL CAPACITY (SOLID/STRANDED AWG) | 20 - 14 |
|---|---------|

| | |
|--------------------------------------|-------|
| STRIPPING LENGTH (MAIN CABLE) | 10 mm |
|--------------------------------------|-------|

| | |
|-------------------------|------------------------------|
| SCREWDRIVER SIZE | 3.0 x 0.5 mm, Terminal screw |
|-------------------------|------------------------------|

Electrical rating

| | |
|---------------------------------------|--|
| RATED OPERATIONAL CURRENT (IE) | 3 A at 110 V, DC L/R ≤ 15 ms (with 1 contact in series) |
| | 2 A at 110 V, DC L/R ≤ 50 ms (with 3 contacts in series) |
| | 10 A at 24 V, DC L/R ≤ 15 ms (with 1 contact in series) |
| | 4 A at 24 V, DC L/R ≤ 50 ms (with 3 contacts in series) |
| | 4 A at 60 V, DC L/R ≤ 50 ms (with 3 contacts in series) |
| | 1 A at 220 V, DC L/R ≤ 50 ms (with 3 contacts in series) |
| | 6 A at 110 V, DC L/R ≤ 15 ms (with 3 contacts in series) |
| | 5 A at 220 V, DC L/R ≤ 15 ms (with 3 contacts in series) |
| | 6 A at 60 V, DC L/R ≤ 15 ms (with 1 contact in series) |
| | 1 A at 220 V, DC L/R ≤ 15 ms (with 1 contact in series) |
| | 10 A at 60 V, DC L/R ≤ 15 ms (with 2 contacts in series) |
| | 16 A |

RATED OPERATIONAL CURRENT (IE) AT AC-15, 220 V, 230 V, 240 V

4 A

RATED OPERATIONAL CURRENT (IE) AT AC-15, 380 V, 400 V, 415 V

4 A

RATED OPERATIONAL CURRENT (IE) AT AC-15, 500 V

1.5 A

RATED INSULATION VOLTAGE (UI)

690 V

RATED OPERATIONAL VOLTAGE (UE) AT AC - MAX

690 V

SHORT-CIRCUIT PROTECTION RATING WITHOUT WELDING

10 A gG/gL, 500 V, Max. Fuse, Contacts

SAFE ISOLATION

400 V AC, Between coil and auxiliary contacts, According to EN 61140
400 V AC, Between

Magnet system

DUTY FACTOR

100 %

PICK-UP VOLTAGE

0.85 - 1.1 V AC x Uc
0.8 - 1.1 V AC x Uc (voltage tolerance - dual frequency coil 50/60 Hz)

POWER CONSUMPTION, PICK-UP, 60 HZ

25 VA, AC, Dual-frequency coil at 60 Hz
27 VA, AC, Dual-frequency coil at 60 Hz

POWER CONSUMPTION, SEALING, 50 HZ

3.3 VA, Dual-frequency coil in a cold state and 1.0 x Us

4.2 VA, Dual-frequency coil in a cold state and 1.0 x Us

1.4 W, Dual-frequency coil in a cold state and 1.0 x Us

3.3 VA, Dual-frequency coil in a cold state and 1.0 x Us

POWER CONSUMPTION, SEALING, 60 HZ

4.2 VA, Dual-frequency coil in a cold state and 1.0 x Us

1.4 W, Dual-frequency coil in a cold state and 1.0 x Us

RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MIN

24 V

RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MAX

24 V

RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MIN

24 V

RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MAX

24 V

RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MIN

0 V

RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MAX

0 V

SWITCHING TIME (AC OPERATED, MAKE CONTACTS, CLOSING DELAY) - MIN

15 ms

SWITCHING TIME (AC OPERATED, MAKE

21 ms

| | |
|---|--|
| | auxiliary contacts, According to EN 61140 |
| SWITCHING CAPACITY (AUXILIARY CONTACTS, GENERAL USE) | 15 A, 600 V AC, (UL/CSA) 1 A, 250 V DC, (UL/CSA) |
| SWITCHING CAPACITY (AUXILIARY CONTACTS, PILOT DUTY) | A600, AC operated (UL/CSA) P300, DC operated (UL/CSA) |

| Communication | |
|---------------------------------------|----|
| CONNECTION TO SMARTWIRE-DT | No |

| | |
|---|-------|
| CONTACTS, CLOSING DELAY) - MAX | |
| SWITCHING TIME (AC OPERATED, MAKE CONTACTS, OPENING DELAY) - MIN | 9 ms |
| SWITCHING TIME (AC OPERATED, MAKE CONTACTS, OPENING DELAY) - MAX | 18 ms |

| Contacts | |
|--|---|
| CODE NUMBER | 22E |
| CONTROL CIRCUIT RELIABILITY | $\lambda < 5 \times 10^{-7}$ (1 failure at 2,000,000 operations for $U_e = 24$ V DC, $U_{min} = 17$ V, $I_{min} = 5.4$ mA) $\lambda < 5 \times 1/10^7$ (1 failure at 2,000,000 operations for $U_e = 24$ V DC, $U_{min} = 17$ V, $I_{min} = 5.4$ mA) |
| NUMBER OF AUXILIARY CONTACTS (CHANGE- OVER CONTACTS) | 0 |
| NUMBER OF CONTACTS (NORMALLY CLOSED CONTACTS) | 2 |
| NUMBER OF CONTACTS (NORMALLY OPEN CONTACTS) | 2 |
| NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS) | 2 |
| NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS) | 2 |

Design verification

| | |
|---|--|
| EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID | 0 W |
| HEAT DISSIPATION CAPACITY PDISS | 0 W |
| 10.2.2 CORROSION RESISTANCE | Meets the product standard's requirements. |
| 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES | Meets the product standard's requirements. |
| 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT | Meets the product standard's requirements. |
| 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS | Meets the product standard's requirements. |
| 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION | Meets the product standard's requirements. |
| 10.2.5 LIFTING | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 MECHANICAL IMPACT | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 INSCRIPTIONS | Meets the product standard's requirements. |
| 10.3 DEGREE OF PROTECTION OF ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 CLEARANCES AND CREEPAGE DISTANCES | Meets the product standard's requirements. |
| 10.5 PROTECTION AGAINST ELECTRIC SHOCK | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS | Is the panel builder's responsibility. |
| 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS | Is the panel builder's responsibility. |
| 10.9.2 POWER-FREQUENCY ELECTRIC | Is the panel builder's responsibility. |

Resources

| | |
|-----------------------------------|---|
| CATALOGUES | eaton-product-overview-for-machinery-catalogue-ca08103003zen-en-us.pdf Product Range Catalog Switching and protecting motors |
| DECLARATIONS OF CONFORMITY | DA-DC-00004789.pdf DA-DC-00004811.pdf |
| DRAWINGS | eaton-contactors-dimensions-007.eps |
| ECAD MODEL | ETN.199216.edz |
| INSTALLATION VIDEOS | WIN-WIN with push-in technology |
| MCAD MODEL | dil_m7_15_pi.dwg dil_m7_15_pi.stp |
| WIRING DIAGRAMS | 2100SWI-108 |

| | |
|---|--|
| STRENGTH | |
| 10.9.3 IMPULSE WITHSTAND VOLTAGE | Is the panel builder's responsibility. |
| 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL | Is the panel builder's responsibility. |
| 10.10 TEMPERATURE RISE | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 SHORT-CIRCUIT RATING | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 ELECTROMAGNETIC COMPATIBILITY | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 MECHANICAL FUNCTION | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

| |
|------------------------|
| PROJECT NAME: |
| PROJECT NUMBER: |
| PREPARED BY: |
| DATE: |



Eaton Corporation plc
 Eaton House
 30 Pembroke Road
 Dublin 4, Ireland
 Eaton.com

Follow us on social media to get the latest product and support information.

