Specifications



Photo is representative





Eaton 216882

Eaton Moeller® series M22 Key-operated actuator, momentary, 2 positions, Key withdrawable: 0, Bezel: black

| General specification | S |
|-------------------------|--|
| | Eaton Moeller® series |
| PRODUCT NAME | M22 Key-operated |
| | actuator |
| CATALOG NUMBER | 216882 |
| MODEL CODE | M22S-WS |
| EAN | 4015082168827 |
| PRODUCT LENGTH/DEPTH | 70 mm |
| PRODUCT HEIGHT | 30 mm |
| PRODUCT WIDTH | 30 mm |
| PRODUCT WEIGHT | 0.034 kg |
| COMPLIANCES | CE Marked |
| CERTIFICATIONS | CSA Std. C22.2 No. 14-05 CSA Std. C22.2 No. 94-91 EN 60947-5 IEC 60947-5 UL 508 VDE CSA Class No.: 3211-03 CSA CSA-C22.2 No. 94-91 CE CSA File No.: 012528 CSA-C22.2 No. 14-05 UL File No.: E29184 IEC/EN 60947 IEC/EN 60947-5 UL VDE 0660 UL Category Control No.: NKCR DNV GL LR |
| GLOBAL CATALOG | 216882 |
| | |



| Product specifications | |
|--|--|
| ТҮРЕ | Key-operated button |
| ACCESSORIES | 1 key included with supplied equipment. |
| ACTUATOR COLOR | Black |
| ACTUATOR FUNCTION | Spring-return Key withdrawable in position 0 Momentary |
| 10.10 TEMPERATURE RISE | Not applicable. |
| 10.11 SHORT-CIRCUIT RATING | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 ELECTROMAGNETIC COMPATIBILITY | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 MECHANICAL FUNCTION | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |
| 10.2.2 CORROSION RESISTANCE | Meets the product standard's requirements. |
| 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES | Meets the product standard's requirements. |
| 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT | Meets the product standard's requirements. |
| 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS | Meets the product standard's requirements. |
| 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION | Please enquire |
| 10.2.5 LIFTING | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 MECHANICAL IMPACT | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 INSCRIPTIONS | Meets the product standard's requirements. |

| Resources | |
|------------------------------|--|
| CATALOGS | eaton-rmq-titan-brochure- br047004en-en-us.pdf |
| | eaton-pushbuttons-signal- towers-sensors- assortment-overview- catalog-ca047003en-en- us.pdf |
| | Flip catalog - Product Range Catalog - Command and indication |
| DECLARATIONS OF CONFORMITY | eaton-pushbutton- declaration-of-conformity- eu250858en.pdf |
| | eaton-key-operated- actuator-declaration-of- conformity- eu250865en.pdf |
| | eaton-operating-key- operated-actuator- |
| | dimensions-005.eps |
| DRAWINGS | eaton-general-m22- symbol.eps |
| | eaton-general-m22- standards.eps |
| | eaton-general-approval- m22-symbol.eps |
| ECAD MODEL | ETN.216882.edz |
| FLYERS | eaton-rmq-titan-selection- aid-brochure-fl047002-en- us.pdf |
| INSTALLATION INSTRUCTIONS | <u>IL04716002Z</u> |
| INSTALLATION VIDEOS | RMQ Flat Design |
| MCAD MODEL | DA-CD-schluesseltaste_ms |
| | DA-CS-schluesseltaste ms |
| MULTIMEDIA | easyE4 SmartWire-DT module with Remote Touch Display and RMQ multi color indicator |
| | MCI Multicolor Light Indicator M22 with SmartWire-DT |
| | MCI MultiColor Light Indicator RMQ compact solution |

| 10.3 DEGREE OF PROTECTION OF ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
|--|--|
| 10.4 CLEARANCES AND CREEPAGE DISTANCES | Meets the product standard's requirements. |
| 10.5 PROTECTION AGAINST ELECTRIC SHOCK | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS | Is the panel builder's responsibility. |
| 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS | ls the panel builder's responsibility. |
| 10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH | ls the panel builder's responsibility. |
| 10.9.3 IMPULSE WITHSTAND VOLTAGE | ls the panel builder's responsibility. |
| 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL | ls the panel builder's responsibility. |
| FITTED WITH: | Front ring |
| OPERATING FREQUENCY | 100 Operations/h |
| POLLUTION DEGREE | 3 |
| CLIMATIC PROOFING | Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to |
| | IEC 60068-2-78 |
| CONNECTION TO SMARTWIRE-DT | • |
| | IEC 60068-2-78 With SWD-RMQ connections |
| SMARTWIRE-DT | With SWD-RMQ connections Yes |
| SMARTWIRE-DT ACTUATOR TYPE AMBIENT OPERATING | IEC 60068-2-78 With SWD-RMQ connections Yes Key |
| SMARTWIRE-DT ACTUATOR TYPE AMBIENT OPERATING TEMPERATURE - MAX AMBIENT OPERATING | IEC 60068-2-78 With SWD-RMQ connections Yes Key 70 °C |
| SMARTWIRE-DT ACTUATOR TYPE AMBIENT OPERATING TEMPERATURE - MAX AMBIENT OPERATING TEMPERATURE - MIN EQUIPMENT HEAT DISSIPATION, CURRENT- | IEC 60068-2-78 With SWD-RMQ connections Yes Key 70 °C -25 °C |
| SMARTWIRE-DT ACTUATOR TYPE AMBIENT OPERATING TEMPERATURE - MAX AMBIENT OPERATING TEMPERATURE - MIN EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID FORCE FOR POSITIVE | With SWD-RMQ connections Yes Key 70 °C -25 °C |
| SMARTWIRE-DT ACTUATOR TYPE AMBIENT OPERATING TEMPERATURE - MAX AMBIENT OPERATING TEMPERATURE - MIN EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID FORCE FOR POSITIVE OPENING - MIN HEAT DISSIPATION | With SWD-RMQ connections Yes Key 70 °C -25 °C 0 W |

| | RMQ small E-Stop |
|-------------|-----------------------------------|
| | emergency-stop button |
| | eaton-rmq-mci-multi- |
| | color-light-indicator-flyer- |
| | fl047005en-en-us.pdf |
| | actor was flat and acuse |
| | <u>eaton-rmq-flat-enclosure-</u> |
| | flyer-fl047003en-en-us.pdf |
| SALES NOTES | oaton rma small o stop |
| | <u>eaton-rmq-small-e-stop-</u> |
| | <u>flyer-fl047006en-en-us.pdf</u> |
| | eaton-control circuit- |
| | |
| | <u>devices rmq-titan-</u> |
| | fl144090en-en-us.pdf |

| DEPENDENT PVID | |
|--|---|
| OPENING DIAMETER | 22.5 mm |
| OPENING HEIGHT | 0 mm |
| OPERATING TORQUE | 0.5 Nm |
| RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN) | 0 A |
| STATIC HEAT DISSIPATION, NON- CURRENT-DEPENDENT PVS | 0 W |
| SWITCHING ANGLE | 40 ° |
| WIDTH OPENING | 0 mm |
| BEZEL COLOR | Black |
| SHOCK RESISTANCE | Mechanical, According to IEC/EN 60068-2-27 30 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms |
| COLOR | Black |
| | |
| BEZEL MATERIAL | Plastic |
| DESIGN | Plastic Key operated Classical |
| | Key operated |
| DESIGN | Key operated Classical |
| DESIGN MOUNTING POSITION OVERVOLTAGE | Key operated Classical As required |
| DESIGN MOUNTING POSITION OVERVOLTAGE CATEGORY | Key operated Classical As required |
| DESIGN MOUNTING POSITION OVERVOLTAGE CATEGORY DEGREE OF PROTECTION DEGREE OF PROTECTION | Key operated Classical As required III NEMA 4X, 13 |
| DESIGN MOUNTING POSITION OVERVOLTAGE CATEGORY DEGREE OF PROTECTION DEGREE OF PROTECTION (FRONT SIDE) | Key operated Classical As required III NEMA 4X, 13 IP66 Stay-put/spring-return function, can be changed with coding parts M22-XC- |
| DESIGN MOUNTING POSITION OVERVOLTAGE CATEGORY DEGREE OF PROTECTION DEGREE OF PROTECTION (FRONT SIDE) FUNCTIONS | Key operated Classical As required III NEMA 4X, 13 IP66 Stay-put/spring-return function, can be changed with coding parts M22-XC-Y |
| DESIGN MOUNTING POSITION OVERVOLTAGE CATEGORY DEGREE OF PROTECTION (FRONT SIDE) FUNCTIONS INDICATOR COLOR | Key operated Classical As required III NEMA 4X, 13 IP66 Stay-put/spring-return function, can be changed with coding parts M22-XC- Y Other |
| DESIGN MOUNTING POSITION OVERVOLTAGE CATEGORY DEGREE OF PROTECTION (FRONT SIDE) FUNCTIONS INDICATOR COLOR LENS TYPE | Key operated Classical As required III NEMA 4X, 13 IP66 Stay-put/spring-return function, can be changed with coding parts M22-XC- Y Other Round |
| DESIGN MOUNTING POSITION OVERVOLTAGE CATEGORY DEGREE OF PROTECTION (FRONT SIDE) FUNCTIONS INDICATOR COLOR LENS TYPE LIFESPAN, MECHANICAL NUMBER OF SWITCH | Key operated Classical As required III NEMA 4X, 13 IP66 Stay-put/spring-return function, can be changed with coding parts M22-XC- Y Other Round 100,000 Operations |

| PROJECT NAME: | |
|-----------------|--|
| PROJECT NUMBER: | |
| PREPARED BY: | |
| DATE: | |



Eaton Corporation plc

Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









