

# Specifications



Photo is representative

## Eaton 216963

Eaton Moeller® series M22 Illuminated pushbutton actuator, RMQ-Titan, Flush, maintained, White, inscribed 1, Bezel: titanium

### General specifications

<b>PRODUCT NAME</b>	Eaton Moeller® series M22 Illuminated pushbutton actuator
<b>CATALOG NUMBER</b>	216963
<b>MODEL CODE</b>	M22-DRL-W-X1
<b>EAN</b>	4015082169633
<b>PRODUCT LENGTH/DEPTH</b>	30 mm
<b>PRODUCT HEIGHT</b>	30 mm
<b>PRODUCT WIDTH</b>	30 mm
<b>PRODUCT WEIGHT</b>	0.012 kg
<b>CERTIFICATIONS</b>	UL 508 CSA-C22.2 No. 14-05 UL File No.: E29184 UL CE CSA File No.: 012528 IEC/EN 60947 IEC/EN 60947-5 UL Category Control No.: NKCR CSA Class No.: 3211-03 CSA CSA-C22.2 No. 94-91 VDE 0660 DNV GL LR
<b>GLOBAL CATALOG</b>	216963

## Product specifications

<b>TYPE</b>	Illuminated pushbutton actuator
<b>ACTUATOR COLOR</b>	White
<b>FEATURES</b>	Labelled
<b>ACTUATOR FUNCTION</b>	Switching function latching Maintained
<b>10.10 TEMPERATURE RISE</b>	Not applicable.
<b>10.11 SHORT-CIRCUIT RATING</b>	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
<b>10.12 ELECTROMAGNETIC COMPATIBILITY</b>	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
<b>10.13 MECHANICAL FUNCTION</b>	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
<b>10.2.2 CORROSION RESISTANCE</b>	Meets the product standard's requirements.
<b>10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES</b>	Meets the product standard's requirements.
<b>10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT</b>	Meets the product standard's requirements.
<b>10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS</b>	Meets the product standard's requirements.
<b>10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION</b>	Please enquire
<b>10.2.5 LIFTING</b>	Does not apply, since the entire switchgear needs to be evaluated.
<b>10.2.6 MECHANICAL IMPACT</b>	Does not apply, since the entire switchgear needs to be evaluated.
<b>10.2.7 INSCRIPTIONS</b>	Meets the product standard's requirements.

## Resources

### CATALOGS

[eaton-rmq-titan-brochure-br047004en-en-us.pdf](#)

[Flip catalog - Product Range Catalog - Command and indication](#)

[eaton-pushbuttons-signal-towers-sensors-assortment-overview-catalog-ca047003en-en-us.pdf](#)

### DECLARATIONS OF CONFORMITY

[eaton-pushbutton-declaration-of-conformity-eu250857en.pdf](#)

[eaton-pushbutton-declaration-of-conformity-eu250858en.pdf](#)

[eaton-operating-pushbutton-m22-dimensions-004.eps](#)

[eaton-operating-actuation-m22-dimensions-002.eps](#)

[eaton-general-m22-symbol.eps](#)

### DRAWINGS

[eaton-general-m22-standards.eps](#)

[eaton-general-approval-m22-symbol.eps](#)

[116C090](#)

[eaton-operating-samrtwire-m22-3d-drawing.eps](#)

### ECAD MODEL

[ETN.216963.edz](#)

### FLYERS

[eaton-rmq-titan-selection-aid-brochure-fl047002-en-us.pdf](#)

### INSTALLATION INSTRUCTIONS

[IL04716002Z](#)

### INSTALLATION VIDEOS

[RMQ Flat Design](#)

### MCAD MODEL

[DA-CS-drucktaste\\_flach](#)  
[DA-CD-drucktaste\\_flach](#)

<b>10.3 DEGREE OF PROTECTION OF ASSEMBLIES</b>	Does not apply, since the entire switchgear needs to be evaluated.
<b>10.4 CLEARANCES AND CREEPAGE DISTANCES</b>	Meets the product standard's requirements.
<b>10.5 PROTECTION AGAINST ELECTRIC SHOCK</b>	Does not apply, since the entire switchgear needs to be evaluated.
<b>10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS</b>	Does not apply, since the entire switchgear needs to be evaluated.
<b>10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS</b>	Is the panel builder's responsibility.
<b>10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS</b>	Is the panel builder's responsibility.
<b>10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH</b>	Is the panel builder's responsibility.
<b>10.9.3 IMPULSE WITHSTAND VOLTAGE</b>	Is the panel builder's responsibility.
<b>10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL</b>	Is the panel builder's responsibility.
<b>FITTED WITH:</b>	Front ring
<b>OPERATING FREQUENCY</b>	1800 Operations/h
<b>CLIMATIC PROOFING</b>	Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30
<b>CONNECTION TO SMARTWIRE-DT</b>	Yes With SWD-RMQ connections
<b>ACTUATING FORCE</b>	5 N
<b>AMBIENT OPERATING TEMPERATURE - MAX</b>	70 °C
<b>AMBIENT OPERATING TEMPERATURE - MIN</b>	-25 °C
<b>EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID</b>	0 W
<b>FORCE FOR POSITIVE OPENING - MIN</b>	0 N
<b>HEAT DISSIPATION CAPACITY PDISS</b>	0 W
<b>HEAT DISSIPATION PER POLE, CURRENT-DEPENDENT PVID</b>	0 W

## MULTIMEDIA

[MCI MultiColor Light Indicator RMQ compact solution](#)

[MCI Multicolor Light Indicator M22 with SmartWire-DT](#)

[RMQ small E-Stop emergency-stop button](#)

[easyE4 SmartWire-DT module with Remote Touch Display and RMQ multi color indicator](#)

## SALES NOTES

[eaton-control circuit-devices rmq-titan-fl144090en-en-us.pdf](#)

[eaton-rmq-flat-enclosure-flyer-fl047003en-en-us.pdf](#)

[eaton-rmq-small-e-stop-flyer-fl047006en-en-us.pdf](#)

[eaton-rmq-mci-multi-color-light-indicator-flyer-fl047005en-en-us.pdf](#)

<b>NUMBER OF COMMAND POSITIONS</b>	1
<b>OPENING DIAMETER</b>	22.5 mm
<b>OPENING HEIGHT</b>	0 mm
<b>RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)</b>	0 A
<b>BEZEL COLOR</b>	Titanium
<b>SHOCK RESISTANCE</b>	Mechanical, According to IEC/EN 60068-2-27 30 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms
<b>BEZEL MATERIAL</b>	Plastic
<b>DESIGN</b>	Flush Classical
<b>MOUNTING POSITION</b>	As required
<b>DEGREE OF PROTECTION</b>	NEMA 4X IP66 IP69K NEMA 12 NEMA 13 IP67 NEMA 3R
<b>DEGREE OF PROTECTION (FRONT SIDE)</b>	IP67/IP69K NEMA 4X
<b>INSCRIPTION</b>	Inscribed
<b>FRONT ELEMENT TYPE</b>	Flat
<b>FUNCTIONS</b>	Stay-put/spring-return function can be changed on device
<b>LENS TYPE</b>	Round
<b>LIFESPAN, MECHANICAL</b>	1,000,000 Operations (AC operated)
<b>STATIC HEAT DISSIPATION, NON-CURRENT-DEPENDENT PVS</b>	0 W
<b>WIDTH OPENING</b>	0 mm
<b>PRODUCT CATEGORY</b>	RMQ-Titan
<b>SIZE</b>	Front diameter: 29.7 mm
<b>SUITABLE FOR</b>	Illumination

PROJECT NAME:
PROJECT NUMBER:
PREPARED BY:
DATE:



**Eaton Corporation plc**  
Eaton House  
30 Pembroke Road  
Dublin 4, Ireland  
Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.

