

Specifications



TEST

Eaton 218419

Eaton Moeller® series M22 Lens, indicator light white, flush, TEST

General specifications

PRODUCT NAME	Eaton Moeller® series M22 Accessory Lens
CATALOG NUMBER	218419
MODEL CODE	M22-XL-W-GB9
EAN	4015082184193
PRODUCT LENGTH/DEPTH	29 mm
PRODUCT HEIGHT	9 mm
PRODUCT WIDTH	29 mm
PRODUCT WEIGHT	0.002 kg
CERTIFICATIONS	UL/CSA certification not required

Features & Functions

DESIGN	Flat Flush
FEATURES	Labelled
INSCRIPTION	Individual inscription possible: ≤ 5 characters: letter height 5 mm Individual inscription possible: > 5 characters: letter height 3 mm " TEST "
INSCRIPTION TYPE	Text
LENS COLOR	White

Climatic environmental conditions

AMBIENT OPERATING TEMPERATURE - MIN	-25 °C
AMBIENT OPERATING TEMPERATURE - MAX	70 °C

General

PRODUCT CATEGORY	Accessories
TYPE	Lenses for indicator lights

Communication

CONNECTION TO SMARTWIRE-DT	No
---------------------------------------	----

Design verification

EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID	0 W
HEAT DISSIPATION CAPACITY PDISS	0 W
HEAT DISSIPATION PER POLE, CURRENT-DEPENDENT PVID	0 W
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	0 A
STATIC HEAT DISSIPATION, NON-CURRENT-DEPENDENT PVS	0 W
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Please enquire
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.

Resources

CATALOGUES

[Flip catalog - Product Range Catalog - Command and indication](#)

[eaton-pushbuttons-signal-towers-sensors-assortment-overview-catalog-ca047003en-en-us.pdf](#)

[eaton-rmq-titan-brochure-br047004en-en-us.pdf](#)

DRAWINGS

[eaton-operating-button-symbol-007.eps](#)

ECAD MODEL

[ETN.218419.edz](#)

FLYERS

[eaton-rmq-titan-selection-aid-brochure-fl047002-en-us.pdf](#)

INSTALLATION INSTRUCTIONS

[IL04716002Z](#)

INSTALLATION VIDEOS

[RMQ Flat Design](#)

MCAD MODEL

[DA-CD-linse flach](#)

[DA-CS-linse flach](#)

MULTIMEDIA

[RMQ small E-Stop emergency-stop button](#)

[easyE4 SmartWire-DT module with Remote Touch Display and RMQ multi color indicator](#)

[MCI MultiColor Light Indicator RMQ compact solution](#)

[MCI Multicolor Light Indicator M22 with SmartWire-DT](#)

[eaton-rmq-small-e-stop-flyer-fl047006en-en-us.pdf](#)

[eaton-control circuit-devices rmq-titan-fl144090en-en-us.pdf](#)

[eaton-rmq-flat-enclosure-flyer-fl047003en-en-us.pdf](#)

[eaton-rmq-mci-multi-color-light-indicator-flyer-fl047005en-en-us.pdf](#)

SALES NOTES

10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	Is the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	Is the panel builder's responsibility.
10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH	Is the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	Is the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	Is the panel builder's responsibility.
10.10 TEMPERATURE RISE	Not applicable.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

PROJECT NAME:

PROJECT NUMBER:

PREPARED BY:

DATE:



Eaton Corporation plc

Eaton House
30 Pembroke Road
Dublin 4, Ireland
Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.

