Specifications



Photo is representative





Eaton 239474

Eaton Moeller® series DILM Contactor, 3 pole, 380 V 400 V 45 kW, 208 V 60 Hz, AC operation, Screw terminals

General specificatio	ns
PRODUCT NAME	Eaton Moeller® series DILM contactor
CATALOG NUMBER	239474
MODEL CODE	DILM95(208V60HZ)
EAN	4015082394745
PRODUCT LENGTH/DEPTH	160 mm
PRODUCT HEIGHT	170 mm
PRODUCT WIDTH	90 mm
PRODUCT WEIGHT	2.18 kg
CERTIFICATIONS	IEC/EN 60947 UL 60947-4-1 CSA File No.: 012528 UL CE UL File No.: E29096 UL Category Control No.: NLDX CSA Class No.: 2411-03, 3211-04 IEC/EN 60947-4-1 CSA-C22.2 No. 60947-4-1- 14 CSA VDE 0660
CATALOG NOTES	Contacts according to EN 50012
GLOBAL CATALOG	239474



Three-pole The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF INSUL. ATTON OF INSUL. ATTON ORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 INSCRIPTIONS Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements.	Product specifications	5
responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT 10.2.3.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING 10.2.6 MECHANICAL IMPACT 10.2.7 INSCRIPTIONS 10.2.7 INSCRIPTIONS POSSION AND AND AND AND AND AND AND AND AND AN	NUMBER OF POLES	Three-pole
10.11 SHORT-CIRCUIT RATING responsibility. The specifications for the switchgear must be observed. 10.12 ELECTROMAGNETIC COMPATIBILITY ls the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION Meets the product standard's requirements. 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL IMPACT 10.2.7 INSCRIPTIONS Meets the product standard's requirements.	10.10 TEMPERATURE RISE	responsible for the temperature rise calculation. Eaton will provide heat dissipation
10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING 10.2.6 MECHANICAL IMPACT 10.2.7 INSCRIPTIONS The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements.		responsibility. The specifications for the switchgear must be
requirements, provided the information in the instruction leaflet (IL) is observed. 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING 10.2.6 MECHANICAL IMPACT 10.2.7 INSCRIPTIONS Pequirements, provided the information in the instruction in the		responsibility. The specifications for the switchgear must be
RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING 10.2.6 MECHANICAL IMPACT 10.2.7 INSCRIPTIONS Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements.		requirements, provided the information in the instruction leaflet (IL) is
THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL IMPACT 10.2.7 INSCRIPTIONS Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements.		
RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL IMPACT Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the product standard's requirements.	THERMAL STABILITY OF	•
INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL IMPACT Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated.	RESISTANCE OF INSULATING MATERIALS	· •
ULTRA-VIOLET (UV) RADIATIONMeets the product standard's requirements.10.2.5 LIFTINGDoes not apply, since the entire switchgear needs to be evaluated.10.2.6 MECHANICAL IMPACTDoes not apply, since the entire switchgear needs to 	INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT.	-
10.2.5 LIFTING entire switchgear needs to be evaluated. 10.2.6 MECHANICAL Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 INSCRIPTIONS Meets the product standard's requirements. 10.3 DEGREE OF Does not apply, since the	ULTRA-VIOLET (UV)	
entire switchgear needs to be evaluated. 10.2.7 INSCRIPTIONS Meets the product standard's requirements. 10.3 DEGREE OF Does not apply, since the	10.2.5 LIFTING	entire switchgear needs to
standard's requirements. 10.3 DEGREE OF Does not apply, since the		entire switchgear needs to
	10.2.7 INSCRIPTIONS	•

Resources	
	Product Range Catalog Switching and protecting motors
CATALOGS	SmartWire-DT Catalog
	eaton-product-overview- for-machinery-catalogue- ca08103003zen-en-us.pdf
	eaton-contactors-switch-dilm-characteristic-curve-002.eps
	eaton-contactors-switch- dilm-characteristic- curve.eps
CHARACTERISTIC CURVE	eaton-contactors- component-dilm- characteristic-curve- 003.eps
	eaton-contactors-short- time-loading-dilm- characteristic-curve- 002.eps
DECLARATIONS OF CONFORMITY	DA-DC-00004818.pdf DA-DC-00004781.pdf
	· · · · · · · · · · · · · · · · · · ·
	eaton-contactors- mounting-dilm-
	dimensions.eps
	•
	eaton-contactors-
	eaton-contactors- mounting-dilm- dimensions-002.eps
	mounting-dilm- dimensions-002.eps
	mounting-dilm-
DRAWINGS	mounting-dilm-dimensions-002.eps eaton-contactors-dilm-dimensions-011.eps
DRAWINGS	mounting-dilm-dimensions-002.eps eaton-contactors-dilm-
DRAWINGS	mounting-dilm-dimensions-002.eps eaton-contactors-dilm-dimensions-011.eps eaton-contactors-dilm-
DRAWINGS	mounting-dilm-dimensions-002.eps eaton-contactors-dilm-dimensions-011.eps eaton-contactors-dilm-dimensions-003.eps eaton-contactors-dilm-3d-
DRAWINGS	mounting-dilm-dimensions-002.eps eaton-contactors-dilm-dimensions-011.eps eaton-contactors-dilm-dimensions-003.eps eaton-contactors-dilm-3d-drawing.eps
DRAWINGS	mounting-dilm-dimensions-002.eps eaton-contactors-dilm-dimensions-011.eps eaton-contactors-dilm-dimensions-003.eps eaton-contactors-dilm-3d-drawing.eps eaton-contactors-dilm-3d-
DRAWINGS	mounting-dilm-dimensions-002.eps eaton-contactors-dilm-dimensions-011.eps eaton-contactors-dilm-dimensions-003.eps eaton-contactors-dilm-3d-drawing.eps eaton-contactors-dilm-3d-drawing-013.eps eaton-general-ie-ready-dilm-contactor-
	mounting-dilm-dimensions-002.eps eaton-contactors-dilm-dimensions-011.eps eaton-contactors-dilm-dimensions-003.eps eaton-contactors-dilm-3d-drawing.eps eaton-contactors-dilm-3d-drawing-013.eps eaton-general-ie-ready-dilm-contactor-standards.eps
DRAWINGS ECAD MODEL	mounting-dilm-dimensions-002.eps eaton-contactors-dilm-dimensions-011.eps eaton-contactors-dilm-dimensions-003.eps eaton-contactors-dilm-3d-drawing.eps eaton-contactors-dilm-3d-drawing-013.eps eaton-general-ie-ready-dilm-contactor-

10.4 CLEARANCES AND CREEPAGE DISTANCES 10.5 PROTECTION AGAINST ELECTRIC SHOCK 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS 10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH 10.9.3 IMPULSE WITHSTAND VOLTAGE 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL OPERATING FREQUENCY CLIMATIC PROOFING CONNECTION TO SMARTWIRE-DT RATED IMPULSE WITHSTAND VOLTAGE UTILIZATION CATEGORY UTILIZATION CATEGORY CONNECTION CONNECTION CONNECTION ON AC-3: Normal AC induction motors: starting, switch off during running AC-1: Non-inductive or slightly inductive loads, resistance furnaces AC-4: Normal AC induction motors: starting, plugging, reversing, inching CONNECTION FRAME SIZE AMBIENT OPERATING TEMPERATURE - MAX AMBIENT OPERATING TEMPERATURE - MAX AMBIENT OPERATING TEMPERATURG -25 °C	ACCEMBLIEC	be evaluated.
TOUR PROTECTION AGAINST ELECTRIC SHOCK 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS 10.8 CONNECTIONS 10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH 10.9.3 IMPULSE WITHSTAND VOLTAGE CLIMATIC PROOFING CONNECTION TO SMARTWIRE-DT RATED IMPULSE WITHSTAND VOLTAGE (UIMP) UTILIZATION CATEGORY UTILIZATION CATEGORY CONNECTION CONNECTION TOUR STAND CONNECTION Standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's r	ASSEMBLIES	
AGAINST ELECTRIC SHOCK 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS 10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH 10.9.3 IMPULSE WITHSTAND VOLTAGE CLIMATIC PROOFING CONNECTION TO SMARTWIRE-DT RATED IMPULSE WITHSTAND VOLTAGE (UIMP) CONNECTION CATEGORY UTILIZATION CATEGORY CONNECTION CONNECTION CONNECTION CONNECTION AC-3: Normal AC induction motors: starting, switch off during running AC-1: Non-inductive or slightly inductive loads, resistance furnaces AC-4: Normal AC induction motors: starting, plugging, reversing, inching CONNECTION C		•
SWITCHING DEVICES AND COMPONENTS 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS 10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH 10.9.3 IMPULSE WITHSTAND VOLTAGE OPERATING FREQUENCY POLLUTION DEGREE CLIMATIC PROOFING CONNECTION TO SMARTWIRE-DT RATED IMPULSE WITHSTAND VOLTAGE (UIMP) UTILIZATION CATEGORY UTILIZATION CATEGORY CONNECTION CONNECTION CONNECTION CONNECTION CONNECTION CONNECTION CATEGORY CONNECTION CONNECTION CONNECTION CONNECTION CONNECTION CATEGORY CONNECTION CONNECTI	AGAINST ELECTRIC	entire switchgear needs to
ELECTRICAL CIRCUITS AND CONNECTIONS 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS 10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH 10.9.3 IMPULSE WITHSTAND VOLTAGE 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL OPERATING FREQUENCY POLLUTION DEGREE CLIMATIC PROOFING CONNECTION TO SMARTWIRE-DT RATED IMPULSE WITHSTAND VOLTAGE UTILIZATION CATEGORY UTILIZATION CATEGORY CONNECTION CONNECTION AC-3: Normal AC induction motors: starting, switch off during running AC-1: Non-inductive or slightly inductive loads, resistance furnaces AC-4: Normal AC induction motors: starting, plugging, reversing, inching CONNECTION FRAME SIZE AMBIENT OPERATING TEMPERATURE - MAX Is the panel builder's responsibility. Is the panel builder's responsible. Is the panel builder's responsible. Is the panel buil	SWITCHING DEVICES AND	entire switchgear needs to
TEXTERNAL CONDUCTORS 10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH 10.9.3 IMPULSE WITHSTAND VOLTAGE 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL OPERATING FREQUENCY POLLUTION DEGREE CLIMATIC PROOFING CONNECTION TO SMARTWIRE-DT RATED IMPULSE WITHSTAND VOLTAGE UITILIZATION CATEGORY UTILIZATION CATEGORY UTILIZATION CATEGORY CONNECTION SCREEN AC-4: Normal AC induction motors: starting, switch off during running AC-1: Non-inductive or slightly inductive loads, resistance furnaces AC-4: Normal AC induction motors: starting, plugging, reversing, inching CONNECTION SCREW terminals FRAME SIZE AMBIENT OPERATING TEMPERATURE - MAX Is the panel builder's responsibility. Is the panel builder's responsibili	ELECTRICAL CIRCUITS	
FREQUENCY ELECTRIC STRENGTH 10.9.3 IMPULSE WITHSTAND VOLTAGE 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL OPERATING FREQUENCY POLLUTION DEGREE CLIMATIC PROOFING CONNECTION TO SMARTWIRE-DT RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AC-3: Normal AC induction motors: starting, switch off during running AC-1: Non-inductive or slightly inductive loads, resistance furnaces AC-4: Normal AC induction motors: starting, plugging, reversing, inching CONNECTION CONNECTION SCIENCE STAR CONNECTION SCIENCE STAR AMBIENT OPERATING TEMPERATURE - MAX Is the panel builder's responsibility. Is th		•
Tesponsibility. 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL OPERATING FREQUENCY POLLUTION DEGREE CLIMATIC PROOFING CONNECTION TO SMARTWIRE-DT RATED IMPULSE WITHSTAND VOLTAGE (UIMP) UTILIZATION CATEGORY UTILIZATION CATEGORY TEMPERATING TEMPERATING TEMPERATURE - MAX CONNECTION SCREW terminals FRAME SIZE FS4 AMBIENT OPERATING TEMPERATURE - MAX Is the panel builder's responsibility. A6000 mechanical Operations/ Operations/ NAC operated) No perations/ hack on stantal AC operations/ Nac operated of the panel builder's responsibility. A6000 mechanical Operations/ Operations/ NAC operations/ NAC operated) No perations/ hack on stantal Damph heat, constant, to IEC 60068-2-78 Damp heat, constan	FREQUENCY ELECTRIC	•
Is the panel builder's responsibility. Solution Solution		•
OPERATING FREQUENCY Operations/h (AC operated) POLLUTION DEGREE CLIMATIC PROOFING Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 CONNECTION TO SMARTWIRE-DT RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AC-3: Normal AC induction motors: starting, switch off during running AC-1: Non-inductive or slightly inductive loads, resistance furnaces AC-4: Normal AC induction motors: starting, plugging, reversing, inching CONNECTION Screw terminals FRAME SIZE FS4 AMBIENT OPERATING TEMPERATURE - MAX	ENCLOSURES MADE OF	•
CLIMATIC PROOFING Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 CONNECTION TO SMARTWIRE-DT RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AC-3: Normal AC induction motors: starting, switch off during running AC-1: Non-inductive or slightly inductive loads, resistance furnaces AC-4: Normal AC induction motors: starting, plugging, reversing, inching CONNECTION Screw terminals FRAME SIZE AMBIENT OPERATING TEMPERATURE - MAX Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-78 Damp heat, constant, to IEC 60068-2-78 Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30	OPERATING FREQUENCY	Operations/h (AC
CLIMATIC PROOFING IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 CONNECTION TO SMARTWIRE-DT RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AC-3: Normal AC induction motors: starting, switch off during running AC-1: Non-inductive or slightly inductive loads, resistance furnaces AC-4: Normal AC induction motors: starting, plugging, reversing, inching CONNECTION Screw terminals FRAME SIZE AMBIENT OPERATING TEMPERATURE - MAX	POLLUTION DEGREE	3
RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AC-3: Normal AC induction motors: starting, switch off during running AC-1: Non-inductive or slightly inductive loads, resistance furnaces AC-4: Normal AC induction motors: starting, plugging, reversing, inching CONNECTION Screw terminals FRAME SIZE AMBIENT OPERATING TEMPERATURE - MAX	CLIMATIC PROOFING	IEC 60068-2-78 Damp heat, cyclic, to IEC
WITHSTAND VOLTAGE (UIMP) AC-3: Normal AC induction motors: starting, switch off during running AC-1: Non-inductive or slightly inductive loads, resistance furnaces AC-4: Normal AC induction motors: starting, plugging, reversing, inching CONNECTION Screw terminals FRAME SIZE AMBIENT OPERATING TEMPERATURE - MAX AC-3: Normal AC induction motors: starting, plugging, reversing, inching 60 °C		No
TEMPERATURE - MAX motors: starting, switch off during running AC-1: Non-inductive or slightly inductive loads, resistance furnaces AC-4: Normal AC induction motors: starting, plugging, reversing, inching CONNECTION Screw terminals FS4 60 °C	WITHSTAND VOLTAGE	8000 V AC
FRAME SIZE FS4 AMBIENT OPERATING TEMPERATURE - MAX FS4 60 °C	UTILIZATION CATEGORY	motors: starting, switch off during running AC-1: Non-inductive or slightly inductive loads, resistance furnaces AC-4: Normal AC induction motors: starting, plugging,
AMBIENT OPERATING TEMPERATURE - MAX 60 °C	CONNECTION	Screw terminals
TEMPERATURE - MAX		
AMBIENT OPERATING -25 °C	FRAME SIZE	FS4
	AMBIENT OPERATING	

INSTALLATION INSTRUCTIONS	eaton-dil-contactors- instruction-leaflet- il03407039z.pdf
INSTALLATION VIDEOS	WIN-WIN with push-in technology
MCAD MODEL	DA-CS-dil_m80_170 DA-CD-dil_m80_170
SYSTEM OVERVIEW	eaton-contactors-dilm- contactor-system- overview.eps
WIRING DIAGRAMS	eaton-contactors-contact- dilm-wiring-diagram- 003.eps

TEMPERATURE - MIN	
AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX	40 °C
AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN	25 °C
AMBIENT STORAGE TEMPERATURE - MAX	80 °C
AMBIENT STORAGE TEMPERATURE - MIN	40 °C
ASSIGNED MOTOR POWER AT 115/120 V, 60 HZ, 1-PHASE	7.5 HP
ASSIGNED MOTOR POWER AT 200/208 V, 60 HZ, 3-PHASE	30 HP
ASSIGNED MOTOR POWER AT 230/240 V, 60 HZ, 1-PHASE	15 HP
ASSIGNED MOTOR POWER AT 230/240 V, 60 HZ, 3-PHASE	40 HP
ASSIGNED MOTOR POWER AT 460/480 V, 60 HZ, 3-PHASE	75 HP
ASSIGNED MOTOR POWER AT 575/600 V, 60 HZ, 3-PHASE	100 HP
CONVENTIONAL THERMAL CURRENT ITH (1-POLE, ENCLOSED)	250 A
CONVENTIONAL THERMAL CURRENT ITH (3-POLE, ENCLOSED)	100 A
CONVENTIONAL THERMAL CURRENT ITH AT 55°C (3-POLE, OPEN)	115 A
CONVENTIONAL THERMAL CURRENT ITH OF MAIN CONTACTS (1- POLE, OPEN)	275 A
EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID	12.6 W
HEAT DISSIPATION CAPACITY PDISS	0 W
HEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID	4.2 W

APPLICATION	Contactors for Motors
PRODUCT CATEGORY	Contactors
PROTECTION	Finger and back-of-hand proof, Protection against direct contact when actuated from front (EN 50274)
ARCING TIME	15 ms
ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT	Screw connection
SCREWDRIVER SIZE	0.8 x 5.5/1 x 6 mm, Terminal screw, Control circuit cables, Standard screwdriver 2, Terminal screw, Control circuit cables, Pozidriv screwdriver
VOLTAGE TYPE	AC
DEGREE OF PROTECTION	IP00
NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)	0
NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)	0
NUMBER OF CONTACTS (NORMALLY CLOSED) AS MAIN CONTACT	0
NUMBER OF MAIN CONTACTS (NORMALLY OPEN CONTACT)	3
RATED BREAKING CAPACITY AT 220/230 V	950 A
RATED BREAKING CAPACITY AT 380/400 V	950 A
RATED BREAKING CAPACITY AT 500 V	950 A
RATED BREAKING CAPACITY AT 660/690 V	800 A
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MAX	0 V
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MIN	0 V
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MAX	208 V

RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MIN	208 V
DROP-OUT VOLTAGE	AC operated: 0.6 - 0.3 x UC, AC operated
OVERVOLTAGE CATEGORY	III
DUTY FACTOR	100 %
EMITTED INTERFERENCE	According to EN 60947-1
INTERFERENCE IMMUNITY	According to EN 60947-1
LIFESPAN, MECHANICAL	10,000,000 Operations (AC operated)
PICK-UP VOLTAGE	0.8 - 1.1 V AC x Uc
POWER CONSUMPTION, PICK-UP, 50 HZ	310 VA, Dual-frequency coil in a cold state and 1.0 x Us, at 50 Hz
SAFE ISOLATION	690 V AC, Between the contacts, According to EN 61140 690 V AC, Between coil and contacts, According to EN 61140
POWER CONSUMPTION, PICK-UP, 60 HZ	345 VA, Dual-frequency coil in a cold state and 1.0 x Us, at 60 Hz
RESIDUAL CURRENT	1 mA (with actuation of A1 - A2 by the electronics with "0" signal)
SCREW SIZE	M3.5, Terminal screw, Control circuit cables M10, Terminal screw, Main cables 5 mm AF, Hexagon socket- head spanner, Terminal screw, Main cables
POWER CONSUMPTION, SEALING, 50 HZ	5.8 W, Dual-frequency coil in a cold state and 1.0 x Us, at 50 Hz 26 VA, Dual-frequency coil in a cold state and 1.0 x Us, at 50 Hz
POWER CONSUMPTION, SEALING, 60 HZ	5.8 W, Dual-frequency coil in a cold state and 1.0 x Us, at 60 Hz 30 VA, Dual-frequency coil in a cold state and 1.0 x Us, at 60 Hz
TERMINAL CAPACITY (STRANDED)	1 x (16 - 70) mm², Main cables

	2 x (16 - 50) mm², Main cables
TERMINAL CAPACITY (COPPER BAND)	2 x (6 x 16 x 0.8) mm (Number of segments x width x thickness), Main cables
TERMINAL CAPACITY (FLEXIBLE WITH FERRULE)	1 x (10 - 70) mm², Main cables 2 x (0.75 - 2.5) mm², Control circuit cables 2 x (10 - 50) mm², Main cables 1 x (0.75 - 2.5) mm², Control circuit cables
SHOCK RESISTANCE	7 g, N/O auxiliary contact, Mechanical, according to IEC/EN 60068-2-27 when tabletop-mounted, Halfsinusoidal shock 10 ms 5 g, N/C auxiliary contact, Mechanical, according to IEC/EN 60068-2-27 when tabletop-mounted, Halfsinusoidal shock 10 ms 10 g, N/O main contact, Mechanical, according to IEC/EN 60068-2-27, Halfsinusoidal shock 10 ms 7 g, N/O auxiliary contact, Mechanical, according to IEC/EN 60068-2-27, Halfsinusoidal shock 10 ms 5 g, N/C auxiliary contact, Mechanical, according to IEC/EN 60068-2-27, Halfsinusoidal shock 10 ms 5 g, N/C auxiliary contact, Mechanical, according to IEC/EN 60068-2-27, Halfsinusoidal shock 10 ms 10 g, N/O main contact, Mechanical, according to IEC/EN 60068-2-27 when tabletop-mounted, Halfsinusoidal shock 10 ms
TERMINAL CAPACITY (SOLID)	1 x (0.75 - 4) mm², Control circuit cables 2 x (0.75 - 2.5) mm², Control circuit cables
TERMINAL CAPACITY (SOLID/STRANDED AWG)	Single 83/0, double 82/0, Main cables 18 - 14, Control circuit cables
SWITCHING CAPACITY (MAIN CONTACTS, GENERAL USE)	125 A, Maximum motor rating (UL/CSA)
TIGHTENING TORQUE	1.2 Nm, Screw terminals, Control circuit cables

	14 Nm, Screw terminals, Main cables
RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MAX	0 V
RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MIN	0 V
RATED INSULATION VOLTAGE (UI)	690 V
RATED MAKING CAPACITY UP TO 690 V (COS PHI TO IEC/EN 60947)	1330 A
RATED OPERATIONAL CURRENT (IE) AT AC-1, 380 V, 400 V, 415 V	130 A
RATED OPERATIONAL CURRENT (IE) AT AC-3, 220 V, 230 V, 240 V	95 A
RATED OPERATIONAL CURRENT (IE) AT AC-3, 380 V, 400 V, 415 V	95 A
RATED OPERATIONAL CURRENT (IE) AT AC-3, 440 V	95 A
RATED OPERATIONAL CURRENT (IE) AT AC-3, 500 V	95 A
RATED OPERATIONAL CURRENT (IE) AT AC-3, 660 V, 690 V	80 A
RATED OPERATIONAL CURRENT (IE) AT AC-4, 220 V, 230 V, 240 V	50 A
RATED OPERATIONAL CURRENT (IE) AT AC-4, 400 V	50 A
RATED OPERATIONAL CURRENT (IE) AT AC-4, 440 V	50 A
RATED OPERATIONAL CURRENT (IE) AT AC-4, 500 V	50 A
RATED OPERATIONAL CURRENT (IE) AT AC-4, 660 V, 690 V	37 A
RATED OPERATIONAL CURRENT (IE) AT DC-1, 110 V	110 A

RATED OPERATIONAL CURRENT (IE) AT DC-1, 220 V	70 A
RATED OPERATIONAL CURRENT (IE) AT DC-1, 60 V	110 A
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	95 A
RATED OPERATIONAL POWER AT AC-3, 240 V, 50 HZ	32 kW
RATED OPERATIONAL POWER AT AC-3, 380/400 V, 50 HZ	45 kW
RATED OPERATIONAL POWER AT AC-3, 415 V, 50 HZ	57 kW
RATED OPERATIONAL POWER AT AC-4, 220/230 V, 50 HZ	16 kW
RATED OPERATIONAL POWER AT AC-4, 240 V, 50 HZ	17 kW
RATED OPERATIONAL POWER AT AC-4, 380/400 V, 50 HZ	26 kW
RATED OPERATIONAL POWER AT AC-4, 415 V, 50 HZ	30 kW
RATED OPERATIONAL POWER AT AC-4, 440 V, 50 HZ	32 kW
RATED OPERATIONAL POWER AT AC-4, 500 V, 50 HZ	36 kW
RATED OPERATIONAL POWER AT AC-4, 660/690 V, 50 HZ	35 kW
RATED OPERATIONAL POWER (NEMA)	55 kW
RATED OPERATIONAL VOLTAGE (UE) AT AC - MAX	690 V
RESISTANCE PER POLE	0.6 mΩ
STATIC HEAT DISSIPATION, NON- CURRENT-DEPENDENT PVS	5.8 W
STRIPPING LENGTH	10 mm

(CONTROL CIRCUIT	
CABLE) STRIPPING LENGTH	24 mm
(MAIN CABLE) SWITCHING TIME (AC OPERATED, MAKE CONTACTS, CLOSING DELAY) - MAX	20 ms
SWITCHING TIME (AC OPERATED, MAKE CONTACTS, CLOSING DELAY) - MIN	14 ms
SWITCHING TIME (AC OPERATED, MAKE CONTACTS, OPENING DELAY) - MAX	14 ms
SWITCHING TIME (AC OPERATED, MAKE CONTACTS, OPENING DELAY) - MIN	9 ms
SHORT-CIRCUIT CURRENT RATING (BASIC RATING)	600 A, max. CB, SCCR (UL/CSA) 600 A, max. Fuse, SCCR (UL/CSA) 10 kA, SCCR (UL/CSA)
SHORT-CIRCUIT CURRENT RATING (HIGH FAULT AT 480 V)	30/100 kA, Fuse, SCCR (UL/CSA) 65 kA, CB, SCCR (UL/CSA) 300/300 A, Class J, max. Fuse, SCCR (UL/CSA) 250 A, max. CB, SCCR (UL/CSA)
SHORT-CIRCUIT CURRENT RATING (HIGH FAULT AT 600 V)	30/100 kA, Fuse, SCCR (UL/CSA) 30 kA, CB, SCCR (UL/CSA) 350 A, max. CB, SCCR (UL/CSA) 300/300 A, Class J, max. Fuse, SCCR (UL/CSA)
SHORT-CIRCUIT PROTECTION RATING (TYPE 1 COORDINATION) AT 400 V	250 A gG/gL
SUITABLE FOR	Also motors with efficiency class IE3
SHORT-CIRCUIT PROTECTION RATING (TYPE 1 COORDINATION) AT 690 V	200 A gG/gL
SHORT-CIRCUIT PROTECTION RATING (TYPE 2 COORDINATION)	160 A gG/gL

AT 400 V	
SHORT-CIRCUIT PROTECTION RATING (TYPE 2 COORDINATION) AT 690 V	160 A gG/gL
SPECIAL PURPOSE RATING OF BALLAST ELECTRICAL DISCHARGE LAMPS	100 A (480V 60Hz 3phase, 277V 60Hz 1phase) 100 A (600V 60Hz 3phase, 347V 60Hz 1phase)
SPECIAL PURPOSE RATING OF DEFINITE PURPOSE RATING	570 A, LRA 480 V 60 Hz 3- ph, 100,000 cycles acc. to UL 1995, (UL/CSA) 95 A, FLA 480 V 60 Hz 3- ph, 100,000 cycles acc. to UL 1995, (UL/CSA)
SPECIAL PURPOSE RATING OF ELEVATOR CONTROL	62.1 A, 200 V 60 Hz 3-ph, (UL/CSA) 30 HP, 240 V 60 Hz 3-ph, (UL/CSA) 80 A, 240 V 60 Hz 3-ph, (UL/CSA) 60 HP, 480 V 60 Hz 3-ph, (UL/CSA) 75 HP, 600 V 60 Hz 3-ph, (UL/CSA) 20 HP, 200 V 60 Hz 3-ph, (UL/CSA) 77 A, 480 V 60 Hz 3-ph, (UL/CSA) 77 A, 600 V 60 Hz 3-ph, (UL/CSA)
SPECIAL PURPOSE RATING OF REFRIGERATION CONTROL (CSA ONLY)	70 A, FLA 600 V 60 Hz 3phase; (CSA) 90 A, FLA 480 V 60 Hz 3phase; (CSA) 540 A, LRA 480 V 60 Hz 3phase; (CSA) 420 A, LRA 600 V 60 Hz 3phase; (CSA)
SPECIAL PURPOSE RATING OF RESISTANCE AIR HEATING	100 A, 600 V 60 Hz 3phase, 347 V 60 Hz 1phase, (UL/CSA) 100 A, 480 V 60 Hz 3phase, 277 V 60 Hz 1phase, (UL/CSA)
SPECIAL PURPOSE RATING OF TUNGSTEN INCANDESCENT LAMPS	100 A, 600 V 60 Hz 3phase, 347 V 60 Hz 1phase, (UL/CSA) 100 A, 480 V 60 Hz 3phase, 277 V 60 Hz 1phase, (UL/CSA)
CONVENTIONAL THERMAL CURRENT ITH	130 A

AT 40°C (3-POLE, OPEN)	
CONVENTIONAL THERMAL CURRENT ITH AT 50°C (3-POLE, OPEN)	125 A
CONVENTIONAL THERMAL CURRENT ITH AT 60°C (3-POLE, OPEN)	110 A
RATED OPERATIONAL POWER AT AC-3, 440 V, 50 HZ	60 kW
RATED OPERATIONAL POWER AT AC-3, 500 V, 50 HZ	70 kW
RATED OPERATIONAL POWER AT AC-3, 690 V, 50 HZ	75 kW
ACTUATING VOLTAGE	208 V 60 Hz
ALTITUDE	Max. 2000 m
OPERATING VOLTAGE AT AC, 50 HZ - MIN	230 V
OPERATING VOLTAGE AT AC, 50 HZ - MAX	690 V
OPERATING VOLTAGE AT AC, 60 HZ - MIN	230 V
OPERATING VOLTAGE AT AC, 60 HZ - MAX	690 V

PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	
DATE:	



Eaton Corporation plc

Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

 $\hbox{@ 2025 Eaton.}$ All Rights Reserved.

Follow us on social media to get the latest product and support information.









