Specifications



Photo is representative





Eaton 259079

Eaton Moeller series NZM - Molded Case Circuit Breaker. Circuit-breaker, 3p, 100A, B, frame1, A100

| General specification | ıs |
|-------------------------|--|
| PRODUCT NAME | Eaton Moeller series NZM molded case circuit breaker thermo-magnetic |
| CATALOG NUMBER | 259079 |
| MODEL CODE | NZMB1-A100 |
| EAN | 4015082590796 |
| PRODUCT LENGTH/DEPTH | 88 mm |
| PRODUCT HEIGHT | 145 mm |
| PRODUCT WIDTH | 90 mm |
| PRODUCT WEIGHT | 1.069 kg |
| COMPLIANCES | RoHS conform |
| CERTIFICATIONS | IEC/EN 60947 IEC |
| GLOBAL CATALOG | 259079 |



| Product specification | S |
|--|--|
| AMPERAGE RATING | 100 A |
| VOLTAGE RATING | 440 V - 440 V |
| CIRCUIT BREAKER FRAME TYPE | NZM1 |
| FEATURES | Protection unit |
| 10.10 TEMPERATURE RISE | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 SHORT-CIRCUIT RATING | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 ELECTROMAGNETIC COMPATIBILITY | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 MECHANICAL FUNCTION | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |
| 10.2.2 CORROSION RESISTANCE | Meets the product standard's requirements. |
| 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES | Meets the product standard's requirements. |
| 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT | Meets the product standard's requirements. |
| 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS | Meets the product standard's requirements. |
| 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION | Meets the product standard's requirements. |
| 10.2.5 LIFTING | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 MECHANICAL IMPACT | Does not apply, since the entire switchgear needs to be evaluated. |

| Resources eaton-feerum-the-whole-grain-solution-success-story-en-us.pdf eaton-digital-nzm-brochure-br013003en-en-us.pdf catalogs eaton-digital-nzm-catalog-ca013003en-en-us.pdf eaton-circuit-breaker-nzm-mccb-characteristic-curve-051.eps eaton-circuit-breaker-characteristic-power-defense-mccb-characteristic-curve-038.eps eaton-circuit-breaker-characteristic-power-defense-mccb-characteristic-curve-032.eps eaton-molded-case-circuit-breaker-circuit-breaker-characteristic-power-defense-mccb-characteristic-curve-032.eps |
|---|
| BROCHURES grain-solution-success- story-en-us.pdf eaton-digital-nzm- brochure-br013003en-en- us.pdf eaton-digital-nzm-catalog- ca013003en-en-us.pdf eaton-circuit-breaker-nzm- mccb-characteristic-curve- 051.eps eaton-circuit-breaker- characteristic-power- defense-mccb- characteristic-curve- 038.eps eaton-circuit-breaker- characteristic-power- defense-mccb- characteristic-power- defense-mccb- characteristic-curve- 032.eps eaton-molded-case-circuit- |
| ca013003en-en-us.pdf eaton-circuit-breaker-nzm- mccb-characteristic-curve- 051.eps eaton-circuit-breaker- characteristic-power- defense-mccb- characteristic-curve- 038.eps eaton-circuit-breaker- characteristic-power- defense-mccb- characteristic-power- defense-mccb- characteristic-curve- 032.eps eaton-molded-case-circuit- |
| characteristic-curve- 051.eps eaton-circuit-breaker- characteristic-power- defense-mccb- characteristic-curve- 038.eps eaton-circuit-breaker- characteristic-power- defense-mccb- characteristic-power- defense-mccb- characteristic-curve- 032.eps eaton-molded-case-circuit- |
| CHARACTERISTIC CURVE CHARACTERISTIC CURVE Characteristic-curve- 038.eps eaton-circuit-breaker- characteristic-power- defense-mccb- characteristic-curve- 032.eps eaton-molded-case-circuit- |
| characteristic-power- defense-mccb- characteristic-curve- 032.eps eaton-molded-case-circuit- |
| |
| DECLARATIONS OF breaker-declaration-of- CONFORMITY conformity- eu250289en.pdf |
| eaton-circuit-breaker-nzm- mccb-dimensions-017.eps |
| DRAWINGS eaton-circuit-breaker- switch-nzm-mccb- dimensions-014.eps |
| <u>eaton-circuit-breaker-</u> <u>switch-nzm-mccb-3d-</u> <u>drawing-006.eps</u> |
| |
| ECAD MODEL <u>ETN.259079.edz</u> |
| INSTALLATION INSTRUCTIONS ETN.259079.edz eaton-cirucit-breaker- switch-disconnector- nzmb-il01203004z.pdf |
| INSTALLATION INSTRUCTIONS eaton-cirucit-breaker- switch-disconnector- |
| INSTALLATION INSTRUCTIONS eaton-cirucit-breaker- switch-disconnector- nzmb-il01203004z.pdf The new digital NZM Range INSTALLATION VIDEOS |
| INSTALLATION INSTRUCTIONS eaton-cirucit-breaker- switch-disconnector- nzmb-il01203004z.pdf The new digital NZM Range Introduction of the new |

| Meets the product standard's requirements. |
|---|
| Does not apply, since the entire switchgear needs to be evaluated. |
| Meets the product standard's requirements. |
| Does not apply, since the entire switchgear needs to be evaluated. |
| Does not apply, since the entire switchgear needs to be evaluated. |
| ls the panel builder's responsibility. |
| ls the panel builder's responsibility. |
| ls the panel builder's responsibility. |
| ls the panel builder's responsibility. |
| ls the panel builder's responsibility. |
| 3 |
| DIN rail (top hat rail) mounting optional Fixed Built-in device fixed built- in technique |
| Damp heat, cyclic, to IEC |
| 60068-2-30 Damp heat, constant, to IEC 60068-2-78 |
| Damp heat, constant, to |
| Damp heat, constant, to IEC 60068-2-78 |
| Damp heat, constant, to IEC 60068-2-78 |
| Damp heat, constant, to IEC 60068-2-78 21.9 W A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the |
| |

| | | eaton-molded-case- switches-mcad-3d-models- nzm1-3p.stp |
|---|-----------------------|--|
| | | eaton-molded-case- switches-mcad-drawings- nzm1-3p.dwg |
| 0 | PEP ECO-PASSPORT | eaton-molded-case- switches-pep-eato-00225- v0101-en.pdf |
| 0 | TECHNICAL DATA SHEETS | eaton-nzm-technical- information-sheet |
| | | |

| AMBIENT STORAGE TEMPERATURE - MAX | 70 °C |
|---|---|
| AMBIENT STORAGE TEMPERATURE - MIN | 40 °C |
| NUMBER OF AUXILIARY CONTACTS (CHANGE- OVER CONTACTS) | 0 |
| NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS) | 0 |
| NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS) | 0 |
| PROTECTION AGAINST DIRECT CONTACT | Finger and back-of-hand proof to DIN EN 50274/VDE 0106 part 110 |
| DEGREE OF PROTECTION | IP20 IP20 (basic degree of protection, in the operating controls area) |
| DIRECTION OF INCOMING SUPPLY | As required |
| ELECTRICAL TYPE OF | Frame clamp |
| CONNECTION TYPE OF MAIN CIRCUIT | riaille ciailip |
| | 20000 operations |
| MAIN CIRCUIT | |
| MAIN CIRCUIT LIFESPAN, MECHANICAL OVERVOLTAGE | 20000 operations |
| MAIN CIRCUIT LIFESPAN, MECHANICAL OVERVOLTAGE CATEGORY DEGREE OF PROTECTION | 20000 operations III IP66 (with door coupling rotary handle) IP40 (with insulating |
| MAIN CIRCUIT LIFESPAN, MECHANICAL OVERVOLTAGE CATEGORY DEGREE OF PROTECTION (IP), FRONT SIDE | 20000 operations III IP66 (with door coupling rotary handle) IP40 (with insulating surround) IP10 (tunnel terminal) IP00 (terminations, phase |
| MAIN CIRCUIT LIFESPAN, MECHANICAL OVERVOLTAGE CATEGORY DEGREE OF PROTECTION (IP), FRONT SIDE DEGREE OF PROTECTION (TERMINATIONS) | 20000 operations III IP66 (with door coupling rotary handle) IP40 (with insulating surround) IP10 (tunnel terminal) IP00 (terminations, phase isolator and strip terminal) |
| MAIN CIRCUIT LIFESPAN, MECHANICAL OVERVOLTAGE CATEGORY DEGREE OF PROTECTION (IP), FRONT SIDE DEGREE OF PROTECTION (TERMINATIONS) NUMBER OF POLES TERMINAL CAPACITY | 20000 operations III IP66 (with door coupling rotary handle) IP40 (with insulating surround) IP10 (tunnel terminal) IP00 (terminations, phase isolator and strip terminal) Three-pole Min. 2 segments of 9 mm x 0.8 mm at box terminal Max. 9 segments of 9 mm |
| MAIN CIRCUIT LIFESPAN, MECHANICAL OVERVOLTAGE CATEGORY DEGREE OF PROTECTION (IP), FRONT SIDE DEGREE OF PROTECTION (TERMINATIONS) NUMBER OF POLES TERMINAL CAPACITY (COPPER STRIP) | 20000 operations III IP66 (with door coupling rotary handle) IP40 (with insulating surround) IP10 (tunnel terminal) IP00 (terminations, phase isolator and strip terminal) Three-pole Min. 2 segments of 9 mm x 0.8 mm at box terminal Max. 9 segments of 9 mm x 0.8 mm at box terminal 7500 operations at 400 V AC-1 7500 operations at 415 V |
| MAIN CIRCUIT LIFESPAN, MECHANICAL OVERVOLTAGE CATEGORY DEGREE OF PROTECTION (IP), FRONT SIDE DEGREE OF PROTECTION (TERMINATIONS) NUMBER OF POLES TERMINAL CAPACITY (COPPER STRIP) | 20000 operations III IP66 (with door coupling rotary handle) IP40 (with insulating surround) IP10 (tunnel terminal) IP00 (terminations, phase isolator and strip terminal) Three-pole Min. 2 segments of 9 mm x 0.8 mm at box terminal Max. 9 segments of 9 mm x 0.8 mm at box terminal 7500 operations at 400 V AC-1 7500 operations at 415 V AC-1 System and cable |

| | fuse, if the expected short- circuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit breaking capacity lcn) • Rated current = rated uninterrupted current: 100 A • Terminal capacity hint: Up to 95 mm² can be connected depending on the cable manufacturer. |
|---|---|
| APPLICATION | Use in unearthed supply systems at 440 V |
| SHOCK RESISTANCE | 20 g (half-sinusoidal shock 20 ms) |
| POSITION OF CONNECTION FOR MAIN CURRENT CIRCUIT | Front side |
| RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN) | 100 A |
| POWER LOSS | 21.9 W |
| RELEASE SYSTEM | Thermomagnetic release |
| SHORT-CIRCUIT TOTAL BREAKTIME | < 10 ms |
| SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MAX | 1000 A |
| SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MIN | 600 A |
| TERMINAL CAPACITY (CONTROL CABLE) | 0.75 mm ² - 2.5 mm ² (1x) 0.75 mm ² - 1.5 mm ² (2x) |
| TERMINAL CAPACITY (COPPER BUSBAR) | Min. 12 mm x 5 mm direct at switch rear-side connection Max. 16 mm x 5 mm direct at switch rear-side connection M6 at rear-side screw connection |

| TERMINAL CAPACITY (COPPER SOLID CONDUCTOR/CABLE) | 10 mm ² - 16 mm ² (1x) direct at switch rear-side connection 6 mm ² - 16 mm ² (2x) direct at switch rear-side connection 10 mm ² - 16 mm ² (1x) at box terminal 6 mm ² - 16 mm ² (2x) at box terminal 16 mm ² (1x) at tunnel terminal |
|---|---|
| TERMINAL CAPACITY (ALUMINUM SOLID CONDUCTOR/CABLE) | 10 mm ² - 16 mm ² (2x) direct at switch rear-side connection 16 mm ² (1x) at tunnel terminal 10 mm ² - 16 mm ² (1x) direct at switch rear-side connection |
| TERMINAL CAPACITY (COPPER STRANDED CONDUCTOR/CABLE) | 25 mm² - 95 mm² (1x) at 1- hole tunnel terminal 25 mm² (2x) direct at switch rear-side connection 10 mm² - 70 mm² (1x) direct at switch rear-side connection 6 mm² - 25 mm² (2x) at box terminal 10 mm² - 70 mm² (1x) at box terminal |
| TERMINAL CAPACITY (ALUMINUM STRANDED CONDUCTOR/CABLE) | 25 mm² - 35 mm² (2x) direct at switch rear-side connection 25 mm² - 35 mm² (1x) direct at switch rear-side connection 25 mm² - 95 mm² (1x) at tunnel terminal |
| HANDLE TYPE | Rocker lever |
| SHORT DELAY CURRENT SETTING (ISD) - MAX | 0 A |
| SHORT DELAY CURRENT SETTING (ISD) - MIN | 0 A |
| INSTANTANEOUS CURRENT SETTING (II) - MAX | 1000 A |
| INSTANTANEOUS CURRENT SETTING (II) - MIN | 600 A |
| NUMBER OF OPERATIONS PER HOUR - | 120 |

| MAX | |
|--|---|
| OVERLOAD CURRENT SETTING (IR) - MAX | 100 A |
| OVERLOAD CURRENT SETTING (IR) - MIN | 80 A |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 230 V, 50/60 HZ | 30 kA |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 400/415 V, 50/60 HZ | 25 kA |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 440 V, 50/60 HZ | 18.5 kA |
| RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 400/415 V, 50/60 HZ | 53 kA |
| RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 440 V, 50/60 HZ | 53 kA |
| STANDARD TERMINALS | Box terminal |
| OPTIONAL TERMINALS | Connection on rear. Screw terminal. Tunnel terminal |
| RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 240 V, 50/60 HZ | 63 kA |
| RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT AUXILIARY CONTACTS | 6000 V |
| RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT MAIN CONTACTS | 6000 V |
| RATED INSULATION VOLTAGE (UI) | 690 V AC |

| PROJECT NAME: | |
|-----------------|--|
| PROJECT NUMBER: | |
| PREPARED BY: | |
| DATE: | |



Eaton Corporation plc

Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









