Specifications



Photo is representative





Eaton 265743

Eaton Moeller series NZM - Molded Case Circuit Breaker. Circuit-breaker, 3p, 50A, H2-S50

General specification	าร
PRODUCT NAME	Eaton Moeller series NZM molded case circuit breaker magnetic
CATALOG NUMBER	265743
MODEL CODE	NZMH2-S50
EAN	4015082657437
PRODUCT LENGTH/DEPTH	149 mm
PRODUCT HEIGHT	184 mm
PRODUCT WIDTH	105 mm
PRODUCT WEIGHT	2.345 kg
COMPLIANCES	RoHS conform
CERTIFICATIONS	IEC IEC/EN 60947
GLOBAL CATALOG	265743



**************************************	50.4
AMPERAGE RATING	50 A
VOLTAGE RATING	690 V - 690 V
CIRCUIT BREAKER FRAME TYPE	NZM2
10.10 TEMPERATURE RISE	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Meets the product standard's requirements.
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.
	be evaluated.

Resources	
BROCHURES	eaton-feerum-the-whole- grain-solution-success- story-en-us.pdf
	eaton-digital-nzm- brochure-br013003en-en- us.pdf
CATALOGS	eaton-digital-nzm-catalog- ca013003en-en-us.pdf
	eaton-circuit-breaker- characteristic-power- defense-mccb- characteristic-curve- 037.eps
CHARACTERISTIC CURVE	eaton-circuit-breaker-let- through-current-nzm- mccb-characteristic-curve- 005.eps
	eaton-circuit-breaker-nzm- mccb-characteristic-curve- 053.eps
	eaton-circuit-breaker-nzm- mccb-characteristic-curve- 052.eps
DECLARATIONS OF CONFORMITY	eaton-molded-case-circuit- breaker-declaration-of- conformity- eu250290en.pdf
DRAWINGS	eaton-circuit-breaker- switch-nzm-mccb- dimensions-017.eps
	eaton-circuit-breaker-nzm- mccb-dimensions-019.eps
ECAD MODEL	ETN.265743.edz
INSTALLATION VIDEOS	The new digital NZM Range
	Introduction of the new digital circuit breaker NZM
MCAD MODEL	DA-CS-nzm2 3p DA-CD-nzm2 3p
PEP ECO-PASSPORT	eaton-molded-case- switches-pep-eato-00207- v0101-en.pdf
TECHNICAL DATA SHEETS	eaton-nzm-technical- information-sheet

	standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	ls the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	ls the panel builder's responsibility.
10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH	ls the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	ls the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	ls the panel builder's responsibility.
INSOLATING WATERIAL	
POLLUTION DEGREE	3
	3 Built-in device fixed built- in technique Fixed
POLLUTION DEGREE	Built-in device fixed built- in technique
POLLUTION DEGREE MOUNTING METHOD	Built-in device fixed built- in technique Fixed Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to
POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT-	Built-in device fixed built- in technique Fixed Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78
POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT	Built-in device fixed built-in technique Fixed Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78
POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY	Built-in device fixed built-in technique Fixed Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 17.03 W A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the
POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY ISOLATION AMBIENT OPERATING	Built-in device fixed built-in technique Fixed Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 17.03 W A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts)
POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY ISOLATION AMBIENT OPERATING TEMPERATURE - MAX AMBIENT OPERATING	Built-in device fixed built-in technique Fixed Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 17.03 W A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts)
POLLUTION DEGREE	Built-in device fixed built-
POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT	Built-in device fixed built- in technique Fixed Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78
POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT	Built-in device fixed built-in technique Fixed Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78
POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT	Built-in device fixed built-in technique Fixed Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78
POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT	Built-in device fixed built-in technique Fixed Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 17.03 W A (IEC/EN 60947-2)
POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY	Built-in device fixed built-in technique Fixed Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 17.03 W A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and
POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY	Built-in device fixed built-in technique Fixed Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 17.03 W A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the
POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY	Built-in device fixed built-in technique Fixed Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 17.03 W A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts)
POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY ISOLATION AMBIENT OPERATING TEMPERATURE - MAX AMBIENT OPERATING	Built-in device fixed built-in technique Fixed Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 17.03 W A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts)
POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY ISOLATION AMBIENT OPERATING TEMPERATURE - MAX AMBIENT OPERATING TEMPERATURE - MIN AMBIENT STORAGE	Built-in device fixed built-in technique Fixed Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 17.03 W A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) 70 °C -25 °C
POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY ISOLATION AMBIENT OPERATING TEMPERATURE - MAX AMBIENT OPERATING TEMPERATURE - MIN AMBIENT STORAGE	Built-in device fixed built-in technique Fixed Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 17.03 W A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) 70 °C -25 °C

TEMPERATURE - MIN	
PROTECTION AGAINST DIRECT CONTACT	Finger and back-of-hand proof to VDE 0106 part 100
RATED INSULATION VOLTAGE (UI)	1000 V
RATED OPERATING POWER AT AC-3, 230 V	15 kW
RATED OPERATING POWER AT AC-3, 400 V	22 kW
SWITCH OFF TECHNIQUE	Magnetic
DEGREE OF PROTECTION	IP20 (basic degree of protection, in the operating controls area) IP20
DIRECTION OF INCOMING SUPPLY	As required
ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT	Screw connection
LIFESPAN, MECHANICAL	20000 operations
OVERVOLTAGE CATEGORY	Ш
RATED OPERATIONAL CURRENT	41 A (400 V AC-3)
DEGREE OF PROTECTION (IP), FRONT SIDE	IP66 (with door coupling rotary handle) IP40 (with insulating surround)
DEGREE OF PROTECTION (TERMINATIONS)	IP00 (terminations, phase isolator and strip terminal)
	IP10 (tunnel terminal)
NUMBER OF POLES	Three-pole
TERMINAL CAPACITY (COPPER STRIP)	Max. 10 segments of 24 mm x 0.8 mm at rear-side connection (punched) Min. 2 segements of 16 mm x 0.8 mm at rear-side connection (punched) Min. 2 segments of 9 mm x 0.8 mm at box terminal Max. 10 segments of 16 mm x 0.8 mm at box terminal Max. 8 segments of 24 mm x 1 mm (2x) at box terminal
LIFESPAN, ELECTRICAL	6500 operations at 400 V AC-3

	5000 operations at 690 V AC-3 7500 operations at 690 V AC-1 10000 operations at 415 V AC-1 6500 operations at 415 V AC-3 10000 operations at 400 V AC-1
FUNCTIONS	Short-circuit protection
ТҮРЕ	Circuit breaker

SPECIAL FEATURES

- Maximum back-up fuse, if the expected shortcircuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit breaking capacity lcn)
- Motor protection in conjunction with overload relay
- With short-circuit release
- Without overload release Ir
- IEC/EN 60947-4-1,
 IEC/EN 60947-2
- The circuit-breaker fulfills all requirements for AC-3 switching category.
- Rated current = rated uninterrupted current: 50 A

APPLICATION	Use in unearthed supply systems at 690 V
SHOCK RESISTANCE	20 g (half-sinusoidal shock 20 ms)
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	50 A
RATED SHORT-TIME WITHSTAND CURRENT (T = 0.3 S)	1.9 kA

RATED SHORT-TIME WITHSTAND CURRENT (T = 1 S)	1.9 kA
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MAX	700 A
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MIN	400 A
HANDLE TYPE	Rocker lever
INSTANTANEOUS CURRENT SETTING (II) - MAX	14 A
INSTANTANEOUS CURRENT SETTING (II) - MIN	8 A
NUMBER OF OPERATIONS PER HOUR - MAX	120
OVERLOAD CURRENT SETTING (IR) - MAX	0 A
OVERLOAD CURRENT SETTING (IR) - MIN	0 A
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 230 V, 50/60 HZ	150 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 400/415 V, 50/60 HZ	130 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 440 V, 50/60 HZ	130 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 525 V, 50/60 HZ	37.5 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 690 V, 50/60 HZ	5 kA
STANDARD TERMINALS	Screw terminal
OPTIONAL TERMINALS	Box terminal. Connection on rear. Tunnel terminal
RELEASE SYSTEM	Thermomagnetic release
SHORT-CIRCUIT TOTAL BREAKTIME	< 10 ms

TERMINAL CAPACITY (ALUMINUM SOLID CONDUCTOR/CABLE)	10 mm ² - 16 mm ² (2x) direct at switch rear-side connection 16 mm ² (1x) at tunnel terminal 10 mm ² - 16 mm ² (1x) direct at switch rear-side connection
TERMINAL CAPACITY (ALUMINUM STRANDED CONDUCTOR/CABLE)	25 mm ² - 50 mm ² (1x) direct at switch rear-side connection 25 mm ² - 185 mm ² (1x) at tunnel terminal 25 mm ² - 50 mm ² (2x) direct at switch rear-side connection
TERMINAL CAPACITY (CONTROL CABLE)	0.75 mm ² - 1.5 mm ² (2x) 0.75 mm ² - 2.5 mm ² (1x)
TERMINAL CAPACITY (COPPER BUSBAR)	M8 at rear-side screw connection Max. 24 mm x 8 mm direct at switch rear-side connection Min. 16 mm x 5 mm direct at switch rear-side connection
TERMINAL CAPACITY (COPPER SOLID CONDUCTOR/CABLE)	10 mm² - 16 mm² (1x) direct at switch rear-side connection 10 mm² - 16 mm² (1x) at box terminal 6 mm² - 16 mm² (2x) at box terminal 6 mm² - 16 mm² (2x) direct at switch rear-side connection 16 mm² (1x) at tunnel terminal
TERMINAL CAPACITY (COPPER STRANDED CONDUCTOR/CABLE)	25 mm² - 185 mm² (1x) at box terminal 25 mm² - 70 mm² (2x) at box terminal 25 mm² - 70 mm² (2x) direct at switch rear-side connection 25 mm² - 185 mm² (1x) direct at switch rear-side connection 25 mm² - 185 mm² (1x) at 1-hole tunnel terminal
RATED SHORT-CIRCUIT BREAKING CAPACITY ICU (IEC/EN 60947) AT 400/415 V, 50/60 HZ	130 kA

RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 400/415 V, 50/60 HZ	330 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 440 V, 50/60 HZ	286 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 525 V, 50/60 HZ	105 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 690 V, 50/60 HZ	40 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 240 V, 50/60 HZ	330 kA
RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT AUXILIARY CONTACTS	6000 V
RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT MAIN CONTACTS	8000 V
POWER LOSS	2.4 W

PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	
DATE:	



Eaton Corporation plc

Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









