Specifications



Photo is representative





Eaton 265829

Eaton Moeller series NZM - Molded Case Circuit Breaker. Circuit-breaker, 4p, 80A, H, frame 2, 4-A80

General specifications	
PRODUCT NAME	Eaton Moeller series NZM molded case circuit breaker thermo-magnetic
CATALOG NUMBER	265829
MODEL CODE	NZMH2-4-A80
EAN	4015082658298
PRODUCT LENGTH/DEPTH	149 mm
PRODUCT HEIGHT	184 mm
PRODUCT WIDTH	140 mm
PRODUCT WEIGHT	3 kg
COMPLIANCES	RoHS conform
CERTIFICATIONS	IEC/EN 60947 IEC
GLOBAL CATALOG	265829



Product specifications	S
AMPERAGE RATING	80 A
VOLTAGE RATING	690 V - 690 V
CIRCUIT BREAKER FRAME TYPE	NZM2
FEATURES	Protection unit Motor drive optional
10.10 TEMPERATURE RISE	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Meets the product standard's requirements.
	Does not apply, since the
10.2.5 LIFTING	entire switchgear needs to be evaluated.

Resources	
BROCHURES	eaton-feerum-the-whole- grain-solution-success- story-en-us.pdf
	eaton-nas-network-and- system-protection- brochure-br01301001zen- en-us.pdf
	eaton-digital-nzm- brochure-br013003en-en- us.pdf
CATALOGS	eaton-digital-nzm-catalog- ca013003en-en-us.pdf
CHARACTERISTIC CURVE	eaton-circuit-breaker- characteristic-power- defense-mccb- characteristic-curve- 037.eps
	eaton-circuit-breaker-nzm- mccb-characteristic-curve- 050.eps
	eaton-circuit-breaker-let- through-current-nzm- mccb-characteristic-curve- 005.eps
DECLARATIONS OF CONFORMITY	eaton-molded-case-circuit- breaker-declaration-of- conformity- eu250290en.pdf
DRAWINGS	eaton-circuit-breaker-nzm- mccb-dimensions-035.eps
	eaton-circuit-breaker- switch-nzm-mccb- dimensions-017.eps
ECAD MODEL	ETN.265829.edz
INSTALLATION INSTRUCTIONS	eaton-circuit-breakers- basic-device-nzm2- il01206006z.pdf
INSTALLATION VIDEOS	The new digital NZM Range
	Introduction of the new digital circuit breaker NZM
MCAD MODEL	DA-CD-nzm2_4p
PEP ECO-PASSPORT	eaton-molded-case- switches-pep-eato-00207- v0101-en.pdf

10.2.7 INSCRIPTIONS 10.3 DEGREE OF PROTECTION OF ASSEMBLIES 10.4 CLEARANCES AND CREEPAGE DISTANCES 10.5 PROTECTION AGAINST ELECTRIC Entire switchgear needs to be evaluated. 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS 10.7 INTERNAL ELECTRIC IS THE PROPECTION SADD CONNECTIONS 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS FREQUENCY ELECTRIC STRENGTH 10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH 10.9.3 IMPULSE IS the panel builder's responsibility. 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL POLLUTION DEGREE 3 MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT UTILIZATION CATEGORY AMBIENT OPERATING TEMPERATURE - MAX AMBIENT OPERATING - 2.5 °C		
10.3 DEGREE OF PROTECTION OF ASSEMBLIES 10.4 CLEARANCES AND CREEPAGE DISTANCES 10.5 PROTECTION AGAINST ELECTRIC SHOCK 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS 10.7 INTERNAL ELECTRICAND CONNECTIONS 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS 10.9.2 POWERFREQUENCY ELECTRIC STRENGTH 10.9.3 IMPULSE WITHSTAND VOLTAGE 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL POLLUTION DEGREE AMOUNTING METHOD CLIMATIC PROOFING ISOLATION CATEGORY LISUATION CATEGORY AMBIENT OPERATING TEMPERATURE - MAX DOes not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility.		be evaluated.
PROTECTION OF ASSEMBLIES 10.4 CLEARANCES AND CREEPAGE DISTANCES 10.5 PROTECTION AGAINST ELECTRIC SHOCK 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS 10.8 CONNECTIONS 10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH 10.9.3 IMPULSE WITHSTAND VOLTAGE 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT UTILIZATION CATEGORY AMBIENT OPERATING TEMPERATURE - MAX MOBIENT OPERATING TEMPERATURE - MAX MESSIMBLES SAND AGE OF COMPERATURE - MAX MESSIMBLES WITHSTAND VOLTAGE POLICUITS AND CONTROL OF THE PROOFICE	10.2.7 INSCRIPTIONS	
TO.5 PROTECTION AGAINST ELECTRIC SHOCK 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS 10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH 10.9.3 IMPULSE WITHSTAND VOLTAGE 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY AMBIENT OPERATING TEMPERATURE - MAX POCE TOS Not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Damp heat, cyclic, to IEC 60068-2-30 Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) AMBIENT OPERATING TEMPERATURE - MAX	PROTECTION OF	entire switchgear needs to
AGAINST ELECTRIC SHOCK 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS 10.8 CONNECTIONS 10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH 10.9.3 IMPULSE WITHSTAND VOLTAGE 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL POLLUTION DEGREE AMOUNTING METHOD CLIMATIC PROOFING CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY AMBIENT OPERATING TEMPERATURE - MAX POC AMBIENT OPERATING TEMPERATURE - MAX PO C Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder'		·
SWITCHING DEVICES AND COMPONENTS 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS 10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH 10.9.3 IMPULSE Is the panel builder's responsibility. 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT UTILIZATION CATEGORY AMBIENT OPERATING TISM TO SWITCH TO SWITC	AGAINST ELECTRIC	entire switchgear needs to
ELECTRICAL CIRCUITS AND CONNECTIONS 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS 10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH 10.9.3 IMPULSE Is the panel builder's responsibility. 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING CLIMATIC PROOFING CLIMATIC PROOFING Damp heat, cyclic, to IEC 60068-2-78 EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT UTILIZATION CATEGORY A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) AMBIENT OPERATING TEMPERATURE - MAX TEMPERATURE - MAX TEMPERATURE - MAX Is the panel builder's responsibility. Is the panel builde	SWITCHING DEVICES AND	entire switchgear needs to
TEXTERNAL CONDUCTORS 10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH 10.9.3 IMPULSE Is the panel builder's responsibility. 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING CLIMATIC PROOFING CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT UTILIZATION CATEGORY IS the panel builder's responsibility. Is the panel builder's responsible to the panel builder's responsibility. Is the panel builder's responsibi	ELECTRICAL CIRCUITS	•
Is the panel builder's responsibility.		·
WITHSTAND VOLTAGE responsibility. 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL Is the panel builder's responsibility. POLLUTION DEGREE 3 MOUNTING METHOD Fixed DIN rail (top hat rail) mounting optional Built-in device fixed built-in technique CLIMATIC PROOFING Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT 20.54 W UTILIZATION CATEGORY A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) 300 V AC (between the auxiliary contacts) AMBIENT OPERATING TEMPERATURE - MAX 70 °C	FREQUENCY ELECTRIC	
Is the panel builder's responsibility. POLLUTION DEGREE 3 Fixed DIN rail (top hat rail) mounting optional Built-in device fixed built-in technique CLIMATIC PROOFING Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT UTILIZATION CATEGORY A (IEC/EN 60947-2) SOO V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) AMBIENT OPERATING TEMPERATURE - MAX ISOLATION 70 °C		•
Fixed DIN rail (top hat rail) mounting optional Built-in device fixed built- in technique Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) AMBIENT OPERATING TEMPERATURE - MAX Fixed DIN rail (top hat rail) mounting optional Built-in device fixed built- in technique 20.54 W Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT A (IEC/EN 60947-2) 500 V AC (between the auxiliary contacts)	ENCLOSURES MADE OF	· · · · · · · · · · · · · · · · · · ·
MOUNTING METHOD DIN rail (top hat rail) mounting optional Built-in device fixed built- in technique Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) AMBIENT OPERATING TEMPERATURE - MAX TO °C	POLLUTION DEGREE	3
CLIMATIC PROOFING 60068-2-30 Damp heat, constant, to IEC 60068-2-78 EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) AMBIENT OPERATING TEMPERATURE - MAX 70 °C	MOUNTING METHOD	DIN rail (top hat rail) mounting optional Built-in device fixed built-
DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY A (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) AMBIENT OPERATING TEMPERATURE - MAX 70 °C	CLIMATIC PROOFING	60068-2-30 Damp heat, constant, to
ISOLATION ISOLATION ISOLATION Solution Sol	DISSIPATION, CURRENT-	20.54 W
auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) AMBIENT OPERATING TEMPERATURE - MAX 70 °C	UTILIZATION CATEGORY	A (IEC/EN 60947-2)
TEMPERATURE - MAX	ISOLATION	auxiliary contacts and main contacts) 300 V AC (between the
AMBIENT OPERATING -25 °C		70 °C
	444015415 0050451416	25 °C

TECHNICAL DATA SHEETS

<u>eaton-nzm-technical-information-sheet</u>

TEMPERATURE - MIN	
AMBIENT STORAGE TEMPERATURE - MAX	70 °C
AMBIENT STORAGE TEMPERATURE - MIN	-40 °C
NUMBER OF AUXILIARY CONTACTS (CHANGE- OVER CONTACTS)	0
NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)	0
NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)	0
PROTECTION AGAINST DIRECT CONTACT	Finger and back-of-hand proof to DIN EN 50274/VDE 0106 part 110
DEGREE OF PROTECTION	IP20 IP20 (basic degree of protection, in the operating controls area)
DIRECTION OF INCOMING SUPPLY	As required
ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT	Screw connection
CURRENT RATING OF NEUTRAL CONDUCTOR	200% of phase conductor
LIFESPAN, MECHANICAL	20000 operations
OVERVOLTAGE CATEGORY	Ш
DEGREE OF PROTECTION (IP), FRONT SIDE	IP40 (with insulating surround) IP66 (with door coupling rotary handle)
DEGREE OF PROTECTION (TERMINATIONS)	IP00 (terminations, phase isolator and strip terminal)
	IP10 (tunnel terminal)
NUMBER OF POLES	Four-pole
TERMINAL CAPACITY (COPPER STRIP)	Max. 8 segments of 24 mm x 1 mm (2x) at box terminal Min. 2 segements of 16 mm x 0.8 mm at rear-side connection (punched) Max. 10 segments of 24 mm x 0.8 mm at rear-side connection (punched) Max. 10 segments of 16

	mm x 0.8 mm at box terminal Min. 2 segments of 9 mm x 0.8 mm at box terminal
LIFESPAN, ELECTRICAL	7500 operations at 690 V AC-1 6500 operations at 400 V AC-3 10000 operations at 400 V AC-1 5000 operations at 690 V AC-3 6500 operations at 415 V AC-3 10000 operations at 415 V AC-1
FUNCTIONS	System and cable protection
ТҮРЕ	Circuit breaker
SPECIAL FEATURES	 Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit breaking capacity lcn) Rated current = rated uninterrupted current: 80 A Set value in neutral conductor is synchronous with set value Ir of main pole.
APPLICATION	Use in unearthed supply systems at 690 V
SHOCK RESISTANCE	20 g (half-sinusoidal shock 20 ms)
POSITION OF CONNECTION FOR MAIN CURRENT CIRCUIT	Front side
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	80 A
DOWED LOSS	20.5.14

20.5 W

POWER LOSS

DELEACE OVERTICAL	
RELEASE SYSTEM	Thermomagnetic release
SHORT-CIRCUIT TOTAL BREAKTIME	< 10 ms
RATED SHORT-TIME WITHSTAND CURRENT (T = 0.3 S)	1.9 kA
RATED SHORT-TIME WITHSTAND CURRENT (T = 1 S)	1.9 kA
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MAX	800 A
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MIN	480 A
TERMINAL CAPACITY (CONTROL CABLE)	0.75 mm ² - 1.5 mm ² (2x) 0.75 mm ² - 2.5 mm ² (1x)
TERMINAL CAPACITY (COPPER BUSBAR)	M8 at rear-side screw connection Max. 24 mm x 8 mm direct at switch rear-side connection Min. 16 mm x 5 mm direct at switch rear-side connection
TERMINAL CAPACITY (COPPER SOLID CONDUCTOR/CABLE)	6 mm² - 16 mm² (2x) direct at switch rear-side connection 16 mm² (1x) at tunnel terminal 10 mm² - 16 mm² (1x) at box terminal 6 mm² - 16 mm² (2x) at box terminal 10 mm² - 16 mm² (1x) direct at switch rear-side connection
TERMINAL CAPACITY (ALUMINUM SOLID CONDUCTOR/CABLE)	16 mm² (1x) at tunnel terminal 10 mm² - 16 mm² (1x) direct at switch rear-side connection 10 mm² - 16 mm² (2x) direct at switch rear-side connection
TERMINAL CAPACITY (COPPER STRANDED CONDUCTOR/CABLE)	25 mm² - 185 mm² (1x) direct at switch rear-side connection 25 mm² - 70 mm² (2x) at box terminal 25 mm² - 185 mm² (1x) at box terminal 25 mm² - 70 mm² (2x)

	direct at switch rear-side connection 25 mm ² - 185 mm ² (1x) at 1-hole tunnel terminal
TERMINAL CAPACITY (ALUMINUM STRANDED CONDUCTOR/CABLE)	25 mm² - 50 mm² (1x) direct at switch rear-side connection 25 mm² - 185 mm² (1x) at tunnel terminal 25 mm² - 50 mm² (2x) direct at switch rear-side connection
HANDLE TYPE	Rocker lever
SHORT DELAY CURRENT SETTING (ISD) - MAX	0 A
SHORT DELAY CURRENT SETTING (ISD) - MIN	0 A
INSTANTANEOUS CURRENT SETTING (II) - MAX	10 A
INSTANTANEOUS CURRENT SETTING (II) - MIN	6 A
NUMBER OF OPERATIONS PER HOUR - MAX	120
OVERLOAD CURRENT SETTING (IR) - MAX	80 A
OVERLOAD CURRENT SETTING (IR) - MIN	63 A
OVERLOAD CURRENT SETTING (IR)	63 A - 80 A
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 230 V, 50/60 HZ	150 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 400/415 V, 50/60 HZ	150 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 440 V, 50/60 HZ	130 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 525 V, 50/60 HZ	37.5 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS	5 kA

(IEC/EN 60947) AT 690 V, 50/60 HZ	
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 400/415 V, 50/60 HZ	330 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 440 V, 50/60 HZ	286 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 525 V, 50/60 HZ	105 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 690 V, 50/60 HZ	40 kA
STANDARD TERMINALS	Screw terminal
OPTIONAL TERMINALS	Box terminal. Connection on rear. Tunnel terminal
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 240 V, 50/60 HZ	330 kA
RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT AUXILIARY CONTACTS	6000 V
RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT MAIN CONTACTS	8000 V
RATED INSULATION VOLTAGE (UI)	1000 V AC

PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	
DATE:	



Eaton Corporation plc

Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









