

# Specifications



Photo is representative



## Eaton 271428

Eaton Moeller series NZM - Molded Case Circuit Breaker. NZM2, 3 pole, Icu 400/415 V 50 Hz( Icu ): 36 kA, 160 A, Fixed, Screw connection, IEC

### General specifications

|                             |                                      |
|-----------------------------|--------------------------------------|
| <b>PRODUCT NAME</b>         | Eaton Moeller series NZM             |
|                             | molded case circuit breaker magnetic |
| <b>CATALOG NUMBER</b>       | 271428                               |
| <b>MODEL CODE</b>           | NZMC2-S160                           |
| <b>EAN</b>                  | 4015082714284                        |
| <b>PRODUCT LENGTH/DEPTH</b> | 149 mm                               |
| <b>PRODUCT HEIGHT</b>       | 184 mm                               |
| <b>PRODUCT WIDTH</b>        | 105 mm                               |
| <b>PRODUCT WEIGHT</b>       | 2.345 kg                             |
| <b>COMPLIANCES</b>          | RoHS conform                         |
| <b>CERTIFICATIONS</b>       | IEC/EN 60947                         |
|                             | IEC                                  |



Powering Business Worldwide

## Product specifications

|   |  |
|---|--|
| <b>AMPERAGE RATING</b>  | 160 A  |
| <b>VOLTAGE RATING</b>   | 690 V - 690 V  |
| <b>CIRCUIT BREAKER FRAME TYPE</b>   | NZM2   |
| <b>10.10 TEMPERATURE RISE</b>   | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| <b>10.11 SHORT-CIRCUIT RATING</b>   | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| <b>10.12 ELECTROMAGNETIC COMPATIBILITY</b>  | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| <b>10.13 MECHANICAL FUNCTION</b>  | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |
| <b>10.2.2 CORROSION RESISTANCE</b>  | Meets the product standard's requirements.   |
| <b>10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES</b>                         | Meets the product standard's requirements.   |
| <b>10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT</b>       | Meets the product standard's requirements.   |
| <b>10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS</b> | Meets the product standard's requirements.   |
| <b>10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION</b>                                 | Meets the product standard's requirements.   |
| <b>10.2.5 LIFTING</b>   | Does not apply, since the entire switchgear needs to be evaluated.   |
| <b>10.2.6 MECHANICAL IMPACT</b>   | Does not apply, since the entire switchgear needs to be evaluated.   |
| <b>10.2.7 INSCRIPTIONS</b>  | Meets the product  |

## Resources

|                                   |   |
|-----------------------------------|---|
| <b>BROCHURES</b>                  | <a href="#">eaton-digital-nzm-brochure-br013003en-en-us.pdf</a><br><a href="#">eaton-feerum-the-whole-grain-solution-success-story-en-us.pdf</a>  |
| <b>CATALOGUES</b>                 | <a href="#">eaton-digital-nzm-catalog-ca013003en-en-us.pdf</a>  |
| <b>DECLARATIONS OF CONFORMITY</b> | <a href="#">eaton-molded-case-circuit-breaker-declaration-of-conformity-eu250290en.pdf</a>  |
| <b>DRAWINGS</b>                   | <a href="#">eaton-circuit-breaker-switch-nzm-mccb-dimensions-017.eps</a><br><a href="#">eaton-circuit-breaker-nzm-mccb-dimensions-019.eps</a><br><a href="#">eaton-circuit-breaker-switch-nzm-mccb-3d-drawing.eps</a> |
| <b>ECAD MODEL</b>                 | <a href="#">ETN.271428.edz</a>  |
| <b>INSTALLATION VIDEOS</b>        | <a href="#">The new digital NZM Range</a><br><a href="#">Introduction of the new digital circuit breaker NZM</a>  |
| <b>MCAD MODEL</b>                 | <a href="#">DA-CD-nzm2_3p</a><br><a href="#">DA-CS-nzm2_3p</a>  |
| <b>PEP ECO-PASSPORT</b>           | <a href="#">eaton-molded-case-switches-pep-eato-00207-v0101-en.pdf</a>  |
| <b>TECHNICAL DATA SHEETS</b>      | <a href="#">eaton-nzm-technical-information-sheet</a>   |

|   |  |
|---|--|
|   | standard's requirements.   |
| <b>10.3 DEGREE OF PROTECTION OF ASSEMBLIES</b>                  | Does not apply, since the entire switchgear needs to be evaluated.                                   |
| <b>10.4 CLEARANCES AND CREEPAGE DISTANCES</b>                   | Meets the product standard's requirements.   |
| <b>10.5 PROTECTION AGAINST ELECTRIC SHOCK</b>                   | Does not apply, since the entire switchgear needs to be evaluated.                                   |
| <b>10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS</b>   | Does not apply, since the entire switchgear needs to be evaluated.                                   |
| <b>10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS</b>        | Is the panel builder's responsibility.   |
| <b>10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS</b>                 | Is the panel builder's responsibility.   |
| <b>10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH</b>                 | Is the panel builder's responsibility.   |
| <b>10.9.3 IMPULSE WITHSTAND VOLTAGE</b>                         | Is the panel builder's responsibility.   |
| <b>10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL</b> | Is the panel builder's responsibility.   |
| <b>POLLUTION DEGREE</b>   | 3  |
| <b>MOUNTING METHOD</b>  | DIN rail (top hat rail)<br>mounting optional<br>Built-in device fixed built-in technique<br>Fixed    |
| <b>CLIMATIC PROOFING</b>  | Damp heat, constant, to IEC 60068-2-78<br>Damp heat, cyclic, to IEC 60068-2-30                       |
| <b>EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT</b>            | 38.4 W   |
| <b>UTILIZATION CATEGORY</b>                                     | A (IEC/EN 60947-2)   |
| <b>ISOLATION</b>  | 500 V AC (between auxiliary contacts and main contacts)<br>300 V AC (between the auxiliary contacts) |
| <b>DEGREE OF PROTECTION</b>                                     | IP20 (basic degree of protection, in the operating controls area)<br>IP20                            |
| <b>DIRECTION OF INCOMING SUPPLY</b>                             | As required  |

|   |  |
|---|--|
| <b>ELECTRICAL<br/>CONNECTION TYPE OF<br/>MAIN CIRCUIT</b> | Screw connection   |
| <b>LIFESPAN, MECHANICAL</b>                               | 20000 operations   |
| <b>OVERVOLTAGE<br/>CATEGORY</b>                           | III  |
| <b>RATED OPERATIONAL<br/>CURRENT</b>                      | 134 A (400 V AC-3, making<br>and breaking capacity)  |
| <b>DEGREE OF PROTECTION<br/>(IP), FRONT SIDE</b>          | IP40 (with insulating<br>surround)<br>IP66 (with door coupling<br>rotary handle)   |
| <b>DEGREE OF PROTECTION<br/>(TERMINATIONS)</b>            | IP00 (terminations, phase<br>isolator and strip terminal)<br><br>IP10 (tunnel terminal)  |
| <b>NUMBER OF POLES</b>                                    | Three-pole   |
| <b>TERMINAL CAPACITY<br/>(COPPER STRIP)</b>               | Max. 10 segments of 24<br>mm x 0.8 mm at rear-side<br>connection (punched)<br>Max. 8 segments of 24<br>mm x 1 mm (2x) at box<br>terminal<br>Min. 2 segments of 16<br>mm x 0.8 mm at rear-side<br>connection (punched)<br>Max. 10 segments of 16<br>mm x 0.8 mm at box<br>terminal<br>Min. 2 segments of 9 mm<br>x 0.8 mm at box terminal |
| <b>LIFESPAN, ELECTRICAL</b>                               | 10000 operations at 400 V<br>AC-1<br>5000 operations at 690 V<br>AC-1<br>7500 operations at 415 V<br>AC-1  |
| <b>FUNCTIONS</b>  | Short-circuit protection   |
| <b>TYPE</b>   | Circuit breaker  |
| <b>SPECIAL FEATURES</b>                                   | <ul style="list-style-type: none"> <li>Maximum back-up<br/>fuse, if the<br/>expected short-<br/>circuit currents at<br/>the installation<br/>location exceed the<br/>switching capacity<br/>of the circuit<br/>breaker (Rated<br/>short-circuit<br/>breaking capacity<br/>I<sub>cn</sub>)</li> </ul>                                     |

|  |  |
|--|--|
|  | <ul style="list-style-type: none"> <li>• Motor protection in conjunction with overload relay</li> <li>• With short-circuit release</li> <li>• Without overload release <math>I_r</math></li> <li>• IEC/EN 60947-4-1, IEC/EN 60947-2</li> <li>• The circuit-breaker fulfills all requirements for AC-3 switching category.</li> <li>• Rated current = rated uninterrupted current: 160 A</li> </ul> |
|--|--|

|  |  |
|--|--|
| <b>APPLICATION</b>   | Use in unearthed supply systems at 690 V   |
| <b>SHOCK RESISTANCE</b>                                    | 20 g (half-sinusoidal shock 20 ms)   |
| <b>RELEASE SYSTEM</b>                                      | Thermomagnetic release   |
| <b>SHORT-CIRCUIT TOTAL BREAKTIME</b>                       | < 10 ms  |
| <b>TERMINAL CAPACITY (CONTROL CABLE)</b>                   | 0.75 mm <sup>2</sup> - 1.5 mm <sup>2</sup> (2x)<br>0.75 mm <sup>2</sup> - 2.5 mm <sup>2</sup> (1x)   |
| <b>TERMINAL CAPACITY (COPPER BUSBAR)</b>                   | Max. 24 mm x 8 mm direct at switch rear-side connection<br>M8 at rear-side screw connection<br>Min. 16 mm x 5 mm direct at switch rear-side connection   |
| <b>TERMINAL CAPACITY (COPPER SOLID CONDUCTOR/CABLE)</b>    | 6 mm <sup>2</sup> - 16 mm <sup>2</sup> (2x) at box terminal<br>16 mm <sup>2</sup> (1x) at tunnel terminal<br>6 mm <sup>2</sup> - 16 mm <sup>2</sup> (2x) direct at switch rear-side connection<br>10 mm <sup>2</sup> - 16 mm <sup>2</sup> (1x) direct at switch rear-side connection<br>10 mm <sup>2</sup> - 16 mm <sup>2</sup> (1x) at box terminal |
| <b>TERMINAL CAPACITY (COPPER STRANDED CONDUCTOR/CABLE)</b> | 25 mm <sup>2</sup> - 70 mm <sup>2</sup> (2x) at box terminal<br>25 mm <sup>2</sup> - 70 mm <sup>2</sup> (2x) direct at switch rear-side connection   |

25 mm<sup>2</sup> - 185 mm<sup>2</sup> (1x) at  
1-hole tunnel terminal  
25 mm<sup>2</sup> - 185 mm<sup>2</sup> (1x) at  
box terminal  
25 mm<sup>2</sup> - 185 mm<sup>2</sup> (1x)  
direct at switch rear-side  
connection

---

**PROJECT NAME:**

---

**PROJECT NUMBER:**

---

**PREPARED BY:**

---

**DATE:**

---



**Eaton Corporation plc**

Eaton House  
30 Pembroke Road  
Dublin 4, Ireland  
Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.

