# Specifications

### Photo is representative

# Eaton 276884

Eaton Moeller® series DILM Contactor, 3 pole, 380 V 400 V 5.5 kW, 1 NC, 220 V DC, DC operation, Screw terminals

General specification	S
PRODUCT NAME	Eaton Moeller® series DILM contactor
CATALOG NUMBER	276884
MODEL CODE	DILM12-01(220VDC)
EAN	4015082768843
PRODUCT LENGTH/DEPTH	75 mm
PRODUCT HEIGHT	68 mm
PRODUCT WIDTH	45 mm
PRODUCT WEIGHT	0.296 kg
COMPLIANCES	CE Marked
CERTIFICATIONS	UL 508 VDE 0660 UL CSA CE UL Category Control No.: NLDX CSA File No.: 012528 IEC/EN 60947 IEC/EN 60947-4-1 UL File No.: E29096 CSA Class No.: 2411-03, 3211-04 CSA-C22.2 No. 14-05
CATALOG NOTES	Contacts according to EN 50012
GLOBAL CATALOG	276884



# Product specifications

ELECTRICAL CONNECTION TYPE FOR AUXILIARY- AND CONTROL-CURRENT CIRCUIT	Screw connection
AMPERAGE RATING	12A
NUMBER OF POLES	Three-pole
VOLTAGE RATING	220 Vdc
10.10 TEMPERATURE RISE	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Meets the product standard's requirements.
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to

be evaluated.

# Resources

CATALOGS

#### SmartWire-DT Catalog

Product Range Catalog Switching and protecting motors

eaton-product-overviewfor-machinery-catalogueca08103003zen-en-us.pdf

eaton-contactorscomponent-dilmcharacteristic-curve-003.eps

eaton-contactors-shorttime-loading-dilmcharacteristic-curve.eps

eaton-contactors-switchdilm-characteristiccurve.eps

eaton-contactors-switchdilm-characteristic-curve-002.eps

DA-DC-00004810.pdf

DA-DC-00004792.pdf

### DECLARATIONS OF CONFORMITY

IFORMITY

CHARACTERISTIC CURVE

eaton-contactors-moduledilm-dimensions-002.eps

eaton-contactors-framedilm-dimensions.eps

eaton-contactors-moduledilm-dimensions.eps

DRAWINGS

eaton-contactorsmounting-dilmdimensions-002.eps

eaton-contactorsmounting-dilmdimensions.eps

eaton-general-ie-readydilm-contactorstandards.eps

eaton-contactors-dilm-3ddrawing-007.eps

ECAD MODEL ETN.276884.edz

INSTALLATION INSTRUCTIONS eaton-contactors-diladilm7-15-dilmp20il03407013z.pdf

10.2.6 MECHANICALDoes not apply, since the entire switchgear needs to be evaluated.10.2.7 INSCRIPTIONSMeets the product standard's requirements.10.3 DEGREE OF PROTECTION OF ASSEMBLIESDoes not apply, since the entire switchgear needs to be evaluated.10.4 CLEARANCES AND CREEPAGE DISTANCESMeets the product standard's requirements.10.5 PROTECTION AGAINST ELECTRIC SHOCKDoes not apply, since the entire switchgear needs to be evaluated.10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTSDoes not apply, since the entire switchgear needs to be evaluated.10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONSIs the panel builder's responsibility.10.8 CONNECTIONS FOR EXTERNAL CONDUCTORSIs the panel builder's responsibility.10.9.1 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALMirror contact varistor suppressor circuit10.9.4 TESTING OF ENCLOSURES MADE OF SULATING FREQUENCYDOU mechanical Operations/h (DC operated)000 mechanical Operations/h (DC operated)Mon01.101 DEGREE3CONNECTION TO SMARTWIRE-DTNoNRateD IMPULSE with HSTAND VOLTAGESouro VACUTILIZATION CATEGORYAC-4: Normal AC induction motors: starting, plugging, reversing, inching and heat, cyclic, to lECC goods-2-30DONCATED IMPULSE SUITHSTAND VOLTAGESouro VACUTILIZATION CATEGORYAC-4: Normal AC induction motors: starting, switch off during running <th></th> <th></th>		
10.2.7 INSCRIPTIONSstandard's requirements.10.3 DEGREE OF PROTECTION OF ASSEMBLIESDoes not apply, since the entire switchgear needs to be evaluated.10.4 CLEARANCES AND CREEPAGE DISTANCESMeets the product standard's requirements.10.5 PROTECTION AGAINST ELECTRIC SHOCKDoes not apply, since the entire switchgear needs to be evaluated.10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTSDoes not apply, since the entire switchgear needs to be evaluated.10.7 INTERNAL ELECTRICA CIRCUITS AND CONNECTIONS FOR EXTERNAL CONDUCTORSIs the panel builder's responsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALSi the panel builder's responsibility.0PERATING FREQUENCY OPERATING FREQUENCY9000 mechanical Operations/h (DC operated)0PULUTION DEGREE3CONNECTION TO SMARTWIRE-DTNoRATED IMPULSE WITHSTAND VOLTAGESo00 V ACUTILIZATION CATEGORNAC-4: Normal AC induction motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, switch off		entire switchgear needs to
PROTECTION OF ASSEMBLIESentire suitchgear needs to be evaluated.10.4 CLEARANCES AND CREEPAGE DISTANCESMeets the product standard's requirements.10.5 PROTECTION AGAINST ELECTRIC SHOCKDoes not apply, since the entire switchgear needs to be evaluated.10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTSDoes not apply, since the entire switchgear needs to be evaluated.10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS FOR EXTERNAL CONDUCTORSIs the panel builder's responsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALShe panel builder's responsibility.0PERATING FREQUENCY CONNECTION TO SMARTWIRE-DTDom pheat, constant, to IEC 60068-2-78 Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30CONNECTION TO SMARTWIRE-DTNoRATED IMPULSE WITHSTAND VOLTAGES000 V ACUTILIZATION CATEGORYAC-4: Normal AC induction motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, switch off	10.2.7 INSCRIPTIONS	
CREEPAGE DISTANCESstandard's requirements.10.5 PROTECTION AGAINST ELECTRIC SHOCKDoes not apply, since the entire switchgear needs to be evaluated.10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTSDoes not apply, since the entire switchgear needs to be evaluated.10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONSIs the panel builder's responsibility.10.8 CONNECTIONS FOR EXTERNAL CONDUCTORSIs the panel builder's responsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALMirror contact Varistor suppressor circuit0000 mechanical Operations/h (DC operated)9000 mechanical Operations/h (DC operations/h (DC operated)POLLUTION DEGREE3CONNECTION TO SMARTWIRE-DTNoRATED IMPULSE WITHSTAND VOLTAGE8000 V ACUTILIZATION CATEGORY VITHSTAND VOLTAGEAC-4: Normal AC induction motors: starting, plugging, reversing, inching	PROTECTION OF	entire switchgear needs to
AGAINST ELECTRIC SHOCKentire switchgear needs to be evaluated.10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTSDoes not apply, since the entire switchgear needs to be evaluated.10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONSIs the panel builder's responsibility.10.8 CONNECTIONS FOR EXTERNAL CONDUCTORSIs the panel builder's responsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALSthe panel builder's responsibility.0PERATING FREQUENCY ELUTION DEGREE9000 mechanical Operations/h (DC operated)POLLUTION DEGREE3CONNECTION TO SMARTWIRE-DTDamp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30CONNECTION TO SMARTWIRE-DT8000 V ACUTILIZATION CATEGORYAC-4: Normal AC induction motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, plugging, seversing, inching AC-3: Normal A		
SWITCHING DEVICES AND COMPONENTSentire switchgear needs to be evaluated.10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONSIs the panel builder's responsibility.10.8 CONNECTIONS FOR EXTERNAL CONDUCTORIs the panel builder's responsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALIs the panel builder's responsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALMirror contact Varistor suppressor circuit0PERATING FREQUENCY9000 mechanical Operations/h (DC operated)0PERATING FREQUENCYDamp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30CONNECTION TO SMARTWIRE-DTNoRATED IMPULSE WITHSTAND VOLTAGE8000 V ACUTILIZATION CATEGORYAC-4: Normal AC induction motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, switch off	AGAINST ELECTRIC	entire switchgear needs to
ELECTRICAL CIRCUITS AND CONNECTIONSIs the panel builder's responsibility.10.8 CONNECTIONS FOR EXTERNAL CONDUCTORSIs the panel builder's responsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALIs the panel builder's responsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALMirror contact Varistor suppressor circuit0PERATING FREQUENCY9000 mechanical Operations/h (DC operated)0PERATING FREQUENCYDamp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30CONNECTION TO SMARTWIRE-DTNoRATED IMPULSE WITHSTAND VOLTAGE8000 V ACUTILLIZATION CATEGORYAC-4: Normal AC induction motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, switch off	SWITCHING DEVICES AND	entire switchgear needs to
EXTERNAL CONDUCTORSresponsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALIs the panel builder's responsibility.fTTED WITH:Mirror contact Varistor suppressor circuitOPERATING FREQUENCY9000 mechanical Operations/h (DC operated)POLLUTION DEGREE3CLIMATIC PROOFINGDamp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30CONNECTION TO SMARTWIRE-DTNoRATED IMPULSE WITHSTAND VOLTAGE (UIMP)S000 V ACUTILLIZATION CATEGORYAC-4: Normal AC induction motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, switch off	ELECTRICAL CIRCUITS	•
FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALIs the panel builder's responsibility.FITTED WITH:Mirror contact Varistor suppressor circuitOPERATING FREQUENCY9000 mechanical Operations/h (DC operated)POLLUTION DEGREE3CONNECTION TO SMARTWIRE-DTDamp heat, constant, to IEC 60068-2-30CONNECTION TO SMARTWIRE-DTNoRATED IMPULSE WITHSTAND VOLTAGE8000 V AC motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, switch off		
WITHSTAND VOLTAGEresponsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALIs the panel builder's responsibility.FITTED WITH:Mirror contact Varistor suppressor circuitOPERATING FREQUENCY9000 mechanical Operations/h (DC operated)POLLUTION DEGREE3CLIMATIC PROOFINGDamp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30CONNECTION TO SMARTWIRE-DTNoRATED IMPULSE WITHSTAND VOLTAGE (UIMP)8000 V ACUTILIZATION CATEGORYAC-4: Normal AC induction motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, switch off	FREQUENCY ELECTRIC	•
ENCLOSURES MADE OF INSULATING MATERIALIs the panel builder's responsibility.FITTED WITH:Mirror contact Varistor suppressor circuitOPERATING FREQUENCY9000 mechanical Operations/h (DC operated)POLLUTION DEGREE3CLIMATIC PROOFINGDamp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30CONNECTION TO SMARTWIRE-DTNoRATED IMPULSE WITHSTAND VOLTAGE (UIMP)8000 V ACUTILIZATION CATEGORYAC-4: Normal AC induction motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, switch off		
FITTED WITH:Nario of suppressor circuitVaristor suppressor circuitVaristor suppressor circuitPOELUTION DEGREE9000 mechanical Operations/h (DC operated)POLLUTION DEGREE3CLIMATIC PROOFINGDamp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30CONNECTION TO SMARTWIRE-DTNoRATED IMPULSE WITHSTAND VOLTAGE (UIMP)8000 V ACUTILIZATION CATEGORYAC-4: Normal AC induction motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, switch off	ENCLOSURES MADE OF	•
OPERATING FREQUENCYOperations/h (DC operated)POLLUTION DEGREE3CLIMATIC PROOFINGDamp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30CONNECTION TO SMARTWIRE-DTNoRATED IMPULSE WITHSTAND VOLTAGE (UIMP)& 8000 V ACUTILIZATION CATEGORYAC-4: Normal AC induction motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, switch off	FITTED WITH:	
CLIMATIC PROOFINGDamp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30CONNECTION TO SMARTWIRE-DTNoRATED IMPULSE WITHSTAND VOLTAGE (UIMP)8000 V ACDurilization categoryAC-4: Normal AC induction motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, switch off	OPERATING FREQUENCY	Operations/h (DC
CLIMATIC PROOFINGIEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30CONNECTION TO SMARTWIRE-DTNoRATED IMPULSE WITHSTAND VOLTAGE (UIMP)8000 V ACDurilization categoryAC-4: Normal AC induction motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, switch off	POLLUTION DEGREE	3
SMARTWIRE-DTNoRATED IMPULSE WITHSTAND VOLTAGE (UIMP)8000 V ACUTILIZATION CATEGORYAC-4: Normal AC induction motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, switch off	CLIMATIC PROOFING	IEC 60068-2-78 Damp heat, cyclic, to IEC
WITHSTAND VOLTAGE (UIMP)8000 V ACUTILIZATION CATEGORYAC-4: Normal AC induction motors: starting, plugging, reversing, inching 		No
UTILIZATION CATEGORY Motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, switch off	WITHSTAND VOLTAGE	8000 V AC
	UTILIZATION CATEGORY	motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, switch off

<u>WIN-WIN with push-in</u> <u>technology</u>
DA-CD-dil m7 15
DA-CS-dil_m7_15
<u>eaton-contactors-dilm-</u> <u>contactor-system-</u> <u>overview.eps</u>
2100SWI-126

	AC-1: Non-inductive or slightly inductive loads, resistance furnaces
	Screw terminals
FRAME SIZE	FS1
AMBIENT OPERATING TEMPERATURE - MAX	60 °C
AMBIENT OPERATING TEMPERATURE - MIN	-25 °C
AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX	40 °C
AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN	-25 °C
AMBIENT STORAGE TEMPERATURE - MAX	80 °C
AMBIENT STORAGE TEMPERATURE - MIN	-40 °C
ASSIGNED MOTOR POWER AT 115/120 V, 60 HZ, 1-PHASE	1 HP
ASSIGNED MOTOR POWER AT 200/208 V, 60 HZ, 3-PHASE	3 HP
ASSIGNED MOTOR POWER AT 230/240 V, 60 HZ, 1-PHASE	2 HP
ASSIGNED MOTOR POWER AT 230/240 V, 60 HZ, 3-PHASE	3 HP
ASSIGNED MOTOR POWER AT 460/480 V, 60 HZ, 3-PHASE	10 HP
ASSIGNED MOTOR POWER AT 575/600 V, 60 HZ, 3-PHASE	10 HP
CONVENTIONAL THERMAL CURRENT ITH (1-POLE, ENCLOSED)	45 A
CONVENTIONAL THERMAL CURRENT ITH (3-POLE, ENCLOSED)	18 A
CONVENTIONAL THERMAL CURRENT ITH AT 55°C (3-POLE, OPEN)	21 A
CONVENTIONAL THERMAL CURRENT ITH OF MAIN CONTACTS (1-	50 A

EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID	1.5 W
HEAT DISSIPATION CAPACITY PDISS	0 W
HEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID	0.5 W
SWITCHING TIME (DC OPERATED, MAKE CONTACTS, CLOSING DELAY) - MAX	31 ms
SWITCHING TIME (DC OPERATED, MAKE CONTACTS, OPENING DELAY) - MAX	12 ms
APPLICATION	Contactors for Motors
PRODUCT CATEGORY	Contactors
PROTECTION	Finger and back-of-hand proof, Protection against direct contact when actuated from front (EN 50274)
ARCING TIME	10 ms
ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT	Screw connection
SCREWDRIVER SIZE	2, Terminal screw, Pozidriv screwdriver 0.8 x 5.5/1 x 6 mm, Terminal screw, Standard screwdriver
VOLTAGE TYPE	DC
DEGREE OF PROTECTION	IP20
NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)	1
NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)	0
NUMBER OF CONTACTS (NORMALLY CLOSED CONTACTS)	1
NUMBER OF CONTACTS	0
(NORMALLY CLOSED) AS MAIN CONTACT	

CONTACTS)	
NUMBER OF MAIN CONTACTS (NORMALLY OPEN CONTACT)	3
OPERATING TEMPERATURE - MAX	60 °C
OPERATING TEMPERATURE - MIN	-25 °C
POWER CONSUMPTION (PICK-UP) AT DC	4.5 W
POWER CONSUMPTION (SEALING) AT DC	4.5 W
RATED BREAKING CAPACITY AT 220/230 V	120 A
RATED BREAKING CAPACITY AT 380/400 V	120 A
RATED BREAKING CAPACITY AT 500 V	100 A
RATED BREAKING CAPACITY AT 660/690 V	70 A
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MAX	0 V
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MIN	0 V
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MAX	0 V
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MIN	0 V
CONTACT CONFIGURATION	1 NC
DROP-OUT VOLTAGE	At least smoothed two- phase bridge rectifier or three-phase rectifier 0.6 - 0.15 x UC, DC operated
OVERVOLTAGE CATEGORY	Ш
DUTY FACTOR	100 %
EMITTED INTERFERENCE	According to EN 60947-1
INTERFERENCE IMMUNITY	According to EN 60947-1
LIFESPAN, MECHANICAL	10,000,000 Operations (DC operated)
PICK-UP VOLTAGE	0.8 - 1.1 V DC x Uc

	0.85 - 1.1 V DC x Uc (only with auxiliary contact module with 3 or more N/C contacts)
SAFE ISOLATION	400 V AC, Between coil and contacts, According to EN 61140 400 V AC, Between the contacts, According to EN 61140
SCREW SIZE	M3.5, Terminal screw
SWITCHING CAPACITY (AUXILIARY CONTACTS, GENERAL USE)	10 A, 600 V AC, (UL/CSA) 1 A, 250 V DC, (UL/CSA)
SWITCHING CAPACITY (AUXILIARY CONTACTS, PILOT DUTY)	P300, DC operated (UL/CSA) A600, AC operated (UL/CSA)
TERMINAL CAPACITY (FLEXIBLE WITH FERRULE)	2 x (0.75 - 2,5) mm² 1 x (0.75 - 2.5) mm²
SHOCK RESISTANCE	5.7 g, N/O main contact, Mechanical, according to IEC/EN 60068-2-27 when tabletop-mounted, Half- sinusoidal shock 10 ms 3.4 g, N/O auxiliary contact, Mechanical, according to IEC/EN 60068-2-27 when tabletop- mounted, Half-sinusoidal shock 10 ms 10 g, N/O main contact, Mechanical, according to IEC/EN 60068-2-27, Half- sinusoidal shock 10 ms 3.4 g, N/C auxiliary contact, Mechanical, according to IEC/EN 60068-2-27 when tabletop- mounted, Half-sinusoidal shock 10 ms 7 g, N/O auxiliary contact, Mechanical, according to IEC/EN 60068-2-27, Half- sinusoidal shock 10 ms 5 g, N/C auxiliary contact, Mechanical, according to IEC/EN 60068-2-27, Half- sinusoidal shock 10 ms 5 g, N/C auxiliary contact, Mechanical, according to IEC/EN 60068-2-27, Half- sinusoidal shock 10 ms
TERMINAL CAPACITY (SOLID)	2 x (0.75 - 2.5) mm² 1 x (0.75 - 4) mm²
TERMINAL CAPACITY	Single 18 - 10, double 18 -

(SOLID/STRANDED AWG)	14
SWITCHING CAPACITY (MAIN CONTACTS, GENERAL USE)	20 A, Maximum motor rating (UL/CSA)
TIGHTENING TORQUE	1.2 Nm, Screw terminals
RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MAX	220 V
RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MIN	220 V
RATED INSULATION VOLTAGE (UI)	690 V
RATED MAKING CAPACITY UP TO 690 V (COS PHI TO IEC/EN 60947)	168 A
RATED OPERATIONAL CURRENT (IE) AT AC-1, 380 V, 400 V, 415 V	22 A
RATED OPERATIONAL CURRENT (IE) AT AC-3, 220 V, 230 V, 240 V	12 A
RATED OPERATIONAL CURRENT (IE) AT AC-3, 380 V, 400 V, 415 V	12 A
RATED OPERATIONAL CURRENT (IE) AT AC-3, 440 V	12 A
RATED OPERATIONAL CURRENT (IE) AT AC-3, 500 V	10 A
RATED OPERATIONAL CURRENT (IE) AT AC-3, 660 V, 690 V	7 A
RATED OPERATIONAL CURRENT (IE) AT AC-4, 220 V, 230 V, 240 V	7 A
RATED OPERATIONAL CURRENT (IE) AT AC-4, 400 V	7 A
RATED OPERATIONAL CURRENT (IE) AT AC-4, 440 V	7 A
RATED OPERATIONAL CURRENT (IE) AT AC-4, 500 V	6 A
RATED OPERATIONAL CURRENT (IE) AT AC-4, 660 V, 690 V	5 A

RATED OPERATIONAL CURRENT (IE) AT DC-1, 110 V	20 A
RATED OPERATIONAL CURRENT (IE) AT DC-1, 220 V	15 A
RATED OPERATIONAL CURRENT (IE) AT DC-1, 60 V	20 A
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	12 A
RATED OPERATIONAL POWER AT AC-3, 240 V, 50 HZ	4 kW
RATED OPERATIONAL POWER AT AC-3, 380/400 V, 50 HZ	5.5 kW
RATED OPERATIONAL POWER AT AC-3, 415 V, 50 HZ	7 kW
RATED OPERATIONAL POWER AT AC-4, 220/230 V, 50 HZ	2 kW
RATED OPERATIONAL POWER AT AC-4, 240 V, 50 HZ	2.2 kW
RATED OPERATIONAL POWER AT AC-4, 380/400 V, 50 HZ	3 kW
RATED OPERATIONAL POWER AT AC-4, 415 V, 50 HZ	3.4 kW
RATED OPERATIONAL POWER AT AC-4, 440 V, 50 HZ	3.6 kW
RATED OPERATIONAL POWER AT AC-4, 500 V, 50 HZ	3.5 kW
RATED OPERATIONAL POWER AT AC-4, 660/690 V, 50 HZ	4.4 kW
RATED OPERATIONAL POWER (NEMA)	7.4 kW
RATED OPERATIONAL VOLTAGE (UE) AT AC - MAX	690 V
RESISTANCE PER POLE	4.6 mΩ
STATIC HEAT DISSIPATION, NON-	4.5 W

CURRENT-DEPENDENT PVS	
STRIPPING LENGTH (CONTROL CIRCUIT CABLE)	10 mm
STRIPPING LENGTH (MAIN CABLE)	10 mm
SHORT-CIRCUIT CURRENT RATING (BASIC RATING)	5 kA, SCCR (UL/CSA) 60 A, max. CB, SCCR (UL/CSA) 45 A, max. Fuse, SCCR (UL/CSA)
SHORT-CIRCUIT CURRENT RATING (HIGH FAULT AT 480 V)	25 A, Class RK5/ 45 A Class J, max. Fuse, SCCR (UL/CSA) 30/100 kA, Fuse, SCCR (UL/CSA)
SHORT-CIRCUIT CURRENT RATING (HIGH FAULT AT 600 V)	30/100 kA, Fuse, SCCR (UL/CSA) 25 A, Class RK5/45 A, Class J, max. Fuse, SCCR (UL/CSA)
SHORT-CIRCUIT PROTECTION RATING (TYPE 1 COORDINATION) AT 400 V	35 A gG/gL
SUITABLE FOR	Also motors with efficiency class IE3
SUITABLE FOR SHORT-CIRCUIT PROTECTION RATING (TYPE 1 COORDINATION) AT 690 V	•
SHORT-CIRCUIT PROTECTION RATING (TYPE 1 COORDINATION)	class IE3
SHORT-CIRCUIT PROTECTION RATING (TYPE 1 COORDINATION) AT 690 V SHORT-CIRCUIT PROTECTION RATING (TYPE 2 COORDINATION)	class IE3
SHORT-CIRCUIT PROTECTION RATING (TYPE 1 COORDINATION) AT 690 V SHORT-CIRCUIT PROTECTION RATING (TYPE 2 COORDINATION) AT 400 V SHORT-CIRCUIT PROTECTION RATING (TYPE 2 COORDINATION)	class IE3 25 A gG/gL 20 A gG/gL
SHORT-CIRCUIT PROTECTION RATING (TYPE 1 COORDINATION) AT 690 V SHORT-CIRCUIT PROTECTION RATING (TYPE 2 COORDINATION) AT 400 V SHORT-CIRCUIT PROTECTION RATING (TYPE 2 COORDINATION) AT 690 V SPECIAL PURPOSE RATING OF BALLAST ELECTRICAL DISCHARGE	class IE3 25 A gG/gL 20 A gG/gL 20 A gG/gL 20 A (480V 60Hz 3phase, 277V 60Hz 1phase) 20 A (600V 60Hz 3phase,

RATING OF ELEVATOR CONTROL	(UL/CSA) 9 A, 600 V 60 Hz 3-ph, (UL/CSA) 11 A, 480 V 60 Hz 3-ph, (UL/CSA) 7.5 HP, 480 V 60 Hz 3-ph, (UL/CSA) 2 HP, 200 V 60 Hz 3-ph, (UL/CSA) 6.8 A, 240 V 60 Hz 3-ph, (UL/CSA) 2 HP, 240 V 60 Hz 3-ph, (UL/CSA) 7.5 HP, 600 V 60 Hz 3-ph, (UL/CSA)
SPECIAL PURPOSE RATING OF REFRIGERATION CONTROL (CSA ONLY)	60 A, LRA 480 V 60 Hz 3phase; (CSA) 60 A, LRA 600 V 60 Hz 3phase; (CSA) 10 A, FLA 480 V 60 Hz 3phase; (CSA) 10 A, FLA 600 V 60 Hz 3phase; (CSA)
SPECIAL PURPOSE RATING OF RESISTANCE AIR HEATING	20 A, 600 V 60 Hz 3phase, 347 V 60 Hz 1phase, (UL/CSA) 20 A, 480 V 60 Hz 3phase, 277 V 60 Hz 1phase, (UL/CSA)
SPECIAL PURPOSE RATING OF TUNGSTEN INCANDESCENT LAMPS	14 A, 480 V 60 Hz 3phase, 277 V 60 Hz 1phase, (UL/CSA) 14 A, 600 V 60 Hz 3phase, 347 V 60 Hz 1phase, (UL/CSA)
OPERATING TEMPERATURE	-25° to 60°C
CONVENTIONAL THERMAL CURRENT ITH AT 40°C (3-POLE, OPEN)	22 A
CONVENTIONAL THERMAL CURRENT ITH AT 50°C (3-POLE, OPEN)	21 A
CONVENTIONAL THERMAL CURRENT ITH AT 60°C (3-POLE, OPEN)	20 A
RATED OPERATIONAL POWER AT AC-3, 440 V, 50 HZ	7.5 kW
RATED OPERATIONAL POWER AT AC-3, 500 V, 50 HZ	7 kW
RATED OPERATIONAL	6.5 kW

POWER AT AC-3, 690 V, 50 HZ	
ACTUATING VOLTAGE	220 V DC
ALTITUDE	Max. 2000 m
OPERATING VOLTAGE AT AC, 50 HZ - MIN	24 V
OPERATING VOLTAGE AT AC, 50 HZ - MAX	690 V
OPERATING VOLTAGE AT AC, 60 HZ - MIN	24 V
OPERATING VOLTAGE AT AC, 60 HZ - MAX	690 V

## **PROJECT NAME:**

**PROJECT NUMBER:** 

PREPARED BY:

DATE:



# Eaton Corporation plc Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.

