## Specifications



Photo is representative





## Eaton 286069

Eaton Moeller® series PKZM01 Motorprotective circuit-breaker, 440 V: 0.06kW, Ir = 0.16 - 0.25 A, IP65

General specifications	5
PRODUCT NAME	Eaton Moeller® series PKZM01 Motor-protective circuit-breaker
CATALOG NUMBER	286069
EAN	4015082860691
PRODUCT LENGTH/DEPTH	158 mm
PRODUCT HEIGHT	80 mm
PRODUCT WIDTH	117 mm
PRODUCT WEIGHT	0.557 kg
COMPLIANCES	CE Marked
CERTIFICATIONS	IEC 60947-4-1 CSA Std. C22.2 No. 14 UL 508 VDE VDE 0660 IEC/EN 60947
MODEL CODE	PKZM01-0,25-G



Features & Function	ns
ACTUATOR TYPE	Push button
FEATURES	Phase-failure sensitivity (according to IEC/EN 60947-4-1, VDE 0660 Part 102)
FITTED WITH:	Operating membrane
FUNCTIONS	Motor protection Phase failure sensitive
NUMBER OF POLES	Three-pole

General	
LIFESPAN, ELECTRICAL	50,000 operations (at 400V, AC-3)
LIFESPAN, MECHANICAL	50,000 Operations (Main conducting paths)
MOUNTING POSITION	Can be snapped on to IEC/EN 60715 top-hat rail with 7.5 or 15 mm height.
OPERATING FREQUENCY	25 Operations/h
OVERVOLTAGE CATEGORY	III
POLLUTION DEGREE	3
PRODUCT CATEGORY	Motor protective circuit breaker
PROTECTION	Finger and back-of-hand proof, Protection against direct contact when actuated from front (EN 50274)
RATED IMPULSE WITHSTAND VOLTAGE (UIMP)	6000 V AC
SHOCK RESISTANCE	25 g, Mechanical, according to IEC/EN 60068-2-27, Half- sinusoidal shock 10 ms
SUITABLE FOR	Also motors with efficiency class IE3

Climatic environmental conditions	
ALTITUDE	Max. 2000 m
AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN	-25 °C
AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX	40 °C
AMBIENT STORAGE TEMPERATURE - MIN	-40 °C
AMBIENT STORAGE TEMPERATURE - MAX	80 °C

Terminal capacities	
TERMINAL CAPACITY (SOLID/STRANDED AWG)	18 - 10
STRIPPING LENGTH (MAIN CABLE)	10 mm
TIGHTENING TORQUE	1.7 Nm, Screw terminals, Main cable

Electrical rating	
RATED FREQUENCY - MIN	50 Hz
RATED FREQUENCY - MAX	60 Hz
RATED OPERATIONAL POWER AT AC-3, 220/230 V, 50 HZ	0.04 kW
RATED OPERATIONAL POWER AT AC-3, 380/400 V, 50 HZ	0.06 kW
RATED OPERATIONAL VOLTAGE (UE) - MIN	440 V
RATED OPERATIONAL VOLTAGE (UE) - MAX	440 V
RATED UNINTERRUPTED CURRENT (IU)	0.25 A

o to 250 V DC,
cting paths
fixed 15.5 x lu
ance

Communication	
CONNECTION	Screw terminals

Trip blocks	
OVERLOAD RELEASE CURRENT SETTING - MIN	0.16 A
OVERLOAD RELEASE CURRENT SETTING - MAX	0.25 A
TRIPPING CHARACTERISTIC	Overload trigger: tripping class 10 A

s.
S.
S.
S.
S.
e to
e to
s.
e to
s.
e to

Resources	
BROCHURES	eaton-motor-starters- system-xstart-brochure- br03407001en-en-us.pdf
CATALOGUES	eaton-product-overview- for-machinery-catalogue- ca08103003zen-en-us.pdf
	eaton-switching-and- protecting-motors- product-range-catalog- ca034001en-en-us.pdf
	Product Range Catalog Switching and protecting motors
CHARACTERISTIC CURVE	eaton-manual-motor- starters-characteristic- characteristic-curve- 009.eps
	eaton-manual-motor- starters-characteristic- characteristic-curve- 002.eps
	eaton-manual-motor- starters-characteristic- characteristic-curve- 008.eps
DECLARATIONS OF CONFORMITY	DA-DC-00004914.pdf  DA-DC-00004884.pdf
DRAWINGS	eaton-manual-motor- starters-circuit-breaker- pkzm01-dimensions.eps
	eaton-general-ie-ready- dilm-contactor- standards.eps
ECAD MODEL	ETN.286069.edz
INSTALLATION VIDEOS	WIN-WIN with push-in technology
	DA-CS-ci_pkz01_g
MCAD MODEL	DA-CS-pkzm0
	DA-CD-pkzm0
SALES NOTES	eaton-link-module-for- motor-starters-pkz-flyer- fl034003en-en-us.pdf

Does not apply, since the entire switchgear needs to be evaluated.
ls the panel builder's responsibility.
Is the panel builder's responsibility.
Is the panel builder's responsibility.
ls the panel builder's responsibility.
Is the panel builder's responsibility.
The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
Is the panel builder's responsibility. The specifications for the switchgear must be observed.
Is the panel builder's responsibility. The specifications for the switchgear must be observed.
The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	
DATE:	



## **Eaton Corporation plc**

Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









