Specifications



Photo is representative





Eaton 294022

Eaton Moeller® series DILK Contactor for capacitors, with series resistors, 25 kVAr, 48 V 50 Hz

General specifications	5
PRODUCT NAME	Eaton Moeller® series DILK capacity contactor
CATALOG NUMBER	294022
MODEL CODE	DILK25-11(48V50HZ)
EAN	4015082940225
PRODUCT LENGTH/DEPTH	138 mm
PRODUCT HEIGHT	135 mm
PRODUCT WIDTH	45 mm
PRODUCT WEIGHT	0.51 kg
COMPLIANCES	CE Marked
CERTIFICATIONS	IEC 60947-4-1 CSA Std. C22.2 No. 14-05 UL 508 EN 60947-4-1 VDE CE CSA UL File No.: E29096 CSA-C22.2 No. 60947-4-1- 14 IEC/EN 60947 CSA Class No.: 3211-04 IEC/EN 60947-4-1 UL UL 60947-4-1 CSA File No.: 012528 UL Category Control No.: NLDX
GLOBAL CATALOG	294022



Product specifications

10.10 TEMPERATURE RISE	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.	CATALOGS	SmartWire-DT Catalog Product Range Catalog Switching and protecting motors eaton-product-overview-
10.11 SHORT-CIRCUIT	Is the panel builder's responsibility. The specifications for the switchgear must be observed.		for-machinery-catalogue- ca08103003zen-en-us.pdf
RATING		DECLARATIONS OF CONFORMITY	DA-DC-00004814.pdf DA-DC-00004785.pdf
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.		eaton-contactors-dilk- dimensions-004.eps eaton-contactors- mounting-dilm-
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.	DRAWINGS	dimensions-002.eps eaton-contactors-dilk- dimensions-002.eps eaton-contactors-dilk-
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.		<u>dimensions.eps</u> <u>eaton-contactors-</u>
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.		<u>mounting-dilm-</u> <u>dimensions.eps</u> <u>eaton-contactors-dilk-3d-</u>
10.2.3.2 VERIFICATION OF			drawing.eps
RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.	ECAD MODEL	<u>ETN.DILK25-</u> <u>11(48V50HZ).edz</u>
10.2.3.3 RESIST. OF		INSTALLATION INSTRUCTIONS	<u>IL03407038Z</u>
INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. Meets the product standard's requirements.	INSTALLATION VIDEOS	<u>WIN-WIN with push-in</u> <u>technology</u>	
EFFECTS			<u>eaton-dilk12-25-</u> <u>drawing.dwg</u>
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Meets the product standard's requirements.	MCAD MODEL	DA-CD-dil_m17_38
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.		eaton-dilk12-25-3d- model.stp
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.	WIRING DIAGRAMS	DA-CS-dil m17_38 eaton-contactors-circuit- dilk-wiring-diagram- 002.eps
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.		
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.		

Resources

10.4 CLEARANCES AND CREEPAGE DISTANCESMeets the product standard's requirements.10.5 PROTECTION AGAINST ELECTRIC SHOCKDoes not apply, since the entire switchgear needs to be evaluated.10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTSDoes not apply, since the entire switchgear needs to be evaluated.10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS FOR EXTERNAL CONDUCTORSIs the panel builder's responsibility.10.3 CONNECTIONS FOR EXTERNAL CONDUCTORSIs the panel builder's responsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALIs the panel builder's responsibility.FITTED WITH:Series resistorsOPERATING FREQUENCY TEMPERATURE - MAX60 °CAMBIENT OPERATING TEMPERATURE - MIN-25 °CAMBIENT OPERATING TEMPERATURE ENCLOSED) - MAX9.3 WAMBIENT OPERATING TEMPERATURE EQUIPMENT HEAT DISSIPATION, CURRENT- DEFENDENT PVID9.3 WHEAT DISSIPATION CAPACITY PDISS0 WHEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID3.1 WNUMBER OF AUXILIARY CONTACTS (NORMALLY CONTACTS)1		
AGAINST ELECTRIC SHOCKentire switchgear needs to be evaluated.10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTSDoes not apply, since the entire switchgear needs to be evaluated.10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONSIs the panel builder's responsibility.10.8 CONNECTIONS FOR EXTERNAL CONDUCTORSIs the panel builder's responsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALIs the panel builder's responsibility.FITTED WITH:Series resistorsOPERATING FREQUENCY120 Operations/hAMBIENT OPERATING TEMPERATURE - MAX60 °CAMBIENT OPERATING TEMPERATURE - MIN-25 °CAMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX9.3 WAMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN9.3 WEQUIPMENT HEAT DISSIPATION, CURRENT- DEFENDENT PVID9.3 WHEAT DISSIPATION COPACITY PDISS0 WHEAT DISSIPATION PER POLE, CURRENT- DUEPENDENT PVID3.1 WNUMBER OF AUXILIARY CONTACTS (NORMALLY1		
SWITCHING DEVICES AND COMPONENTSentire switchgear needs to be evaluated.10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONSIs the panel builder's responsibility.10.8 CONNECTIONS FOR EXTERNAL CONDUCTORSIs the panel builder's responsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALIs the panel builder's responsibility.FITTED WITH:Series resistorsOPERATING FREQUENCY120 Operations/hAMBIENT OPERATING TEMPERATURE - MIN-25 °CAMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX40 °CEQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID9.3 WHEAT DISSIPATION CAPACITY PDISS0 WHEAT DISSIPATION PER POLE, CURRENT- DOLE, CURRENT- DUEPENDENT PVID3.1 WNUMBER OF AUXILIARY CONTACTS (NORMALLY1	AGAINST ELECTRIC	entire switchgear needs to
ELECTRICAL CIRCUITS AND CONNECTIONSIs the panel builder's responsibility.10.8 CONNECTIONS FOR EXTERNAL CONDUCTORSIs the panel builder's responsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALIs the panel builder's responsibility.FITTED WITH:Series resistorsOPERATING FREQUENCY120 Operations/hAMBIENT OPERATING TEMPERATURE - MIN-25 °CAMBIENT OPERATING TEMPERATURE - MIN40 °CEQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID9.3 WHEAT DISSIPATION CAPACITY PDISS0 WHEAT DISSIPATION PER POLE, CURRENT- POLE,	SWITCHING DEVICES AND	entire switchgear needs to
EXTERNAL CONDUCTORSresponsibility.10.9.2 POWER- FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALIs the panel builder's responsibility.FITTED WITH:Series resistorsOPERATING FREQUENCY120 Operations/hAMBIENT OPERATING TEMPERATURE - MAX60 °CAMBIENT OPERATING TEMPERATURE - MIN-25 °CAMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX25 °CEQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID9.3 WHEAT DISSIPATION CAPACITY PDISS0 WHEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID3.1 WNUMBER OF AUXILIARY CONTACTS (NORMALLY1	ELECTRICAL CIRCUITS	•
FREQUENCY ELECTRIC STRENGTHIs the panel builder's responsibility.10.9.3 IMPULSE WITHSTAND VOLTAGEIs the panel builder's responsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALIs the panel builder's responsibility.FITTED WITH:Series resistorsOPERATING FREQUENCY120 Operations/hAMBIENT OPERATING TEMPERATURE - MAX60 °CAMBIENT OPERATING TEMPERATURE - MIN-25 °CAMBIENT OPERATING TEMPERATURE MAX40 °CAMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX25 °CEQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID9.3 WHEAT DISSIPATION CAPACITY PDISS0 WHEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID3.1 WNUMBER OF AUXILIARY CONTACTS (NORMALLY1		
WITHSTAND VOLTAGEresponsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALIs the panel builder's responsibility.FITTED WITH:Series resistorsOPERATING FREQUENCY120 Operations/hAMBIENT OPERATING TEMPERATURE - MAX $60 ^\circ$ CAMBIENT OPERATING TEMPERATURE - MIN $-25 ^\circ$ CAMBIENT OPERATING TEMPERATURE - MIN $40 ^\circ$ CAMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX $25 ^\circ$ CAMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX $9.3 W$ AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN $0 W$ EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID $0. W$ HEAT DISSIPATION CAPACITY PDISS $3.1 W$ NUMBER OF AUXILIARY CONTACTS (NORMALLY 1	FREQUENCY ELECTRIC	· ·
Is the panel builder's responsibility.ENCLOSURES MADE OF INSULATING MATERIALIs the panel builder's responsibility.FITTED WITH:Series resistorsOPERATING FREQUENCY120 Operations/hAMBIENT OPERATING TEMPERATURE - MAX60 °CAMBIENT OPERATING TEMPERATURE - MIN-25 °CAMBIENT OPERATING TEMPERATURE MIN40 °CAMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX25 °CAMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN9.3 WEQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID0 WHEAT DISSIPATION CAPACITY PDISS0.1 WHEAT DISSIPATION PER POLE, CURRENT- DOLE, CURRENT- DEPENDENT PVID3.1 WNUMBER OF AUXILIARY CONTACTS (NORMALLY1		
OPERATING FREQUENCY120 Operations/hAMBIENT OPERATING TEMPERATURE - MAX60 °CAMBIENT OPERATING TEMPERATURE - MIN-25 °CAMBIENT OPERATING TEMPERATURE MIN40 °CAMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX25 °CAMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN9.3 WEQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID9.3 WHEAT DISSIPATION CAPACITY PDISS0 WHEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID3.1 WNUMBER OF AUXILIARY CONTACTS (NORMALLY1	ENCLOSURES MADE OF	-
AMBIENT OPERATING TEMPERATURE - MAX60 °CAMBIENT OPERATING TEMPERATURE - MIN-25 °CAMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX40 °CAMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX25 °CEQUIPMENT OPERATING TEMPERATURE DISSIPATION, CURRENT- DEPENDENT PVID9.3 WHEAT DISSIPATION CAPACITY PDISS0 WHEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID3.1 WNUMBER OF AUXILIARY CONTACTS (NORMALLY1	FITTED WITH:	Series resistors
TEMPERATURE - MAX60 °CAMBIENT OPERATING TEMPERATURE - MIN-25 °CAMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX40 °CAMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN25 °CEQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID9.3 WHEAT DISSIPATION CAPACITY PDISS0 WHEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID3.1 WNUMBER OF AUXILIARY CONTACTS (NORMALLY1	OPERATING FREQUENCY	120 Operations/h
TEMPERATURE - MIN-25 °CAMBIENT OPERATING TEMPERATURE40 °C(ENCLOSED) - MAX40 °CAMBIENT OPERATING TEMPERATURE25 °C(ENCLOSED) - MIN9.3 WEQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID9.3 WHEAT DISSIPATION CAPACITY PDISS0 WHEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID3.1 WNUMBER OF AUXILIARY CONTACTS (NORMALLY1		60 °C
TEMPERATURE (ENCLOSED) - MAX40 °CAMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN25 °CEQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID9.3 WHEAT DISSIPATION CAPACITY PDISS0 WHEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID3.1 WNUMBER OF AUXILIARY CONTACTS (NORMALLY1		-25 °C
TEMPERATURE (ENCLOSED) - MIN25 °CEQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID9.3 WHEAT DISSIPATION CAPACITY PDISS0 WHEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID3.1 WNUMBER OF AUXILIARY CONTACTS (NORMALLY1	TEMPERATURE	40 °C
DISSIPATION, CURRENT- DEPENDENT PVID9.3 WHEAT DISSIPATION CAPACITY PDISS0 WHEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID3.1 WNUMBER OF AUXILIARY CONTACTS (NORMALLY1	TEMPERATURE	25 °C
CAPACITY PDISS0 WHEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID3.1 WNUMBER OF AUXILIARY CONTACTS (NORMALLY1	DISSIPATION, CURRENT-	9.3 W
POLE, CURRENT- 3.1 W DEPENDENT PVID 3.1 W NUMBER OF AUXILIARY 1		0 W
CONTACTS (NORMALLY 1	POLE, CURRENT-	3.1 W
	CONTACTS (NORMALLY	1
NUMBER OF AUXILIARY CONTACTS (NORMALLY 1 OPEN CONTACTS)	CONTACTS (NORMALLY	1
NUMBER OF CONTACTS (NORMALLY CLOSED) AS		0

MAIN CONTACT	
NUMBER OF MAIN CONTACTS (NORMALLY OPEN CONTACT)	3
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MAX	48 V
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MIN	48 V
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MAX	0 V
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MIN	0 V
RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MAX	0 V
RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MIN	0 V
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	38 A
RATED OPERATIONAL POWER AT AC-6B, 220/230 V, 50 HZ	15 kW
RATED OPERATIONAL POWER AT AC-6B, 380/400 V, 50 HZ	25 kW
CONNECTION	Screw terminals
RATED OPERATIONAL POWER AT AC-6B, 525 V, 50 HZ	33.3 kW
RATED OPERATIONAL POWER AT AC-6B, 690 V, 50 HZ	40 kW
STATIC HEAT DISSIPATION, NON- CURRENT-DEPENDENT PVS	2.1 W
SWITCHING TIME (AC OPERATED, MAKE CONTACTS, CLOSING DELAY) - MAX	22 ms
SWITCHING TIME (AC OPERATED, MAKE CONTACTS, CLOSING	16 ms

SWITCHING TIME (AC OPERATED, MAKE CONTACTS, OPENING DELAY) - MAX	14 ms
SWITCHING TIME (AC OPERATED, MAKE CONTACTS, OPENING DELAY) - MIN	8 ms
APPLICATION	Contactors for power factor correction
PRODUCT CATEGORY	DILK Contactors for capacitors
PROTECTION	Finger and back-of-hand proof, Protection against direct contact when actuated from front (EN 50274)
NUMBER OF AUXILIARY CONTACTS (CHANGE- OVER CONTACTS)	0
RATED SWITCH CURRENT	38 A
OPERATING VOLTAGE AT AC, 50 HZ - MIN	230 V
OPERATING VOLTAGE AT AC, 50 HZ - MAX	690 V
OPERATING VOLTAGE AT AC, 60 HZ - MIN	230 V
OPERATING VOLTAGE AT AC, 60 HZ - MAX	690 V
RATED BLIND POWER AT 400 V, 60 HZ	25 kWAR
ARCING TIME	10 ms
ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT	Screw connection
VOLTAGE TYPE	AC
DEGREE OF PROTECTION	IP00
DROP-OUT VOLTAGE	AC operated: 0.6 - 0.3 x UC, AC operated
DUTY FACTOR	100 %
EMITTED INTERFERENCE	According to EN 60947-1
INTERFERENCE IMMUNITY	According to EN 60947-1
LIFESPAN, ELECTRICAL	150,000 Operations
MAKING CAPACITY WITHOUT DAMPING (I- PEAK VALUE)	180 x le
PICK-UP VOLTAGE	0.8 - 1.1 V AC x Uc

POWER CONSUMPTION, PICK-UP, 50 HZ	58 VA, Dual-frequency coil in a cold state and 1.0 x Us, at 50 Hz
POWER CONSUMPTION, PICK-UP, 60 HZ	71 VA, Dual-frequency coil in a cold state and 1.0 x Us, at 60 Hz
POWER CONSUMPTION, SEALING, 50 HZ	7.6 VA, Dual-frequency coil in a cold state and 1.0 x Us, at 50 Hz 2.1 W, Dual-frequency coil in a cold state and 1.0 x Us, at 50 Hz
POWER CONSUMPTION, SEALING, 60 HZ	9.3 VA, Dual-frequency coil in a cold state and 1.0 x Us, at 60 Hz 2.1 W, Dual-frequency coil in a cold state and 1.0 x Us, at 60 Hz
RATED BLIND POWER	25 kvar
RATED OPERATIONAL CURRENT (IE)	38 A at 690 V (three-phase capacitors, open) 34 A at 690 V (three-phase capacitors, enclosed) 38 A at 400 V (three-phase capacitors, open) 34 A at 400 V (three-phase capacitors, enclosed) 34 A at 230 V (three-phase capacitors, enclosed) 38 A at 230 V (three-phase capacitors, open) 38 A at 525 V (three-phase capacitors, open) 34 A at 525 V (three-phase capacitors, open)
SPECIAL PURPOSE RATING OF CAPACITOR SWITCHING	36 A, 240 V 60 Hz 3phase, (UL/CSA) 38.4 A, 600 V 60 Hz 3phase, (UL/CSA) 40 kVar, 600 V 60 Hz 3phase, (UL/CSA) 15 kVar, 240 V 60 Hz 3phase, (UL/CSA) 36 A, 480 V 60 Hz 3phase, (UL/CSA) 30 kVar, 480 V 60 Hz 3phase, (UL/CSA)
TERMINAL CAPACITY (STRANDED)	1 x 16 mm², Main cables
SWITCHING CAPACITY (AUXILIARY CONTACTS, GENERAL USE)	1 A, 250 V DC, (UL/CSA) 10 A, 600 V AC, (UL/CSA)
SWITCHING CAPACITY	A600, AC operated

(AUXILIARY CONTACTS, PILOT DUTY)	(UL/CSA) P300, DC operated (UL/CSA)
TERMINAL CAPACITY (FLEXIBLE WITH FERRULE)	1 x (0.75 - 16) mm², Main cables
TERMINAL CAPACITY (SOLID)	1 x (0.75 - 16) mm², Main cables
TERMINAL CAPACITY (SOLID/STRANDED AWG)	18 - 6, Main cables

PROJECT NAME:

PROJECT NUMBER:

PREPARED BY:

DATE:



Eaton Corporation plc Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.

