

Specifications

Eaton 030452

Eaton Moeller® series TM Changeover switches, TM, 10 A, center mounting, 3 contact unit(s), Contacts: 6, 60 °, maintained, Without 0 (Off) position, 1-2, Design number 8222, Key operated lock mechanism

General specifications

PRODUCT NAME	Eaton Moeller® series TM Changeover switch
CATALOG NUMBER	030452
EAN	4015080304524
PRODUCT LENGTH/DEPTH	83 mm
PRODUCT HEIGHT	30 mm
PRODUCT WIDTH	30 mm
PRODUCT WEIGHT	0.072 kg
CERTIFICATIONS	CSA CSA-C22.2 No. 14-05 UL Category Control No.: NLRV UL VDE 0660 Certified by UL for use in Canada UL report applies to both US and Canada IEC/EN 60947-5-1 UL 508 CSA-C22.2 No. 94 CE IEC/EN 60947-3 IEC/EN 60947 UL File No.: E36332
MODEL CODE	TM-3-8222/EZ/S-J



Powering Business Worldwide

Features & Functions

ENCLOSURE MATERIAL	Plastic
FITTED WITH:	Black thumb grip and front plate
INSCRIPTION	1-2
LOCKING MECHANISM	Key actuation
NUMBER OF POLES	3

Climatic environmental conditions

AMBIENT OPERATING TEMPERATURE - MIN	-25 °C
AMBIENT OPERATING TEMPERATURE - MAX	50 °C
CLIMATIC PROOFING	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78

General

DEGREE OF PROTECTION	IP65
DEGREE OF PROTECTION (FRONT SIDE)	IP65 NEMA 12
LIFESPAN, MECHANICAL	1,000,000 Operations
MODEL	Reverser
MOUNTING METHOD	Center mounting
MOUNTING POSITION	As required
NUMBER OF CONTACT UNITS	3
OPERATING FREQUENCY	1200 Operations/h
OVERVOLTAGE CATEGORY	III
POLLUTION DEGREE	3
PRODUCT CATEGORY	Control switches
RATED IMPULSE WITHSTAND VOLTAGE (UIMP)	4000 V AC
SUITABLE FOR	Front mounting
SWITCHING ANGLE	60 °
TYPE	Changeover switch

Terminal capacities

TERMINAL CAPACITY (FLEXIBLE WITH FERRULE)	1 x 1.0 mm ² , ferrules to DIN 46228 2 x 1.0 mm ² , ferrules to DIN 46228
TERMINAL CAPACITY (FLEXIBLE)	1 x 1.5 mm ² 2 x 1.5 mm ²
TERMINAL CAPACITY (SOLID/FLEXIBLE WITH FERRULE AWG)	14
TERMINAL CAPACITY (SOLID/STRANDED)	1 x 1.5 mm ² 2 x 1,5 mm ²
SCREW SIZE	M2.5, Terminal screw
TIGHTENING TORQUE	0.4 Nm, Screw terminals 3.5 lb-in, Screw terminals

Electrical rating

RATED OPERATIONAL CURRENT (IE) AT AC-3, 380 V, 400 V, 415 V 0 A

RATED OPERATIONAL POWER AT AC-3, 380/400 V, 50 HZ 3.3 kW

RATED OPERATIONAL POWER AT AC-23A, 400 V, 50 HZ 3 kW

RATED OPERATIONAL VOLTAGE (UE) AT AC - MAX 500 V

RATED UNINTERRUPTED CURRENT (IU) 10 A

UNINTERRUPTED CURRENT Rated uninterrupted current I_u is specified for max. cross-section.

Switching capacity

SWITCHING CAPACITY (MAIN CONTACTS, GENERAL USE) 10 A, Rated uninterrupted current max. (UL/CSA)

SWITCHING CAPACITY (AUXILIARY CONTACTS, GENERAL USE) 10A, IU, (UL/CSA)

SWITCHING CAPACITY (AUXILIARY CONTACTS, PILOT DUTY) A300 (UL/CSA)

Short-circuit rating

SHORT-CIRCUIT PROTECTION RATING 10 A gG/gL, Fuse, Contacts

Motor rating

ASSIGNED MOTOR POWER AT 115/120 V, 60 HZ, 1-PHASE 0.33 HP

ASSIGNED MOTOR POWER AT 115/120 V, 60 HZ, 3-PHASE 0.75 HP

ASSIGNED MOTOR POWER AT 230/240 V, 60 HZ, 1-PHASE 0.75 HP

ASSIGNED MOTOR POWER AT 230/240 V, 60 HZ, 3-PHASE 1 HP

ASSIGNED MOTOR POWER AT 277 V, 60 HZ, 1-PHASE 0.75 HP

Contacts

CONTROL CIRCUIT RELIABILITY	1 failure per 100,000 switching operations statistically determined, at 24 V DC, 10 mA)
------------------------------------	---

NUMBER OF AUXILIARY CONTACTS (CHANGE-OVER CONTACTS)	0
--	---

NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)	0
--	---

NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)	0
--	---

NUMBER OF CONTACTS	6
---------------------------	---

Actuator

ACTUATOR FUNCTION	Without 0 (Off) position Maintained
--------------------------	--

ACTUATOR TYPE	Key
----------------------	-----

Design verification

EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID	0 W
HEAT DISSIPATION CAPACITY PDISS	0 W
HEAT DISSIPATION PER POLE, CURRENT-DEPENDENT PVID	0.15 W
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	10 A
STATIC HEAT DISSIPATION, NON-CURRENT-DEPENDENT PVS	0 W
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	UV resistance only in connection with protective shield.
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.

10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	Is the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	Is the panel builder's responsibility.
10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH	Is the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	Is the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	Is the panel builder's responsibility.
10.10 TEMPERATURE RISE	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Resources

BROCHURES

[Brochure - T Rotary Cam switch and P Switch-disconnector](#)

CATALOGUES

[P Switch-disconnectors and T Rotary cam switches catalogue CA042001EN](#)

DECLARATIONS OF CONFORMITY

[DA-DC-00004893.pdf](#) [DA-DC-00004922.pdf](#)

DRAWINGS

[eaton-rotary-switches-front-plate-tm-changeover-switch-symbol.eps](#)

	eaton-general-rotary-switch-t0-step-switch-symbol-004.eps
ECAD MODEL	DA-CE-ETN.TM-3-8222_EZ_S-I
INSTALLATION INSTRUCTIONS	IL03801025Z
INSTALLATION VIDEOS	Eaton's P Switch-disconnectors used in a factory
MCAD MODEL	DA-CS-tm3_ez_s DA-CD-tm3_ez_s
PRODUCT NOTIFICATIONS	MZ008006ZU_Orderform_Customized_Switch.pdf MZ008005ZU_Orderform_Customized_Switch.pdf
WIRING DIAGRAMS	eaton-rotary-switches-contact-t0-changeover-switch-wiring-diagram-005.eps

PROJECT NAME:

PROJECT NUMBER:

PREPARED BY:

DATE:



Eaton Corporation plc
Eaton House
30 Pembroke Road
Dublin 4, Ireland
Eaton.com

Follow us on social media to get the latest product and support information.

