## SIEMENS

Product data sheet

OVERLOAD RELAY 6...25 A FOR MOTOR PROTECTION SIZE S2,

CLASS 20 STAND-ALONE INSTALLATION MAIN CIRCUIT: THROUGH TRANSF. AUX. CIRCUIT: SCREW CONNECTION MANUAL-AUTOMATIC-RESET

General technical data:				
product brand name		SIRIUS		
Product designation		solid-state overload relay		
Size of overload relay		S2		
Number of poles / for main current circuit		3		
Product function / removable terminal for auxiliary and control circuit		Yes		
Impulse voltage resistance / rated value	kV	6		
Protection class IP		IP20		
Protection class IP / on the front		IP20		
Protection against electrical shock		finger-safe		
Installation altitude / at a height over sea level / maximum	m	2,000		
Resistance against shock		15g / 11 ms		
Ambient temperature				
during transport	°C	-40 +80		
during storage	°C	-40 +80		
during operating	°C	-25 +60		
Relative humidity / during operating phase / maximum	%	100		
Electrostatic discharge / according to IEC 61000-4-2		6 kV contact discharge / 8 kV air discharge		
Field-bound parasitic coupling / according to IEC 61000-4-3		10 V/m		
Conductor-bound parasitic coupling BURST / according to IEC 61000-4-4		2 kV (power ports), 1 kV (signal ports) corresponds to degree of severity 3 $$		
Conductor-bound parasitic coupling conductor-earth SURGE / according to IEC 61000-4-5		2 kV (line to earth) corresponds to degree of severity 3 $$		
Conductor-bound parasitic coupling conductor-conductor SURGE / according to IEC 61000-4-5		1 kV (line to line) corresponds to degree of severity 3		
Type of protection		PTB 06 ATEX 3001 Ex II (2) GD		
Active power loss / total / typical	W	0.05		
Size of the contactor / can be combined / company-specific		S2		
Main circuit:				
Operating current / of the fuse link / rated value	А	63		

## Type of assignement


Auxiliary circuit:		
Number of NC contacts / for auxiliary contacts		1
Number of NO contacts / for auxiliary contacts	_	1
Number of changeover contacts / for auxiliary contacts		0
Design of the fuse link / for short-circuit protection of the auxiliary switch / required		fuse gL/gG: 6 A
Operating current / of the auxiliary contacts		
• at AC-15		
• at 24 V	А	4
• at 110 V	А	4
• at 120 V	А	4
• at 125 V	А	4
• at 230 V	А	3
• at DC-13		
• at 24 V	А	2
• at 60 V	А	0.55
• at 110 V	А	0.3
• at 125 V	А	0.3
• at 220 V	А	0.11


Protective and monitoring functions:				
Trip class		CLASS 20		
Adjustable response current / of the current-dependent overload release	А	6 25		

Installation/ mounting/ dimensions:			
Mounting type		stand-alone installation	
mounting position		any	
Depth	mm	109	
Height	mm	92	
Width	mm	55	

Connections/ terminals:Design of the electrical connectionImage: straight - through transformers• for main current circuitstraight - through transformers• for auxiliary and control current circuitscrew-type terminalsType of the connectable conductor cross-sectionImage: solid• for auxiliary contacts0.5 ... 4 mm², 2x (0.5 ... 2.5 mm²)• finely strandedImage: solid

	with conductor end processing for AWG conductors / for auxiliary contacts			0.5 2.5 mm², 2x (0.5 1.5 mm²) 2x (20 14)		
Certificates/ app	provals:		_			
General Product				EMC	For use in hazardous locations	
	(SA)	EHC		C-TICK	K ATEX	
Test Certificates	;					
Special Test Certificate	<u>Type Test</u> Certificates/Test <u>Report</u>					
Shipping Approv	val					
ABS		GL	Lloyd's Register Lrs	RINA		
other						
Declaration of Conformity	other	Environmental Confirmations				
Further informa	tion:					
Information- and Downloadcenter (Catalogs, Brochures,) http://www.siemens.com/industrial-controls/catalogs						
Industry Mall (Online ordering system) http://www.siemens.com/industrial-controls/mall						
Cax online generator http://www.siemens.com/cax						
Service&Support (Manuals, Certificates, Characteristics, FAQs,) http://support.automation.siemens.com/WW/view/en/3RB2036-2QW1/all						
Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams,) http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3RB2036-2QW1						





last change:

Jun 16, 2014