SIEMENS

Data sheet 3TK2824-2BB40



SIRIUS safety relay with relay enabling circuits (EC) 24 V DC, 22.5 mm Spring-type terminal EC instantaneous: 2 NO EC delayed: 0 NO SC: 0 NC AUTOSTART Basic device Maximum achieved SIL: 1, PL: c

Figure similar

product brand name	SIRIUS		
product designation	safety relays		
design of the product	for EMERGENCY-STOP and safety doors		
General technical data			
protection class IP of the enclosure	IP40		
protection class IP of the terminal	IP20		
touch protection against electrical shock	finger-safe		
insulation voltage rated value	300 V		
ambient temperature			
during storage	-40 +80 °C		
during operation	-25 +60 °C		
air pressure according to SN 31205	90 106 kPa		
relative humidity during operation	10 95 %		
installation altitude at height above sea level maximum	2 000 m		
vibration resistance according to IEC 60068-2-6	5 500 Hz: 0,075 mm		
shock resistance	8g / 10 ms		
surge voltage resistance rated value	4 000 V		
EMC emitted interference	EN 60947-5-1		
installation environment regarding EMC	This product is suitable for Class A environments only. In household environments, this device can cause unwanted radio interference. The user is required to implement appropriate measures in this case.		
reference code according to DIN 40719 extended according to IEC 204-2 according to IEC 750	KT		
reference code according to EN 61346-2	F-		
number of sensor inputs			
• 1-channel or 2-channel	1		
design of the cascading	none		
type of the safety-related wiring of the inputs	single-channel or single-channel and two-channel		
product feature cross-circuit-proof	No		
Safety Integrity Level (SIL)			
 according to IEC 61508 	3		
SIL Claim Limit (subsystem) according to EN 62061	1		
category according to EN ISO 13849-1	2		
hardware fault tolerance according to IEC 61508	1		
safety device type according to IEC 61508-2	Type A		
PFHD with high demand rate according to EN 62061	8.7E-10 1/h		
Average probability of failure on demand (PFDavg) with low demand rate acc. to IEC 61508	7.7E-7 1/y		
T1 value for proof test interval or service life according to IEC 61508	20 a		
number of outputs as contact-affected switching element			

as NO seedest	
as NC contact	
for signaling function instantaneous contact	0
as NO contact	
safety-related instantaneous contact	2
— safety-related delayed switching	0
number of outputs as contact-less semiconductor switching element	
safety-related	
delayed switching	0
instantaneous contact	0
for signaling function	
delayed switching	0
instantaneous contact	0
stop category according to EN 60204-1	0
Inputs	
design of input	
	No
cascading input/functional switching feedback input	Yes
• feedback input	Yes
• start input	165
Outputs tupe of electrical connection plug in cocket	Voc
type of electrical connection plug-in socket	Yes 1,000 1/b
operating frequency maximum	1 000 1/h
switching capacity current	
of the NO contacts of the relay outputs at DC-13	
— at 24 V	6 A
— at 115 V	0.2 A
— at 230 V	0.1 A
of the NO contacts of the relay outputs at AC-15	6.0
— at 115 V	6 A
— at 230 V	6 A
thermal current of the switching element with contacts maximum	5 A
electrical endurance (operating cycles) typical	100 000
mechanical service life (operating cycles) typical	10 000 000
design of the fuse link for short-circuit protection of the NO contacts of the relay outputs required	gL/gG: 6 A, or quick: 10 A
DC resistance of the cable maximum	30 Ω
wire length between sensor and electronics evaluation device with Cu 1.5 mm ² and 150 nF/km maximum	1 000 m
Times	
make time with automatic start	
• at DC maximum	200 ms
at AC maximum	300 ms
backslide delay time in the event of power failure	
• maximum	200 ms
recovery time after opening of the safety circuits typical	200 ms
recovery time after power failure typical	200 ms
pulse duration	
• of the sensor input minimum	200 ms
 of the ON pushbutton input minimum 	0.15 s
Control circuit/ Control	
type of voltage of the control supply voltage	DC
control supply voltage 1	
at DC rated value	24 V
operating range factor control supply voltage rated value of magnet coil	
• at AC	
— at 50 Hz	0.85 1.1
— at 60 Hz	0.85 1.1
• at DC	0.85 1.2
Installation/ mounting/ dimensions	
mounting position	any
	

fastening method	screw and snap-on mounting				
width	22.5 mm	· · · · · · · · · · · · · · · · · · ·			
height	120 mm				
depth	120 mm				
Connections/ Terminals					
type of electrical connection	spring-loaded terminals				
type of connectable conductor cross-sections					
• solid	2x (0.25 1.5 mm²)				
• finely stranded					
— with core end processing	2 x (0.25 1.5 mm²)				
 — without core end processing 	2x (0.25 1.5 mm²)				
type of connectable conductor cross-sections for AWG cables					
• solid	2x (24 16)				
stranded	2x (24 16)				
Product Function					
product function					
light barrier monitoring	No				
standstill monitoring	No				
 protective door monitoring 	Yes				
automatic start	Yes				
 magnetically operated switch monitoring NC-NO 	No				
 rotation speed monitoring 	No				
laser scanner monitoring	No				
 monitored start-up 	No				
light array monitoring	No				
 magnetically operated switch monitoring NC-NC 	No				
 EMERGENCY OFF function 	Yes				
 pressure-sensitive mat monitoring 	No				
suitability for interaction press control	No				
suitability for use					
 monitoring of floating sensors 	Yes				
 monitoring of non-floating sensors 	No				
safety switch	Yes				
 position switch monitoring 	Yes				
 EMERGENCY-OFF circuit monitoring 	Yes				
 valve monitoring 	No				
 tactile sensor monitoring 	No				
 magnetically operated switch monitoring 	No	No			
safety-related circuits	Yes				
Certificates/ approvals					
certificate of suitability	BG, SUVA, UL, CSA, EN 60204-1, EN ISO 12100, EN 954-1, IEC 61508				
 TÜV (German technical inspectorate) certificate 	Yes				
UL approval	Yes				
BG BIA approval	Yes				
General Product Approval		EMC	Test Certificates		











Special Test Certificate

other

Confirmation

Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3TK2824-2BB40

Cax online generator


http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3TK2824-2BB40

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/3TK2824-2BB40

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)

http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3TK2824-2BB40&lang=en



last modified:

7/6/2022