SIEMENS

Data sheet 3TK2828-2BB41



SIRIUS safety relay with relay enabling circuits (EC) 24 V DC, 45 mm overall width Spring-type terminal EC instantaneous: 2 NO EC delayed: 2NO, 0.05...3 s SC: 1NC AUTOSTART Basic device Maximum achieved SIL: 3/2, PL: e/d

Figure similar

product brand name	SIRIUS		
product designation	safety relays		
design of the product	für Schutztüren		
General technical data			
protection class IP of the enclosure	IP20		
protection class IP of the terminal	IP20		
touch protection against electrical shock	finger-safe		
insulation voltage rated value	300 V		
ambient temperature			
during storage	-40 +80 °C		
during operation	-25 +60 °C		
air pressure according to SN 31205	90 106 kPa		
relative humidity during operation	10 95 %		
installation altitude at height above sea level maximum	2 000 m		
vibration resistance according to IEC 60068-2-6	5 500 Hz: 0,075 mm		
shock resistance	8g / 10 ms		
surge voltage resistance rated value	4 000 V		
EMC emitted interference	EN 60947-5-1		
installation environment regarding EMC	This product is suitable for Class A environments only. In household environments, this device can cause unwanted radio interference. The user is required to implement appropriate measures in this case.		
reference code according to DIN 40719 extended according to IEC 204-2 according to IEC 750	KT		
reference code according to EN 61346-2	F		
number of sensor inputs			
• 1-channel or 2-channel	1		
design of the cascading	none		
type of the safety-related wiring of the inputs	single-channel and two-channel		
product feature cross-circuit-proof	Yes		
Safety Integrity Level (SIL)			
 according to IEC 61508 	3		
 for delayed release circuit according to IEC 61508 	SIL2		
SIL Claim Limit (subsystem) according to EN 62061	3		
performance level (PL)			
 for delayed release circuit according to EN ISO 13849-1 	d		
category according to EN ISO 13849-1	4		
hardware fault tolerance according to IEC 61508	1		
safety device type according to IEC 61508-2	Туре А		
PFHD with high demand rate according to EN 62061	2.7E-9 1/h		
Average probability of failure on demand (PFDavg) with low	2.4E-6 1/y		

demand rate acc. to IEC 61508	
T1 value for proof test interval or service life according to	20 a
IEC 61508	
number of outputs as contact-affected switching element	
as NC contact	
 for signaling function instantaneous contact 	1
as NO contact	
 — safety-related instantaneous contact 	2
 — safety-related delayed switching 	2
number of outputs as contact-less semiconductor	
switching element	
safety-related	
 delayed switching 	0
 instantaneous contact 	0
 for signaling function 	
 delayed switching 	0
— instantaneous contact	0
stop category according to EN 60204-1	0 + 1
Inputs	
design of input	
 cascading input/functional switching 	No
• feedback input	Yes
• start input	Yes
Outputs	
type of electrical connection plug-in socket	Yes
operating frequency maximum	1 000 1/h
switching capacity current	
 of the NO contacts of the relay outputs for delayed release circuit 	
— at AC-15 at 230 V	3 A
— at DC-13 at 24 V	2 A
of the NO contacts of the relay outputs for instantaneous enabling circuit	
— at AC-15 at 230 V	5 A
— at DC-13 at 24 V	5 A
thermal current of the switching element with contacts maximum	5 A
electrical endurance (operating cycles) typical	100 000
mechanical service life (operating cycles) typical	10 000 000
design of the fuse link for short-circuit protection of the NO contacts of the relay outputs required	gL/gG: 6 A, or quick: 10 A
DC resistance of the cable maximum	30 Ω
wire length between sensor and electronics evaluation device with Cu 1.5 mm² and 150 nF/km maximum	1 000 m
Times	
make time with automatic start	
at DC maximum	80 ms
backslide delay time in the event of power failure	
maximum	100 ms
recovery time after power failure typical	1s
pulse duration	
 of the sensor input minimum 	25 ms
 of the ON pushbutton input minimum 	0.025 s
Control circuit/ Control	
type of voltage of the control supply voltage	DC
control supply voltage 1	
at DC rated value	24 V
operating range factor control supply voltage rated value of magnet coil	
• at AC	
— at 50 Hz	0.85 1.1
— at 60 Hz	0.85 1.1
• at DC	0.85 1.1
- 4000	VIOV III 111

Installation/ mounting/ dimensions					
mounting position	any				
fastening method	screw and snap-on mounting				
width	45 mm				
height	138.5 mm				
depth	120 mm				
Connections/ Terminals					
type of electrical connection	spring-loaded terminals				
type of connectable conductor cross-sections					
• solid	2x (0.25 1.5 mm²)				
finely stranded					
with core end processing	2 x (0.25 1.5 mm²)				
without core end processing	2x (0.25 1.5 mm²)				
type of connectable conductor cross-sections for AWG cables					
• solid	2x (24 16)				
• stranded	2x (24 16)				
Product Function					
product function					
light barrier monitoring	No				
standstill monitoring	No				
 protective door monitoring 	Yes				
automatic start	Yes				
 magnetically operated switch monitoring NC-NO 	No				
 rotation speed monitoring 	No				
laser scanner monitoring	No				
monitored start-up	No				
 light array monitoring 	No				
 magnetically operated switch monitoring NC-NC 	No				
 EMERGENCY OFF function 	No	No			
 pressure-sensitive mat monitoring 	Yes	Yes			
suitability for interaction press control	No				
suitability for use					
 monitoring of floating sensors 	Yes	Yes			
 monitoring of non-floating sensors 	No				
 safety switch 	Yes				
position switch monitoring	Yes				
 EMERGENCY-OFF circuit monitoring 	No				
valve monitoring	No				
• tactile sensor monitoring	No				
 magnetically operated switch monitoring 	No	No			
safety-related circuits	Yes				
Certificates/ approvals					
certificate of suitability	BG, SUVA, UL, CSA, EN 60204-1, EN ISO 12100, EN 954-1, IEC 61508				
 TÜV (German technical inspectorate) certificate 	Yes				
UL approval	Yes				
BG BIA approval	Yes				
General Product Approval		EMC	Functional Safety/Safety of Ma chinery		











Type Examination Certificate

Test Certificates

other

Special Test Certificate

Confirmation

Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3TK2828-2BB41

Cax online generator


http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3TK2828-2BB41

 $Service \& Support \ (Manuals, \ Certificates, \ Characteristics, \ FAQs, ...)$

https://support.industry.siemens.com/cs/ww/en/ps/3TK2828-2BB41

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)

http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3TK2828-2BB41&lang=en



last modified:

7/6/2022