Specifications



Photo is representative

Eaton 046844

Eaton Moeller® series RMQ16 Key-operated actuator, 3 positions, red, momentary Q25S3-RT

General specifications Eaton Moeller® series **PRODUCT NAME** RMQ16 Key-operated actuator CATALOG NUMBER 046844 EAN 4015080468448 PRODUCT 50 mm LENGTH/DEPTH **PRODUCT HEIGHT** 25 mm **PRODUCT WIDTH** 25 mm **PRODUCT WEIGHT** 0.023 kg CSA File No.: 46552 CSA-C22.2 No. 14-05 UL UL 508 UL Category Control No.: NKCR CERTIFICATIONS CSA Class No.: 3211-03

	C5/(Clu551105211.05
	IEC/EN 60947-5
	CE
	CSA
	IEC/EN 60947
	UL File No.: E29184
MODEL CODE	Q25S3-RT



Features & Functions	
BEZEL COLOR	Black
BEZEL MATERIAL	Plastic
DESIGN	Key operated
FITTED WITH:	Front ring

General	
ACCESSORIES	1 key included with supplied equipment.
DEGREE OF PROTECTION	NEMA 1
DEGREE OF PROTECTION (FRONT SIDE)	IP65
LIFESPAN, MECHANICAL	3,000,000 Operations
OPENING DIAMETER	16 mm
OPERATING FREQUENCY	1800 Operations/h
OPERATING TORQUE	0.4 Nm
OVERVOLTAGE CATEGORY	III
POLLUTION DEGREE	3
PRODUCT CATEGORY	RMQ16
RATED IMPULSE WITHSTAND VOLTAGE (UIMP)	800 V AC
SIZE	Front dimensions: 25 × 25 mm
SWITCHING ANGLE	45 °
SWITCHING ANGLE TERMINAL CAPACITY	45 ° 0.5 - 1.0 mm²
TERMINAL CAPACITY	0.5 - 1.0 mm ² 2.8 x 0.8 mm to DIN 46244, Blade terminal 2.8 x 0.8 mm to DIN 46247 and IEC 60760, Fast-on

Ambient conditions, mechanical	
MOUNTING POSITION	As required
SHOCK RESISTANCE	Mechanical, According to IEC/EN 60068-2-27 40 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms

Climatic environmental conditions

AMBIENT OPERATING TEMPERATURE - MIN	-25 °C
AMBIENT OPERATING TEMPERATURE - MAX	60 °C
AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN	25 °C
AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX	40 °C
CLIMATIC PROOFING	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78

Electrical rating

RATED INSULATION VOLTAGE (UI) RATED OPERATIONAL VOLTAGE (UE) AT AC -MAX ActuatorRedACTUATOR COLORRedACTUATOR FUNCTIONMomentary
Key withdrawable in
position 0
Spring-returnACTUATOR TYPEKeyNUMBER OF SWITCH
POSITIONS3

Design verification

EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID	0 W
HEAT DISSIPATION CAPACITY PDISS	0 W
HEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID	0 W
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	0 A
STATIC HEAT DISSIPATION, NON- CURRENT-DEPENDENT PVS	0 W
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Please enquire
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to

Communication

CONNECTION TO SMARTWIRE-DT

No

250 V

24 V

	be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	Is the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	ls the panel builder's responsibility.
10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH	ls the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	ls the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	ls the panel builder's responsibility.
10.10 TEMPERATURE RISE	Not applicable.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Resources

CATALOGUES	eaton-pushbuttons-signal- towers-sensors- assortment-overview- catalog-ca047003en-en- us.pdf eaton-rmq-titan-brochure- br047004en-en-us.pdf
DECLARATIONS OF	DA-DC-00004158.pdf
CONFORMITY	DA-DC-00004136.pdf
DRAWINGS	<u>eaton-operating-rmq16-</u> <u>key-operated-actuator-</u> <u>dimensions.eps</u>
ECAD MODEL	ETN.046844.edz
INSTALLATION INSTRUCTIONS	<u>IL04716016Z</u>
	DA-CD-schluessel_25
MCAD MODEL	DA-CS-schluessel_25

PROJECT NAME:

PROJECT NUMBER:

PREPARED BY:

DATE:



Eaton Corporation plc Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.

