Specifications



Eaton 046850

Eaton Moeller® series RMQ16 Key-operated actuator, 3 positions, white, momentary Q18S3-WS

General specifications	
PRODUCT NAME	Eaton Moeller® series RMQ16 Key-operated actuator
CATALOG NUMBER	046850
EAN	4015080468509
PRODUCT LENGTH/DEPTH	50 mm
PRODUCT HEIGHT	18 mm
PRODUCT WIDTH	18 mm
PRODUCT WEIGHT	0.02 kg
CERTIFICATIONS	CE UL UL Category Control No.: NKCR UL File No.: E29184 UL 508 IEC/EN 60947-5 CSA Class No.: 3211-03 CSA-C22.2 No. 14-05 CSA CSA File No.: 46552 IEC/EN 60947
MODEL CODE	Q18S3-WS



Features & Functions	
BEZEL COLOR	Black
BEZEL MATERIAL	Plastic
DESIGN	Key operated
FITTED WITH:	Front ring

General	
ACCESSORIES	1 key included with supplied equipment.
DEGREE OF PROTECTION	NEMA 1
DEGREE OF PROTECTION (FRONT SIDE)	IP65
LIFESPAN, MECHANICAL	3,000,000 Operations
OPENING DIAMETER	16 mm
OPERATING FREQUENCY	1800 Operations/h
OPERATING TORQUE	0.4 Nm
OVERVOLTAGE CATEGORY	III
POLLUTION DEGREE	3
PRODUCT CATEGORY	RMQ16
RATED IMPULSE WITHSTAND VOLTAGE (UIMP)	800 V AC
SIZE	Front dimensions: 18 x 18 mm
SWITCHING ANGLE	45 °
TERMINAL CAPACITY	0.5 - 1.0 mm ²
TERMINAL SIZE	2.8 x 0.8 mm to DIN 46247 and IEC 60760, Fast-on connectors 2.8 x 0.8 mm to DIN 46244, Blade terminal
ТҮРЕ	Key-operated button

Ambient conditions, mechanical	
MOUNTING POSITION As required	
SHOCK RESISTANCE	Mechanical, According to IEC/EN 60068-2-27 40 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms

Climatic environmental conditions	
AMBIENT OPERATING TEMPERATURE - MIN	-25 °C
AMBIENT OPERATING TEMPERATURE - MAX	60 °C
AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN	25 °C
AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX	40 °C
CLIMATIC PROOFING	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78

Electrical rating	
RATED INSULATION VOLTAGE (UI)	250 V
RATED OPERATIONAL VOLTAGE (UE) AT AC - MAX	24 V

Actuator	
ACTUATOR COLOR	White
ACTUATOR FUNCTION	Momentary Spring-return Key withdrawable in position 0
ACTUATOR TYPE	Key
NUMBER OF SWITCH POSITIONS	3

Communication	
CONNECTION TO SMARTWIRE-DT	No

Design verification	
EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID	0 W
HEAT DISSIPATION CAPACITY PDISS	0 W
HEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID	0 W
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	0 A
STATIC HEAT DISSIPATION, NON- CURRENT-DEPENDENT PVS	0 W
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Please enquire
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to

	be evaluated.
	Meets the product
10.2.7 INSCRIPTIONS	standard's requirements.
10.3 DEGREE OF	Does not apply, since the
PROTECTION OF ASSEMBLIES	entire switchgear needs to be evaluated.
10.4 CLEARANCES AND	Meets the product
CREEPAGE DISTANCES	standard's requirements.
10.5 PROTECTION	Does not apply, since the
AGAINST ELECTRIC	entire switchgear needs to
SHOCK	be evaluated.
10.6 INCORPORATION OF	Does not apply, since the
SWITCHING DEVICES AND COMPONENTS	entire switchgear needs to be evaluated.
10.7 INTERNAL	25 0741441041
ELECTRICAL CIRCUITS	Is the panel builder's
AND CONNECTIONS	responsibility.
10.8 CONNECTIONS FOR	Is the panel builder's
EXTERNAL CONDUCTORS	responsibility.
10.9.2 POWER-	Is the panel builder's
FREQUENCY ELECTRIC STRENGTH	responsibility.
10.9.3 IMPULSE	La the a penal buildede
WITHSTAND VOLTAGE	Is the panel builder's responsibility.
10.9.4 TESTING OF	
ENCLOSURES MADE OF	Is the panel builder's responsibility.
INSULATING MATERIAL	responsibility.
10.10 TEMPERATURE RISE	Not applicable.
	Is the panel builder's
10.11 SHORT-CIRCUIT	responsibility. The
RATING	specifications for the switchgear must be
	observed.
	Is the panel builder's
10.12 ELECTROMAGNETIC	responsibility. The
COMPATIBILITY	specifications for the
	switchgear must be observed.
	The device meets the
40.42 MECHANICAL	The device meets the requirements, provided
10.13 MECHANICAL FUNCTION	

Resources	
	eaton-rmq-titan-brochure- br047004en-en-us.pdf
CATALOGUES	eaton-pushbuttons-signal- towers-sensors- assortment-overview- catalog-ca047003en-en- us.pdf
DECLARATIONS OF CONFORMITY	DA-DC-00004136.pdf DA-DC-00004158.pdf
DRAWINGS	eaton-operating-rmq16- key-operated-actuator- dimensions.eps
ECAD MODEL	ETN.046850.edz
INSTALLATION INSTRUCTIONS	<u>IL04716016Z</u>
MCAD MODEL	DA-CS-schluessel_18
	DA-CD-schluessel_18

PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	
DATE:	



Eaton Corporation plc

Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









