

Specifications



Photo is representative

Eaton 062149

Eaton Moeller® series RMQ16 Key-operated actuator, 3 positions, green, momentary Q18S3-GN

General specifications

PRODUCT NAME	Eaton Moeller® series RMQ16 Key-operated actuator
CATALOG NUMBER	062149
EAN	4015080621492
PRODUCT LENGTH/DEPTH	50 mm
PRODUCT HEIGHT	18 mm
PRODUCT WIDTH	18 mm
PRODUCT WEIGHT	0.02 kg
CERTIFICATIONS	CSA CE CSA-C22.2 No. 14-05 UL Category Control No.: NKCR UL CSA Class No.: 3211-03 CSA File No.: 46552 IEC/EN 60947 IEC/EN 60947-5 UL 508 UL File No.: E29184
MODEL CODE	Q18S3-GN

Features & Functions

BEZEL COLOR	Black
BEZEL MATERIAL	Plastic
DESIGN	Key operated
FITTED WITH:	Front ring

General

ACCESSORIES	1 key included with supplied equipment.
DEGREE OF PROTECTION	NEMA 1
DEGREE OF PROTECTION (FRONT SIDE)	IP65
LIFESPAN, MECHANICAL	3,000,000 Operations
OPENING DIAMETER	16 mm
OPERATING FREQUENCY	1800 Operations/h
OPERATING TORQUE	0.4 Nm
OVERVOLTAGE CATEGORY	III
POLLUTION DEGREE	3
PRODUCT CATEGORY	RMQ16
RATED IMPULSE WITHSTAND VOLTAGE (UIMP)	800 V AC
SIZE	Front dimensions: 18 x 18 mm
SWITCHING ANGLE	45 °
TERMINAL CAPACITY	0.5 - 1.0 mm ²
TERMINAL SIZE	2.8 x 0.8 mm to DIN 46244, Blade terminal 2.8 x 0.8 mm to DIN 46247 and IEC 60760, Fast-on connectors
TYPE	Key-operated button

Ambient conditions, mechanical

MOUNTING POSITION	As required
SHOCK RESISTANCE	40 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms Mechanical, According to IEC/EN 60068-2-27

Climatic environmental conditions

AMBIENT OPERATING TEMPERATURE - MIN	-25 °C
AMBIENT OPERATING TEMPERATURE - MAX	60 °C
AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN	25 °C
AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX	40 °C
CLIMATIC PROOFING	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78

Electrical rating

RATED INSULATION VOLTAGE (UI)	250 V
--------------------------------------	-------

RATED OPERATIONAL VOLTAGE (UE) AT AC - MAX	24 V
---	------

Communication

CONNECTION TO SMARTWIRE-DT	No
-----------------------------------	----

Actuator

ACTUATOR COLOR	Green
-----------------------	-------

ACTUATOR FUNCTION	Momentary Spring-return Key withdrawable in position 0
--------------------------	--

ACTUATOR TYPE	Key
----------------------	-----

NUMBER OF SWITCH POSITIONS	3
-----------------------------------	---

Design verification

EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID	0 W
---	-----

HEAT DISSIPATION CAPACITY PDISS	0 W
--	-----

HEAT DISSIPATION PER POLE, CURRENT-DEPENDENT PVID	0 W
--	-----

RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	0 A
--	-----

STATIC HEAT DISSIPATION, NON-CURRENT-DEPENDENT PVS	0 W
---	-----

10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
------------------------------------	--

10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
---	--

10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
---	--

10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
---	--

10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Please enquire
---	----------------

10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
-----------------------	--

10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to
---------------------------------	--

	be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	Is the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	Is the panel builder's responsibility.
10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH	Is the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	Is the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	Is the panel builder's responsibility.
10.10 TEMPERATURE RISE	Not applicable.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Resources

CATALOGUES	eaton-rmq-titan-brochure-br047004en-en-us.pdf
	eaton-pushbuttons-signal-towers-sensors-assortment-overview-catalog-ca047003en-en-us.pdf
DECLARATIONS OF CONFORMITY	DA-DC-00004158.pdf
	DA-DC-00004136.pdf
DRAWINGS	eaton-operating-rmq16-key-operated-actuator-dimensions.eps
ECAD MODEL	ETN.062149.edz
INSTALLATION INSTRUCTIONS	IL04716016Z
MCAD MODEL	DA-CS-schluessel_18
	DA-CD-schluessel_18

PROJECT NAME:

PROJECT NUMBER:

PREPARED BY:

DATE:



Eaton Corporation plc

Eaton House
30 Pembroke Road
Dublin 4, Ireland
Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.

