Specifications



Photo is representative

Eaton 062152

Eaton Moeller® series RMQ16 Key-operated actuator, 3 positions, green, maintained Q18S3R-GN

General specifications	
PRODUCT NAME	Eaton Moeller® series RMQ16 Key-operated actuator
CATALOG NUMBER	062152
EAN	4015080621522
PRODUCT LENGTH/DEPTH	50 mm
PRODUCT HEIGHT	18 mm
PRODUCT WIDTH	18 mm
PRODUCT WEIGHT	0.02 kg
CERTIFICATIONS	UL UL 508 CE CSA IEC/EN 60947-5 CSA Class No.: 3211-03 IEC/EN 60947 UL Category Control No.: NKCR UL File No.: E29184 CSA File No.: 46552 CSA-C22.2 No. 14-05
MODEL CODE	Q18S3R-GN



Features & Functions	
BEZEL COLOR	Black
BEZEL MATERIAL	Plastic
DESIGN	Key operated
FITTED WITH:	Front ring

General	
ACCESSORIES	1 key included with supplied equipment.
DEGREE OF PROTECTION	NEMA 1
DEGREE OF PROTECTION (FRONT SIDE)	IP65
LIFESPAN, MECHANICAL	3,000,000 Operations
OPENING DIAMETER	16 mm
OPERATING FREQUENCY	1800 Operations/h
OPERATING TORQUE	0.4 Nm
OVERVOLTAGE CATEGORY	Ш
POLLUTION DEGREE	3
PRODUCT CATEGORY	RMQ16
RATED IMPULSE WITHSTAND VOLTAGE (UIMP)	800 V AC
SIZE	Front dimensions: 18 x 18 mm
SWITCHING ANGLE	45 °
TERMINAL CAPACITY	0.5 - 1.0 mm²
	2.8 x 0.8 mm to DIN 46244, Blade terminal 2.8 x 0.8 mm to DIN 46247
TERMINAL SIZE	and IEC 60760, Fast-on connectors
TERMINAL SIZE	and IEC 60760, Fast-on

Ambient conditions, mechanical	
MOUNTING POSITION	As required
SHOCK RESISTANCE	40 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms Mechanical, According to IEC/EN 60068-2-27

Climatic environmental conditions

AMBIENT OPERATING TEMPERATURE - MIN	-25 °C
AMBIENT OPERATING TEMPERATURE - MAX	60 °C
AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN	25 °C
AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX	40 °C
CLIMATIC PROOFING	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78

Electrical rating

RATED INSULATION VOLTAGE (UI) RATED OPERATIONA

250 V

RATED OPERATIONAL VOLTAGE (UE) AT AC - 24 V MAX

Actuator	
ACTUATOR COLOR	Green
ACTUATOR FUNCTION	Key withdrawable in position 0 Maintained Switching function latching Key withdrawable in position 2
ACTUATOR TYPE	Кеу
NUMBER OF SWITCH POSITIONS	3

Communication	Design verification	
CONNECTION TO NO NO	EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID	0 W
	HEAT DISSIPATION CAPACITY PDISS	0 W
	HEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID	0 W
	RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	0 A
	STATIC HEAT DISSIPATION, NON- CURRENT-DEPENDENT PVS	0 W
	10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
	10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
	10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
	10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
	10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Please enquire
	10.2.5 LIFTING	Does not apply, since the entire switchgear needs to

	be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	ls the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	ls the panel builder's responsibility.
10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH	ls the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	ls the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	ls the panel builder's responsibility.
10.10 TEMPERATURE RISE	Not applicable.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Resources	
	<u>eaton-rmq-titan-brochure-</u> <u>br047004en-en-us.pdf</u>
CATALOGUES	<u>eaton-pushbuttons-signal-</u> <u>towers-sensors-</u>
	assortment-overview-
	<u>catalog-ca047003en-en-</u>
	<u>us.pdf</u>
DECLARATIONS OF	DA-DC-00004136.pdf
CONFORMITY	DA-DC-00004158.pdf
	eaton-operating-rmq16-
DRAWINGS	<u>key-operated-actuator-</u>
	dimensions.eps
ECAD MODEL	ETN.062152.edz
INSTALLATION INSTRUCTIONS	<u>IL04716016Z</u>
MCAD MODEL	DA-CS-schluessel_18
	DA-CD-schluessel_18

PROJECT NAME:

PROJECT NUMBER:

PREPARED BY:

DATE:



Eaton Corporation plc Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.

