## Specifications



## Eaton 088059

Eaton Moeller® series RMQ16 Indicator light, flush, white, +filament lamp, 24 V Q18LF-WS/WB

General specifications	
PRODUCT NAME	Eaton Moeller® series RMQ16 Indicator light
CATALOG NUMBER	088059
EAN	4015080880592
PRODUCT LENGTH/DEPTH	59 mm
PRODUCT HEIGHT	18 mm
PRODUCT WIDTH	18 mm
PRODUCT WEIGHT	0.009 kg
CERTIFICATIONS	CE IEC/EN 60947 UL IEC/EN 60947-5 UL Category Control No.: NKCR CSA File No.: 46552 UL 508 CSA CSA Class No.: 3211-03 CSA-C22.2 No. 14-05 UL File No.: E29184
MODEL CODE	Q18LF-WS/WB



Features & Functions	
BEZEL COLOR	Black
BEZEL MATERIAL	Plastic
DESIGN	Flat
FITTED WITH:	Front ring
LENS COLOR	White

General	
DEGREE OF PROTECTION	NEMA 1
DEGREE OF PROTECTION (FRONT SIDE)	IP65
OPENING DIAMETER	16 mm
OVERVOLTAGE CATEGORY	III
POLLUTION DEGREE	3
PRODUCT CATEGORY	RMQ16
RATED IMPULSE WITHSTAND VOLTAGE (UIMP)	800 V AC
SIZE	Front dimensions: 18 x 18 mm
TERMINAL CAPACITY	0.5 - 1.0 mm <sup>2</sup>
TERMINAL SIZE	2.8 x 0.8 mm to DIN 46244, Blade terminal 2.8 x 0.8 mm to DIN 46247 and IEC 60760, Fast-on connectors
ТҮРЕ	Indicator lights

Ambient conditions, mechanical	
MOUNTING POSITION	As required
SHOCK RESISTANCE	40 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms Mechanical, According to IEC/EN 60068-2-27

Climatic environmental conditions	
AMBIENT OPERATING TEMPERATURE - MIN	-25 °C
AMBIENT OPERATING TEMPERATURE - MAX	60 °C
AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN	25 °C
AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX	40 °C
CLIMATIC PROOFING	Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30

Electrical rating	
RATED INSULATION VOLTAGE (UI)	250 V
RATED OPERATIONAL VOLTAGE (UE) AT AC - MAX	24 V

Communication	
CONNECTION TO SMARTWIRE-DT	No

Design verification	
EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID	0 W
HEAT DISSIPATION CAPACITY PDISS	0 W
HEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID	0 W
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	0 A
STATIC HEAT DISSIPATION, NON- CURRENT-DEPENDENT PVS	1 W
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Please enquire
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.

Resources	
CATALOGUES	eaton-pushbuttons-signal- towers-sensors- assortment-overview- catalog-ca047003en-en- us.pdf
	eaton-rmq-titan-brochure- br047004en-en-us.pdf
DECLARATIONS OF	DA-DC-00004158.pdf
CONFORMITY	DA-DC-00004136.pdf
DRAWINGS	eaton-operating- pushbutton-rmq16- dimensions-002.eps eaton-operating-
	indication-rmq16- indicator-light-3d-drawing- 002.eps 116C076
ECAD MODEL	DA-CE-ETN.Q18LF-WS_WB
INSTALLATION INSTRUCTIONS	<u>IL04716016Z</u>
MCAD MODEL	DA-CD-leucht 18
MICAD MODEL	DA-CS-leucht_18
	CATALOGUES  DECLARATIONS OF CONFORMITY  DRAWINGS  ECAD MODEL INSTALLATION

Does not apply, since the entire switchgear needs to be evaluated.
ls the panel builder's responsibility.
Is the panel builder's responsibility.
Is the panel builder's responsibility.
ls the panel builder's responsibility.
Is the panel builder's responsibility.
The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
Is the panel builder's responsibility. The specifications for the switchgear must be observed.
Is the panel builder's responsibility. The specifications for the switchgear must be observed.
The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	
DATE:	



## **Eaton Corporation plc**

Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









