Miniature Switches and Pilot lights

# 



Bright illumination face and snap-action switching.







• See website for details on approvals and standards.

Hole Size		Model	Function	Degree of Protection
ø12		AL2	Illuminated Pushbuttons Momentary Maintained Pilot Light	IP65
	AB2	Pushbuttons Momentary Maintained	IP40 (IEC60529)	
<b>410</b>		AL1	Illuminated Pushbuttons Momentary Maintained Pilot Light	IP40
ø10	AB1	Pushbuttons Momentary Maintained	(IEC60529)	
a0		AL8	Illuminated Pushbuttons Momentary Maintained Pilot Light	IP40
Ø8	AB8	Pushbuttons Momentary Maintained	(IEC60529)	

# Ø12 A2 / Ø10 A1 / Ø8 A8 Series Miniature Pilot Lights

### Bright illumination face and snap-action switching. 22 mm short body.

#### **Contact Ratings (Contact Block)**

Rated Insulation	n Voltage	250V				
Rated Thermal	Current	3A				
Operating Volta	age (AC/DC)	24V	110V	220V		
AC 50/60 Hz	Resistive Load	_	1.0A	0.5A		
AC 30/60 HZ	Inductive Load	_	0.7A	0.5A		
DC	Resistive Load	1.0A	0.2A	_		
DC	Inductive Load	0.7A	0.1A	_		
Contact Materi	al	Silver				

 Minimum applicable load: 5V AC/DC, 3 mA (applicable range may vary with operating conditions and load types)

#### Weight (Example)

Weight (approx.)	A2 Series	4g (AL2M-M11, AL2M-P1, AB2M-M1)		
	A1 Series	3g (AL1M-M11, AL1M-P1, AB1M-M1)		
	A8 Series	2g (AL8M-M11, AL8M-P1, AB8M-M1)		

#### **Specifications**

Operating To	emperature	-25 to +55°C (no freezing)					
Storage Temperature		-30 to +80°C (no freezing)					
Operating H	umidity	45 to 85% RH (no condensation)					
Contact Res	istance	50 mΩ maximum (initial value)					
Insulation R	esistance	100 MΩ minimum (500V DC megger)					
Dielectric Strength Switch Unit		Between live and dead metal parts: 2,000V AC, 1 minute Between terminals of different poles: 2,000V AC, 1 minute Between terminals of the same pole: 1,000V AC, 1 minute Between contact and lamp terminals: 1,500V AC, 1 minute					
	Illumination Unit	Between live part and ground: 2,000V AC, 1 minute					
Vibration Re	sistance	Damage limits, Operating extremes: 5 to 55 Hz, amplitude 0.75 mm					
Shock Resistance		Damage limits: 500 m/s² (50G) Operating extremes: 200 m/s² (20G)					
Mechanical Durability (minimum operations)		Momentary: 200,000 operations Maintained: 100,000 operations					
Electrical Durability (minimum operations)		Momentary: 100,000 operations Maintained: 50,000 operations (Switching frequency 1200 operations/h)					
Degree of P	rotection (*1)	IP40, IP65 (IEC 60529)					


<sup>\*1)</sup> IP65: A2 series only

# **LED Lamp Ratings (LAD-S)**

Rated Current	20 mA						
Built-in LED Part No.	LAD-SRN	LAD-SGN	LAD-SAN	LAD-SJWN			
Lamp Base	Exclusive for A series						
Forward Voltage (Vf) (nominal)	2.0V	2.9V	2.0V	2.7V			
Reverse Voltage (Vr)	4V						
Illumination Color	R	G	AG	JW			
LED Lamp Color	Red clear	Green clear	Amber clear	White diffused			
Applicable Lens Color	Red (R)	Green (G)	Amber (A)	Yellow (Y) / Pure white (JW)			
LED Lamp Life (reference value)	Approx. 50,000 hours (The illun	ninance reduces to 50% of the in	itial intensity when used on co	mplete DC.)			
Operating Voltage & External	5V DC: 150Ω, 0.5W						
Current-limiting Resistor	6V DC: 200Ω, 0.5W						
(recommended value)	12V DC: 510Ω, 0.75W						
(Note)	24V DC: 1.1 kΩ, 0.75W						
Internal Circuit	(+) O————————————————————————————————————						

Note: When LED lamps are used on voltages other than the above, external resistor value R is determined by the following formula: R = (operating voltage - Vf) / If

LED lamps do not have a current-limiting resistor, and external resistors of recommended values for each voltage
must be provided. Connect a current-limiting resistor in series, otherwise LED lamps will be damaged. Because no
protection diode is contained, ensure the correct polarity is observed.



Control Boxes Emergency Stop Switches Enabling Switches Safety Products **Explosion Proof** Relays & Sockets Circuit Protectors Power Supplies LED Illumination Controllers Operator Sensors AUTO-ID

Flush Silhouette
ø16
ø22
ø30
Miniature

Pilot Lights

HW1Z AP22

A Series

Control Boxes Emergency Stop Switches Enabling Switches Safety Products **Explosion Proof** Terminal Blocks Relays & Sockets Circuit Protectors **Power Supplies** LED Illumination Controllers Operator Interfaces Sensors AUTO-ID

Flush Silhouette

ø16

ø22

ø30

Pilot Lights

HW1Z AP22

LD6A


#### ø12 A2 Series Illuminated Pushbuttons & Pilot Lights

Quantity: 1


			Par	t No.		LED Lamp
Shape	Operation	Contact	IP40	IP65	② Lens Color Code	Part No., Rated Current (External Resistor Recommended Value)
Round AL2M	Momentary	SPDT	AL2M-M112	AL2M-M11P2		
) · · · · · · · · · · · · · · · · · · ·	Womentary	DPDT	AL2M-M21②	AL2M-M21P2		
	Maintained	SPDT	AL2M-A11@	AL2M-A11P2		R: LAD-SRN G: LAD-SGN Y/JW: LAD-SJWN A: LAD-SAN  Rated Current: 20 mA  5V DC: 150Ω, 0.5W 6V DC: 200Ω, 0.5W 12V DC: 510Ω, 0.75W 24V DC: 1.1 kΩ, 0.75W
	Mamameu	DPDT	AL2M-A21②	AL2M-A21P②		
	Pilot Light	_	AL2M-P1②	AL2M-P1P2		
Square AL2Q	Momentary —	SPDT	AL2Q-M112	AL2Q-M11P2	Specify a color code in place of ② in the Part No.  R: red G: green Y: yellow A: amber JW:pure white	
<u> </u>		DPDT	AL2Q-M21②	AL2Q-M21P2		
	Maintained -	SPDT	AL2Q-A11@	AL2Q-A11P2		
		DPDT	AL2Q-A21②	AL2Q-A21P②		
	Pilot Light	_	AL2Q-P1②	AL2Q-P1P2	J JW.pure Writte	
Rectangular AL2H	Momentary	SPDT	AL2H-M112	AL2H-M11P2		24V DO. 1.1 Kt2, 0.75W
	Womentary	DPDT	AL2H-M212	AL2H-M21P2		
	Maintained	SPDT	AL2H-A11②	AL2H-A11P2		
		DPDT	AL2H-A21②	AL2H-A21P2		
	Pilot Light	_	AL2H-P1②	AL2H-P1P2		

- LED lamps do not have a current-limiting resistor. Connect a current-limiting resistor in series, otherwise LED lamps will be damaged.
- External current-limiting resistor is not necessary when an optional socket with built-in resistor is used (see B-383).
- AP2M series pilot lights (round bezel only) with built-in current-limiting resistors are also available.
- · Pilot lights are not CCC certifed.
- See B-386 for marking plate size and engraving area.

#### **Dimensions**




### **Terminal Arrangement**



SPDT has NC1, NO1, and C1 only.

# **Mounting Hole Layout**



Note: Determine mounting centers to ensure easy operation.

Control Boxes
Emergency
Stop Switches


#### **ø12 A2 Series Pushbuttons**

Quantity: 1


Chana	Button Style	Operation	Contact	Pa	rt No.	0-10-1
Shape	Button Style	Operation	Contact	IP40	IP65	Color Code ①②
Round	Button	Momentary	SPDT	AB2M-M1①	AB2M-M1P①	B: black
AB2M		Womentary	DPDT	AB2M-M2①	AB2M-M2P①	G: green R: red S: blue W: white
	Dutton	Maintained	SPDT	AB2M-A1①	AB2M-A1P①	
		Maintaineu	DPDT	AB2M-A21	AB2M-A2P①	Y: yellow
		Momentary	SPDT	AB2M-M1L <sup>2</sup>	AB2M-M1PL <sup>2</sup>	A: amber
	Lens	Wildingillary	DPDT	AB2M-M2L2	AB2M-M2PL2	G: green R: red
	Lens	Maintained	SPDT	AB2M-A1L2	AB2M-A1PL②	W: white
		Maintaineu	DPDT	AB2M-A2L2	AB2M-A2PL②	Y: yellow
Square		Momentary	SPDT	AB2Q-M1①	AB2Q-M1P①	B: black
AB2Q	Button	Williary	DPDT	AB2Q-M2①	AB2Q-M2P①	G: green R: red
	Dutton	Maintained	SPDT	AB2Q-A1①	AB2Q-A1P①	S: blue W: white
		Maintaineu	DPDT	AB2Q-A2①	AB2Q-A2P①	Y: yellow
	Lens -	Momentary	SPDT	AB2Q-M1L2	AB2Q-M1PL2	A: amber
			DPDT	AB2Q-M2L2	AB2Q-M2PL②	G: green R: red
		Maintainad	SPDT	AB2Q-A1L <sup>2</sup>	AB2Q-A1PL@	W: white
		Maintained	DPDT	AB2Q-A2L②	AB2Q-A2PL@	Y: yellow
Rectangular		Momentary	SPDT	AB2H-M1①	AB2H-M1P①	B: black
AB2H	Button	Willingthary	DPDT	AB2H-M2①	AB2H-M2P①	G: green R: red
	DULIOII	Maintained	SPDT	AB2H-A1①	AB2H-A1P①	S: blue W: white
		Maintaineu	DPDT	AB2H-A2①	AB2H-A2P①	Y: yellow
		Momentary	SPDT	AB2H-M1L <sup>2</sup>	AB2H-M1PL <sup>②</sup>	A: amber
	Long	womentary	DPDT	AB2H-M2L2	AB2H-M2PL②	G: green R: red
	Lens	Maintainad	SPDT	AB2H-A1L2	AB2H-A1PL②	W: white
	M	Maintained	DPDT	AB2H-A2L2	AB2H-A2PL②	Y: yellow

- $\bullet$  Specify a color code in place of  $\textcircled{\scriptsize 1}$  or  $\textcircled{\scriptsize 2}$  in the Part No.
- See B-386 for marking plate size and engraving area for illuminated lens type.

#### **Dimensions**




### **Terminal Arrangement**




SPDT has NC1, NO1, and C1 only.

#### **Mounting Hole Layout**

# Round/Square Units





Note: Determine mounting centers to ensure easy operation.

All dimensions in mm.



Round

(TOP)

ø14

Square

(TOP)

□14

Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit

Protectors

Power Supplies

Flush Silhouette

LED Illumination

Controllers

Operator
Interfaces

Sensors

AUTO-ID

ø22 ø30

ø16

Miniature

Pilot Lights

HW1Z AP22

A Series

# ø12 A2 Series Accessories

All dimensions in mm.

	APEM
Sv	Switches & Pilot Lights
	Control Boxes
	Emergency Stop Switches
	Enabling
Sc	Switches
"	Safety Products
	Explosion Proof
	Terminal Blocks
Sc	Relays & Sockets
	Circuit Protectors
	Power Supplies
	LED Illumination
	Controllers
	Operator Interfaces
	Sensors
	AUTO-ID
Те	
	Flush Silhouette
Dı	ø16
	ø22
	ø30
1	
`	Miniature
	Pilot Lights
М	

Shape	N	laterial	Part No.	Quantity	ity Remarks		Remarks		
Locking Ring Wrench  Metal (nickel-plated brass)		MT-002	1		• Used to tighten the locking ring when installing the A2 series into a panel.				
Switch Guard	00% onen	For round/ square unit	AL-K2	1	Degree of protection: IP40     Used to protect pushbuttons from				
	90° open	For rectangular unit	AL-KH2	1		inadvertent operation.  • See B-384 for dimensions. (remains 90° open)			
Socket	Solder Term	inal	AL-C2	1	• S	naps on th	ne rear of the A2 series.		
	PC Board Te	erminal	AL-C2V	1	4	•	for dimensions)		
Socket with Built-in Resistor		5V DC	AL-C21	1	lor	Blue	A current limiting resistor is contained, eliminating the need for external resistors.      When using the socket with a built-in resistor,		
	Solder Terminal	12V DC	AL-C23	1	Socket Bottom Color	Yellow	make sure that the continuous current is 1A maximum and the operating temperature is -25 to +40°C. In collective mounting, keep center-to center-spacing of 20 mm or more between		
		24V DC	AL-C24	1	Soc	Red	<ul> <li>adjacent units in consideration of built-in resistor heating.</li> <li>See B-384 for dimensions.</li> </ul>		
Terminal Cover	Nylon		AL-V2	10	When wiring the terminals, insert the lead wires into the cover holes before soldering.     Terminal cover is not attached and must be ordered separate.		before soldering.		
Dust Cover	① For roun	d units	AL-D2	1	When mounting the units with the dust covers installed, refer to				
	② For square units		AL-DQ2	1	• 0 <sub>1</sub> • M Fr	mounting hole layout on B-384.  Operating temperature: -10 to +55°C  Material Front part: Elastomer (transparent) Rear part: Polypropylene (black)  See B-384 for dimensions and mounting hole layout.			
	③ For rectangular units		AL-DH2	1					
Mounting Hole Plug  Nitryl rubber (black)		AL-B2	5	• De	Degree of protection: IP65				

HW1Z AP22


### **ø12 A2 Series Dimensions**

All dimensions in mm.

Panel Thickness 0.5 to 5

Rubber Gasket

#### **Switch Guard**



### For Rectangular Units (AL-KH2) 19.5 8.5 12.5 22.5 10

19 min.

### APEM

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

**Explosion Proof** 

Terminal Blocks Relays & Sockets

Circuit

Protectors

Power Supplies

LED Illumination

Controllers

Operator

Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø22

ø30

Pilot Lights


HW1Z AP22


LD6A


Determine mounting centers


#### Socket

(AL-C2, AL-C2V, AL-C2□)









**Terminal Arrangement** 


Lamp Terminal (–)

Lamp Terminal (+)

(TOP)

#### **Terminal Cover**


(AL-V2)



Note: When wiring the terminals, insert the lead wires into the terminal cover holes before soldering.

#### **Dust Cover**

**For Round Units** (AL-D2)



Waterproof Gasket







□20


For Square Units

(AL-DQ2)




#### For Rectangular Units (AL-DH2)






#### **Mounting Hole Centers** (Round Units, Square Units)







Note: to ensure easy operation.

# ø12 A2/ø10 A1/ø8 A8 Series Miniature Pilot Lights

# ø12 A2 Series Maintenance Parts

All dimensions in mm.

l	
	APEM
	Switches & Pilot Lights
L	Control Boxes
	Emergency Stop Switches
	Enabling Switches
	Safety Products
	Explosion Proof
Į.	Terminal Blocks
L	Relays & Sockets
	Circuit Protectors
	Power Supplies
L	LED Illumination
B	Controllers
	Operator Interfaces
H	Sensors
	AUTO-ID

Flush Silhouette
ø16

ø22 ø30

Miniature

Pilot Lights

HW1Z

AP22

Shape	Specification		Part No.	Quantity	Color Code ①②
Marking Plate	Round		AL2M-W		
	Square		AL2Q-W	5	White
	Rectangular		AL2H-W		
Lens Unit		Round	AL2M-LK1-@		
	For IP40 units	Square	AL2Q-LK1-2	2	
		Rectangular	AL2H-LK1-2		Specify a color code in place of ② in the Part No     A: amber     G: green
	For IP65 illuminated pushbuttons	Round	AL2M-LK2-②		
		Square	AL2Q-LK2-②		
		Rectangular	AL2H-LK2-2		R: red W: white
	For IP65 pilot lights	Round	AL2M-LK3-②	- 1	Y: yellow
		Square	AL2Q-LK3-2		
		Rectangular	AL2H-LK3-②		
Button Unit		Round	AB2M-BK1-①		
🏊 🐸 造	For IP40 pushbuttons	Square	AB2Q-BK1-①	2	• Specify a color code in place of ① in the Part No.
	Ι' Γ	Rectangular	AB2H-BK1-①		B: black G: green
		Round	<b>AB2M-BK2-</b> ①		R: red S: blue
	For IP65 pushbuttons	Square	AB2Q-BK2-①	1	W: white Y: yellow
		Rectangular	AB2H-BK2-①		1. yollow

Control Boxes Emergency Stop Switches Enabling Switches Safety Products **Explosion Proof** Terminal Blocks Relays & Sockets Circuit Protectors Power Supplies LED Illumination Controllers Operator Interfaces Sensors AUTO-ID

Flush Silhouette

ø16

ø22

ø30

Pilot Lights

HW1Z

AP22

LD6A


#### ø10 A1 Series Illuminated Pushbuttons & Pilot Lights

Quantity: 1


					Quantity: 1	
			Part No.		LED Lamp	
Shape	Operation	Contact	IP40	② Lens Color Code	Part No., Rated Current (External Resistor Recommended Value)	
Round AL1M	Momentary	SPDT	AL1M-M11②			
	Maintained	SPDT	AL1M-A112			
	Pilot Light	_	AL1M-P1②			
Square AL1Q	Momentary	SPDT	AL1Q-M11②	Specify a color code in place of ② in the Part No.	R: LAD-SRN G: LAD-SGN Y/JW: LAD-SJWN A: LAD-SAN Rated Current: 20 mA 5V DC: 150Ω, 0.5W 6V DC: 200Ω, 0.5W 12V DC: 510Ω, 0.75W 24V DC: 1.1 kΩ, 0.75W	
	Maintained	SPDT	AL1Q-A11@	R: red G: green Y: yellow		
	Pilot Light	_	AL1Q-P1②	A: amber JW:pure white		
Rectangular AL1H	Momentary	SPDT	AL1H-M11②			
	Maintained	SPDT	AL1H-A11②			
	Pilot Light	_	AL1H-P1②			

- LED lamps do not have a current-limiting resistor. Connect a current-limiting resistor in series, otherwise LED lamps will be damaged.
- AP1M series pilot lights (round bezel only) with built-in current-limiting resistor are also available.
- Pilot lights are not CCC certifed.
- See B-386 for marking plate size and engraving area.

#### **Dimensions**



Terminal Arrangement (bottom view)







**Round/Square Units** 



### **Mounting Hole Layout**





**Rectangular Units**  $0^{+0.2}$ 12 min. 16 min.

Note: Determine mounting centers to ensure easy operation.



Control Boxes Emergency Enabling Switches Safety Products **Explosion Proof** Terminal Blocks Relays & Sockets Circuit Protectors Power Supplies LED Illumination Controllers Operator Interfaces Sensors AUTO-ID

Flush Silhouette

ø16

ø22

ø30

Pilot Lights

HW1Z AP22

LD6A


# ø10 A1 Series Pushbuttons

Quantity: 1

	Shape	Button Style	Operation	Contact	Part No. IP40	Color Code ①②
	Round AB1M	Dutter	Momentary	SPDT	AB1M-M1①	B black G: green R: red
M S		Button	Maintained	SPDT	AB1M-A1①	S: blue W: white Y: yellow
s  y s		Lens	Momentary	SPDT	AB1M-M1L@	A: amber G: green R: red
s g s			Maintained	SPDT	AB1M-A1L②	W: white Y: yellow
s — f	Square AB1Q	Button	Momentary	SPDT	AB1Q-M1①	B black G: green R: red
s —		Button	Maintained	SPDT	AB1Q-A1①	S: blue W: white Y: yellow
t s		Lens	Momentary	SPDT	AB1Q-M1L②	A: amber G: green R: red
s — 1		Lond	Maintained	SPDT	AB1Q-A1L@	W: white Y: yellow
s r	Rectangular AB1H	Button	Momentary	SPDT	AB1H-M1①	B black G: green R: red
S S		Button	Maintained	SPDT	AB1H-A1①	S: blue W: white Y: yellow
J —		Lens	Momentary	SPDT	AB1H-M1L2	A: amber G: green R: red
e -		Lens		SPDT	AB1H-A1L②	W: white Y: yellow

- Specify a color code in place of ① or ② in the Part No.
- See B-386 for marking plate size and engraving area for illuminated lens type.

#### **Dimensions**



Rectangular (TOP)

Round (TOP)


#### Terminal Arrangement (bottom view)




# Mounting Hole Layout

# Round/Square Units

Square (TOP)





Note: Determine mounting centers to ensure easy operation.

# ø10 A1 Series Accessories

Shape		Material	Part No.	Quantity	Remarks	ot Lights
Locking Ring Wrench	Metal (nickel-plate	d brass)	MT-003	1	Used to tighten the locking ring when installing the A1 series into a panel.	APEM Switches
Switch Guard	00° onon	For round/square unit	AL-K1	1	Used to protect pushbuttons from inadvertent operation.     See B-389 for dimensions.	Pilot Ligh Control E
	90° open	For rectangular unit	AL-KH1	1	(remains 90° open)	Stop Swi Enabling Switches
Socket	Solder Terminal  PC Board Terminal		AL-C1	1	Snaps on the rear of the A1 series. (see B-389 for dimensions)	Safety Pr Explosion
			AL-C1V	1		Terminal
Terminal Cover	Nylon		AL-V1	10	When wiring the terminals, insert the lead wires into the terminal cover holes before soldering.     Terminal cover is not attached and must be ordered separately.	Relays & Circuit Protector Power Su
Mounting Hole Plug  Nitryl rubber (black)		AL-B1	5	Degree of protection: IP65      Output     Output	Operator Interface Sensors AUTO-ID	

Boxes

ncy itches

roducts

upplies

nination

Flush Silhouette

ø16

ø22 ø30

Pilot Lights

HW1Z

AP22

Control Boxes Emergency Stop Switches

Safety Products

**Explosion Proof** 

Terminal Blocks Relays & Sockets


Enabling Switches

#### **ø10 A1 Series Dimensions**


All dimensions in mm.


#### **Switch Guard**

For Round/Square Units (AL-K1)




For Rectangular Units (AL-KH1)






Socket (AL-C1, AL-C1V)



33 17 **PC Board Terminal** (AL-C1V)

 $\underline{\text{Terminal } 0.8 \times 0.3t}$ 



**Mounting Hole Layout)** 

**Terminal Arrangement** NO. COM Lamp Lamp Terminal (–) (Bottom View)

Power Supplies LED Illumination

Circuit

Protectors

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette


ø16 ø22 ø30

Pilot Lights

HW1Z AP22

LD6A

**Terminal Cover** 



When wiring the terminals, insert the lead wires into the terminal cover holes before soldering.

#### ø10 A1 Series Maintenance Parts

Shape		Part No.	Quantity	Color Code ①②
Marking Plate	Round	AL1M-W		
	Square	AL1Q-W	5	White
	Rectangular	AL1H-W		
Lens Unit	Round	AL1M-LK1-②		Charify a color code in place of @ in the Part No.
	Square	AL1Q-LK1-②		Specify a color code in place of ② in the Part No. A (amber), G (green), R (red)
	Rectangular	AL1H-LK1-②	2	W (white), Y (yellow)
Button Unit	Round	AB1M-BK1-①	2	Charify a color code in place of (1) in the Part No.
	Square	AB1Q-BK1-①		Specify a color code in place of ① in the Part No.  B (black), G (green), R (red)
	Rectangular	AB1H-BK1-①		S (blue), W (white), Y (yellow)


#### ø8 A8 Series Illuminated Pushbuttons & Pilot Lights

Quantity: 1


					Quantity. 1	<del></del>
			Part No.		LED Lamp	t Lights
Shape	Operation	Contact	IP40	② Lens Color Code	Part No., Rated Current (External Resistor Recommended Value)	hts
Round AL8M	Momentary	SPDT	AL8M-M112			APEM
						Switches & Pilot Lights
	Maintained	SPDT	AL8M-A112			Control Boxes
				_		Emergency Stop Switches
	Pilot Light	_	AL8M-P1②			Enabling Switches
Square					R: LAD-SRN	Safety Products
AL8Q	Momentary	SPDT	AL8Q-M112	Part No.   A: LAD-SAN   R: red   Rated Current: 2: G: green   Y: yellow   5V DC: 150Ω, 0	Y/JW: LAD-SJWN	Explosion Proof
						Terminal Blocks
	Maintained	SPDT	AL8Q-A11②		Rated Current: 20 mA  5V DC: 150Ω, 0.5W  6V DC: 200Ω, 0.5W  12V DC: 510Ω, 0.75W  24V DC: 1.1 kΩ, 0.75W	Relays & Sockets
	Pilot Light		AL 00 D4 @			Circuit Protectors
	Filot Light	_	AL8Q-P1②	JW:pure white		Power Supplies
Rectangular AL8H	Momentary	SPDT	AL8H-M112		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	LED Illumination
						Controllers
	Maintained	SPDT	AL8H-A11@			Operator Interfaces
				-		Sensors
	Pilot Light	_	AL8H-P1②			AUTO-ID

- LED lamps do not have a current-limiting resistor. Connect a current-limiting resistor in series, otherwise LED lamps will be damaged.
- AP8M series pilot lights (round bezel only) with built-in current-limiting resistor are also available.
- Pilot lights are not CCC certified.
- See B-386 for marking plate size and engraving area.

#### **Dimensions**



#### **Terminal Arrangement**



#### **Mounting Hole Layout**

Ø8\*0.2 EE BO 9 min.

**Round/Square Units** 

Ø8\*02

12 min.

**Rectangular Units** 

lote: Determine mounting centers to ensure easy operation.

All dimensions in mm.

Flush Silhouette

ø16

ø22

ø30

Pilot Lights

HW1Z

AP22

A Series

Control Boxes Emergency Enabling Switches Safety Products **Explosion Proof** Terminal Blocks Relays & Sockets Circuit Protectors Power Supplies LED Illumination Controllers Operator Interfaces Sensors AUTO-ID

#### **ø8 A8 Series Pushbuttons**

Quantity: 1

Chana	Putton Ctulo	Operation	Contact	Part No.	Quantity. 1
Shape	Button Style	Орегация	Contact	IP40	Color Code ①②
Round AB8M	Button	Momentary	SPDT	AB8M-M1①	B black G: green R: red
	Button	Maintained	SPDT	AB8M-A1①	S: blue W: white Y: yellow
	Lens	Momentary	SPDT	AB8M-M1L②	A: amber G: green R: red
	25.15	Maintained	SPDT	AB8M-A1L②	W: white Y: yellow
Square AB8Q	Button	Momentary	SPDT	AB8Q-M1①	B black G: green R: red
	Button	Maintained	SPDT	AB8Q-A1①	S: blue W: white Y: yellow
	Lens	Momentary	SPDT	AB8Q-M1L@	A: amber G: green R: red
		Maintained	SPDT	AB8Q-A1L②	W: white Y: yellow
Rectangular AB8H	Button	Momentary	SPDT	AB8H-M1①	B black G: green R: red
	Duttoli	Maintained	SPDT	AB8H-A1①	S: blue W: white Y: yellow
	Lens	Momentary	SPDT	AB8H-M1L②	A: amber G: green R: red
	Lens N	Maintained	SPDT	AB8H-A1L②	W: white Y: yellow

Flush Silhouette

ø22

ø16

ø30

Pilot Lights

HW1Z


AP22
A Series

LD6A

 $\bullet$  Specify a color code in place of  $\ensuremath{\mathfrak{I}}$  or  $\ensuremath{\mathfrak{D}}$  in the Part No.

• See B-386 for marking plate size and engraving area for illuminated lens type.

#### **Dimensions**



Rectangular (TOP)

Square (TOP)

Ø9


Round (TOP)

#### Terminal Arrangement (bottom view)



# **Mounting Hole Layout**

**Round/Square Units** 



08 + 02 EE 00 12 min.

**Rectangular Units** 

Note: Determine mounting centers to ensure easy operation.

# ø8 A8 Series Accessories

All dimensions in mm.

Shape	Material		Part No.	Quantity	Remarks	ot Lights
Locking Ring Wrench	Metal (nickel	I-plated brass)	MT-004	1	Used to tighten the locking ring when installing the A8 series into a panel.	)hts
55						APEM
Switch Guard		For round/square	AL-K8	1	Used to protect pushbuttons from inadvertent operation.	Switches & Pilot Lights
1850 BEG	90° open	Unit	AL NO	1	See B-393 for dimensions.	Control Boxes
	90 Open	For rectangular unit	AL-KH8	1	(remains 90° open)	Emergency Stop Switches
		101 rectangular unit	AL-NIIO	'	(contains of open)	Enabling Switches
Socket	Solder Termi	inal	AL-C8	1	Snaps on the rear of the A8 series. (see B-393 for dimensions)	Safety Products
Trans.	Soluei lettiililai		AL UU	'	(See D-333 for dimensions)	Explosion Proof
W	PC Board Terminal		AL-C8V	1		Terminal Blocks
o c	TO Board 101	minai	AL OUV	'		Relays & Sockets
Terminal Cover					When wiring the terminals, insert the lead wires into the terminal cover holes before soldering.	Circuit Protectors
	Nylon	Nylon		10	Terminal cover is not attached and must be ordered	Power Supplies
	,				separately.	LED Illumination
						Controllers
Mounting Hole Plug		Nitryl rubber (black)			Degree of protection: IP65	Operator Interfaces
	Nitryl rubber			5		Sensors
						AUTO-ID

Flush Silhouette ø16

ø22

ø30

Miniature

Pilot Lights

HW1Z

AP22

Control Boxes

Emergency Stop Switches Enabling

Switches

Safety Products

**Explosion Proof** 

Terminal Blocks

Relays & Sockets

LED Illumination

Circuit


Protectors
Power Supplies

#### **ø8 A8 Series Dimensions**


All dimensions in mm.

#### Switch Guard

For Round/Square Units (AL-K8)




For Rectangular Units (AL-KH8)




#### Socket

(AL-C8, AL-C8V)



PC Board Terminal (AL-C8V)

Terminal  $0.8 \times 0.3t$ 



Mounting Hole Layout)

Terminal Arrangement
(TOP)

NC
D
D
D
D
D
Lamp
Terminal (+)


(Bottom View)

**Terminal Cover** 

Controllers

Operator Interfaces

Sensors AUTO-ID (AL-V8)



Note: When wiring the terminals, insert the lead wires into the terminal cover holes before soldering.

#### ø8 A8 Series Maintenance Parts

All dimensions in mm

Shape		Part No.	Quantity	Color Code ①②
Marking Plate	Round	AL8M-W		
	Square	AL8Q-W	5	White
	Rectangular	AL8H-W		
Lens Unit	Round	AL8M-LK1-2		Consider a solar code in place of @ in the Doub No.
	Square	AL8Q-LK1-②		Specify a color code in place of ② in the Part No.  A (amber), G (green), R (red)  W (white), Y (yellow)
	Rectangular	AL8H-LK1-2	2	w (wille), 1 (yellow)
Button Unit	Round	AB8M-BK1-①	2	Consider a solar and a in place of (2) in the Doub No.
	Square	AB8Q-BK1-①		Specify a color code in place of ① in the Part No.  B (black), G (green), R (red)
	Rectangular	AB8H-BK1-①		S (blue), W (white), Y (yellow)

Flush Silhouette

ø16

ø22

ø30

Miniature

Pilot Lights

HW1Z

AP22

# A2/A1/A8 Series Accessories

All dimensions in mm.

Shape	Material	Part No.	Quantity	Remarks
Lens Removal Tool				
60.0	Stainless Steel	MT-101	1	Used to remove the lens and button.
Lamp Holder Tool	Rubber	OR-66	1	Used to remove and install the LED lamps.

# A2/A1/A8 Series Maintenance Parts

All dimensions in mm.

							1 -
Shape		Part No.	Quantity			Remarks	١.
LED Lamp	Illumination color: red	LAD-SRN	10		Red	LED color: red clear	-
	Illumination color: green	LAD-SGN	10	color	Green	LED color: green clear	-
9 0.48	Illumination color: amber	LAD-SAN	10	Lens	Amber	LED color: amber clear	-
Current-limiting resistor is not contained.	Illumination color: pure white	LAD-SJWN	10		White/ Yellow	LED color: white diffused	-

APEM

Switches &

Control Boxes

Emergency Stop Switches

Enabling Switches Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers
Operator

Sensors

AUTO-ID

Flush Silhouette

ø16

ø22

ø30

Pilot Lights

HW1Z

AP22

A Series

#### **Safety Precautions**

- Turn off the power to A series before starting installation, removal, wiring, maintenance, and inspection of the units. Failure to turn power off may cause electrical shocks or fire hazard.
- To avoid burning your hand, use the lamp holder tool when replacing lamps.
- For wiring, use wires of a proper gauge to meet the voltage and current requirements. Failure to tighten terminal screws may cause overheating and create a fire hazard.

APEM

#### Pilot Lights

Control Boxes

Emergency Stop Switches

Switches
Safety Products

Enabling

Explosion Proof

Terminal Blocks

Relavs & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø22

ø30

Miniature

Pilot Lights

HW1Z

AP22

LD6A

#### **Operating Instructions**


#### Replacement of Lens and Marking Plate

#### Removal


Remove the lens assembly (color lens, marking plate, lens holder, and spring) by holding the color lens recesses with the Lens Removal Tool (MT-101) and pulling it out. Remove the marking plate by disengaging the latches between the color lens and lens holder.

The marking plate must be engraved on the front side as shown below.

A2 Series



A8, A1 Series



Note: Make sure that the spring is inserted in the correct direction. The base of spring must fit the groove in the holder.

#### Installation

Place the marking plate on the lens holder in the correct direction, and press the color lens onto the lens holder to engage the latches. Put the spring on the lens holder and insert the lens holder into the housing in the correct direction.

#### Installing Non-illuminated Button

Non-illuminated pushbuttons contain the same marking plate as illuminated units. Be sure to install the marking plate when replacing the button.


#### Replacing the LED Lamp

#### Removal

Use the lamp holder tool (OR-66) to remove lamps. Do not use pliers.

#### Installation

Use the lamp holder tool (OR-66) to install lamps. Note the correct side of the tool for removal or installation.



#### **Panel Mounting**

When mounting the units into a panel, use the optional locking ring wrench (MT-002/-003/-004) to tighten the locking ring. Do not use pliers. Tightening torque must not exceed 0.78 N·m (A8, A1 series : 0.29 N·m). Excessive tightening will damage the locking ring.

### Wiring

Solder the terminal at 350°C within 3 seconds using a 60W soldering iron. Sn-Ag-Cu is recommended when using lead-free solder. When soldering, do not touch the unit with the soldering iron. Also ensure that no tensile force is applied to the terminal. Do not bend the terminal or apply excessive force to the terminal.

Use non-corrosive rosin flux.

#### Installing the Socket

Install the socket on the unit with the TOP markings on the unit and the socket placed in the same direction.

#### Operating Voltage of LED Lamps

The operating voltage is measured at complete DC. When using a pulsating voltage such as a full-wave rectification voltage, keep peak currents within the forward current If. Peak currents exceeding the If may shorten the LED lamp life.

#### **Operating Instructions**

#### Marking

For A series illuminated pushbuttons, legends and symbols can be engraved on the built-in marking plates, or printed film can be inserted under the lens.

#### Marking Plate & Engraving Area

#### **A2 Series**

Lens	Round	Square	Rectangular
Built-in Marking Plate	Engraving Area	Engraving; Area  Size: □10	Engraving Area  12  Size: 14 x 10
Ba		ide on the engraving area nade of white acrylic resin	·

#### A1 Series

Lens	Round	Square	Rectangular
Built-in Marking Plate	Engraving Area 7.5	Engraving: Area  20  17.5  Size: □8.5	Engraving Area  11.5  Size: 12.5 x 8.5
Bu	• •	de on the engraving area l	ess than 0.5mm deep.

#### **A8 Series**

Lens	Round	Square	Rectangular
Built-in Marking Plate	Engraving Area  Size: 96.1	Engraving: Area  5  Size: □6.1	Engraving Area  8  Size: 9.1 x 6.1
Bu	Engraving must be made on the engraving area less than 0.5mm deep.     The marking plate is made of white acrylic resin.		

#### **Other Notes**

#### **Close Proximity Mounting**

When mounting pilot lights or illuminated pushbuttons collectively or lighting them continuously, heat may cause the ambient temperature to rise above the rated operating temperature. When the mounting panel is not made of metal or when the units are mounted in an enclosed panel, provide for ventilation or lower the operating voltage.

#### Replacement of Buttons (Illuminated/Non-illuminated)

Do not replace buttons of maintained action units while the button is in the locked position. Replacing the button in the locked position may damage the internal mechanism. Be sure to release the button before replacing.

#### **Operating and Storage Environment**

- Make sure that the operating/storage temperature and humidity are within the ratings.
- Do not use enclosed type units in an environment subject to oil, water or dust accumulation.

#### **Microswitch Contacts**

Do not connect NO and NC contacts of the microswitch to different voltages or different power sources to prevent a dead short-circuit.

#### IP65 Units (A2 series only)

IP65 units are evaluated by conventional cutting and cooling oils, and can not be used with some special oils. Contact IDEC for resistance against special oils.

APEM

Switches & Pilot Lights

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø22

ø30

Pilot Lights

HW1Z AP22

A Spring

## **Ordering Terms and Conditions**

Thank you for using IDEC Products.

By purchasing products listed in our catalogs, datasheets, and the like (hereinafter referred to as "Catalogs") you agree to be bound by these terms and conditions. Please read and agree to the terms and conditions before placing your order.

#### 1. Notes on contents of Catalogs

- (1) Rated values, performance values, and specification values of IDEC products listed in this Catalog are values acquired under respective conditions in independent testing, and do not guarantee values gained in combined
  - Also, durability varies depending on the usage environment and usage
- (2) Reference data and reference values listed in Catalogs are for reference purposes only, and do not guarantee that the product will always operate appropriately in that range.
- (3) The specifications / appearance and accessories of IDEC products listed in Catalogs are subject to change or termination of sales without notice, for improvement or other reasons.
- (4) The content of Catalogs is subject to change without notice.

#### 2. Note on applications

- (1) If using IDEC products in combination with other products, confirm the applicable laws / regulations and standards.
  - Also, confirm that IDEC products are compatible with your systems, machines, devices, and the like by using under the actual conditions. IDEC shall bear no liability whatsoever regarding the compatibility with IDEC products.
- (2) The usage examples and application examples listed in Catalogs are for reference purposes only. Therefore, when introducing a product, confirm the performance and safety of the instruments, devices, and the like before use. Furthermore, regarding these examples, IDEC does not grant license to use IDEC products to you, and IDEC offers no warranties regarding the ownership of intellectual property rights or non-infringement upon the intellectual property rights of third parties.
- (3) When using IDEC products, be cautious when implementing the following.
  - Use of IDEC products with sufficient allowance for rating and performance
  - Safety design, including redundant design and malfunction prevention design that prevents other danger and damage even in the event that an IDEC product fails
  - Wiring and installation that ensures the IDEC product used in your system, machine, device, or the like can perform and function according to its specifications
- (4) Continuing to use an IDEC product even after the performance has deteriorated can result in abnormal heat, smoke, fires, and the like due to insulation deterioration or the like. Perform periodic maintenance for IDEC products and the systems, machines, devices, and the like in which they are used.
- (5) IDEC products are developed and manufactured as general-purpose products for general industrial products. They are not intended for use in the following applications, and in the event that you use an IDEC product for these applications, unless otherwise agreed upon between you and IDEC, IDEC shall provide no guarantees whatsoever regarding IDEC products.
  - Use in applications that require a high degree of safety, including nuclear power control equipment, transportation equipment (railroads / airplanes / ships / vehicles / vehicle instruments, etc.), equipment for use in outer space, elevating equipment, medical instruments, safety devices, or any other equipment, instruments, or the like that could endanger life or human health
  - ii. Use in applications that require a high degree of reliability, such as provision systems for gas / waterworks / electricity, etc., systems that operate continuously for 24 hours, and settlement systems
  - Use in applications where the product may be handled or used deviating from the specifications or conditions / environment listed in the Catalogs. such as equipment used outdoors or applications in environments subject to chemical pollution or electromagnetic interference If you would like to use IDEC products in the above applications, be sure to consult with an IDEC sales representative.

#### 3. Inspections

We ask that you implement inspections for IDEC products you purchase without delay, as well as thoroughly keep in mind management/maintenance regarding handling of the product before and during the inspection.

#### 4. Warranty

(1) Warranty period

The warranty period for IDEC products shall be one (1) year after purchase or delivery to the specified location. However, this shall not apply in cases where there is a different specification in the Catalogs or there is another agreement in place between you and IDEC.

#### (2) Warranty scope

Should a failure occur in an IDEC product during the above warranty period for reasons attributable to IDEC, then IDEC shall replace or repair that product, free of charge, at the purchase location / delivery location of the product, or an IDEC service base. However, failures caused by the following reasons shall be deemed outside the scope of this warranty.

- The product was handled or used deviating from the conditions / environment listed in the Catalogs
- The failure was caused by reasons other than an IDEC product
- Modification or repair was performed by a party other than IDEC
- The failure was caused by a software program of a party other than IDFC
- The product was used outside of its original purpose
- Replacement of maintenance parts, installation of accessories, or the like was not performed properly in accordance with the user's manual and
- vii. The failure could not have been predicted with the scientific and technical standards at the time when the product was shipped from
- viii. The failure was due to other causes not attributable to IDEC (including cases of force majeure such as natural disasters and other disasters) Furthermore, the warranty described here refers to a warranty on the IDEC product as a unit, and damages induced by the failure of an IDEC product are excluded from this warranty.

#### 5. Limitation of liability

The warranty listed in this Agreement is the full and complete warranty for IDEC products, and IDEC shall bear no liability whatsoever regarding special damages, indirect damages, incidental damages, or passive damages that occurred due to an IDEC product.

#### 6. Service scope

The prices of IDEC products do not include the cost of services, such as dispatching technicians. Therefore, separate fees are required in the following cases.

- (1) Instructions for installation / adjustment and accompaniment at test operation (including creating application software and testing operation, etc.)
- (2) Maintenance inspections, adjustments, and repairs
- (3) Technical instructions and technical training
- (4) Product tests or inspections specified by you

The above content assumes transactions and usage within your region. Please consult with an IDEC sales representative regarding transactions and usage outside of your region. Also, IDEC provides no guarantees whatsoever regarding IDEC products sold outside your region.

# **IDEC CORPORATION**

**Head Office** 6-64, Nishi-Miyahara-2-Chome, Yodogawa-ku, Osaka 532-0004, Japan  ☐ www.idec.com

USA **EMEA** 

**IDEC Corporation** APEM SAS

Singapore Thailand India

IDEC Izumi Asia Pte. Ltd IDEC Asia (Thailand) Co., Ltd. IDEC Controls India Private Ltd. China

IDEC (Shanghai) Corporation IDEC Hong Kong Co. Ltd. Taiwan **IDEC Taiwan Corporation** 

**IDEC** Corporation



