

1. Turn off and lock out the power supplying the load center before working inside.

2. All unused breaker twistout openings must be closed with filler plates.

3. To install filler plate, first place either side into trim opening, then push in on the opposite side until it snaps into place.

Siemens Industry, Inc. Norcross, Georgia U.S.A.

481000280101 Rev.A

The National Electrical Code is a registered trademark of the National Fire Protection Association.
2011 Copyright Siemens Industry, Inc.
Assembled in Mexico