SIEMENS

Data sheet

3VL7110-1KN30-0AA0

circuit breaker VL1200 UL; type NG (cat no. NNX3B100) non-interchangeable frame, with circuit breaker approval acc. to UL 489 standard breaking capacity 3-pole, NEMA rating 35kA/480V, (molded case circuit breaker) trip unit TM, LI TA=40°C In=< 1000A, rated current II=6000...10000A short-circuit protection IR=1000A ETU for line protection without connection accessories without auxiliary release without auxiliary/alarm switch

No
TM
3
3VL7 UL
3 000
1 500
A
N
Q
30 1/s
690 V
800 V
800 V
8 kV
690 V
600 V
690 V
600 V
690 V
IP20
LI
50 Hz
60 Hz
0
0
0
system protection
80 A
No
No
No
No

undervoltage release with leading contact	No		
product extension optional motor drive	Yes		
Product function			
product function			
of thermal overload trip unit	fixed		
grounding protection	No		
for neutral conductors short-circuit and overload proof	No		
overload protection	Yes		
Short circuit			
operating short-circuit current breaking capacity (lcs)			
at 240 V rated value	35 kA		
at 415 V rated value	25 kA		
at 690 V rated value	10 kA		
maximum short-circuit current breaking capacity (Icu)			
at 240 V rated value	65 kA		
at 415 V rated value	50 kA		
 at 480 V according to NEMA rated value 	35 kA		
 at 600 V according to NEMA rated value 	25 kA		
at 690 V rated value	20 kA		
Connections			
arrangement of electrical connectors for main current circuit	front side		
type of electrical connection for main current circuit	without connection accessoires	3	
Mechanical Design			
height	406.5 mm		
width	228.5 mm		
depth	333.5 mm		
fastening method	fixed mounting		
Environmental conditions			
ambient temperature during operation			
• minimum	0 °C		
maximum	70 °C		
ambient temperature during storage			
• minimum	-40 °C		
• maximum	80 °C		
General Product Approval		EMC	Declaration of Conformity

Miscellaneous

Confirmation









Declaration of Conformity

Test Certificates

Marine / Shipping

other

Environment



Special Test Certificate



Confirmation

Miscellaneous

Environmental Confirmations

Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)

 $\underline{https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3VL7110-1KN30-0AA0}$

Service&Support (Manuals, Certificates, Characteristics, FAQs,...) https://support.industry.siemens.com/cs/ww/en/ps/3VL7110-1KN30-0AA0

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams,) http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3VL7110-1KN30-0AA0
CAx-Online-Generator
http://www.siemens.com/cax
Tender specifications
http://www.siemens.com/specifications

12/23/2020

last modified: