NS53E-20 1/5



PRODUCT-DETAILS

NS53E-20

NS53E-20 24V50/60HZ Contactor Relay



General Information	
Extended Product Type	NS53E-20
Product ID	1SBH101001R2053
EAN	3471523006201
Catalog Description	NS53E-20 24V50/60HZ Contactor Relay
Long Description	NS contactor relays are used for switching auxiliary circuits and control circuits Poles: 8-pole contactor relays (mechanically-linked auxiliary contacts compliant with Annex L of IEC 60947-5-1 including the "Mechanically Linked" symbol on the contactor relay side) - Control circuit: AC operated with laminated magnet circuit - Accessories: a wide range of accessories is available.

Ordering	
Minimum Order Quantity	1 piece
Customs Tariff Number	85364900

Popular Downloads

Data Sheet, Technical 1SBC100214C0202

NS53E-20 2/5

Information	
Instructions and	
Manuals	

CAD Dimensional 2CDC001079B0201 Drawing

Dimensions	
Product Net Width	45 mm
Product Net Depth / Length	100.2 mm
Product Net Height	68 mm
Product Net Weight	0.26 kg

Technical	
Number of Auxiliary Contacts NO	5
Number of Auxiliary Contacts NC	3
Standards	IEC 60947-5-1 and EN 60947-5-1, UL 508, CSA C22.2 N°14
Rated Operational Voltage	Auxiliary Circuit 690 V Main Circuit 690 V
Rated Frequency (f)	Auxiliary Circuit 50 / 60 Hz
Conventional Free-air Thermal Current (I _{th})	acc. to IEC 60947-5-1, Θ = 40 °C 10 A
Rated Operational Current AC-15 (I _e)	(500 V) NC 2 (500 V) 2 A (690 V) 2 A (24 / 127 V) 6 A (220 / 240 V) 4 A (400 / 440 V) 3 A
Rated Operational Current DC-13 (I _e)	(24 V) 6 A / 144 W (48 V) 2.8 A / 134 W (72 V) 1 A / 72 W (110 V) 0.55 A / 60 W (125 V) 0.57 A / 69 W (220 V) 0.27 A / 60 W (250 V) 0.27 A / 68 W
Rated Short-time Withstand Current Low Voltage (I _{cw})	for 0.1 s 140 A for 1 s 100 A
Rated Insulation Voltage (U _i)	acc. to IEC 60947-5-1 and VDE 0110 (Gr. C) 690 V acc. to UL/CSA 600 V
Rated Impulse Withstand Voltage (U _{imp})	Auxiliary Circuit 6 kV
Maximum Electrical Switching Frequency	(AC-15) 1200 cycles per hour (DC-13) 900 cycles per hour
Maximum Mechanical Switching Frequency	3600 cycles per hour
Rated Control Circuit Voltage (U _c)	50 Hz 24 V 60 Hz 24 V
Operate Time	Between Coil De-energization and NC Contact Closing 7 22 ms Between Coil De-energization and NO Contact Opening 5 19 ms Between Coil Energization and NC Contact Opening 6 18 ms Between Coil Energization and NO Contact Closing 9 24 ms
Connecting Capacity Auxiliary Circuit	Flexible with Ferrule 1/2x 0.75 2.5 mm ² Flexible with Insulated Ferrule 1x 0.75 2.5 mm ² Flexible with Insulated Ferrule 2x 0.75 1.5 mm ² Rigid 1/2x 0.75 2.5 mm ²

1SBC101020M9701

NS53E-20 3/5

Connecting Capacity Control Circuit	Flexible with Ferrule 1/2x 0.75 2.5 mm² Flexible with Insulated Ferrule 1x 0.75 2.5 mm² Flexible with Insulated Ferrule 2x 0.75 1.5 mm² Rigid 1/2x 0.75 2.5 mm²
Wire Stripping Length	Auxiliary Circuit 9 mm Control Circuit 9 mm
Degree of Protection	acc. to IEC 60529, IEC 60947-1, EN 60529 Auxiliary Terminals IP20 acc. to IEC 60529, IEC 60947-1, EN 60529 Coil Terminals IP20
Tightening Torque	Auxiliary Circuit 1 N·m Control Circuit 1 N·m
Terminal Type	Screw Terminals
Product Name	Block Contactor Relay

Technical UL/CSA

Tightening Torque	Auxiliary Circuit 9 in lb
UL/CSA	Control Circuit 9 in-lb

Environmental	
Ambient Air Temperature	Close to Contactor for Storage -60 +80 °C Near Contactor for Operation in Free Air -40 70 °C
Climatic Withstand	Category B according to IEC 60947-1 Annex Q
Maximum Operating Altitude Permissible	Without Derating 3000 m
Resistance to Shock acc. to IEC 60068-2-27	Closed, Shock Direction: C1 19 g Closed, Shock Direction: C2 16 g Open, Shock Direction: C1 8 g Open, Shock Direction: C2 13 g Shock Direction: A 20 g Shock Direction: B1 5 g Shock Direction: B2 15 g
Resistance to Vibrations	3g Closed Position & 2g Open Position 5 300 Hz

Material Compliance	
Conflict Minerals Reporting Template (CMRT)	9AKK108467A5658
REACH Declaration	2CMT2021-006202
RoHS Information	2CMT2021-006277
RoHS Status	Following EU Directive 2011/65/EU and Amendment 2015/863 July 22, 2019
Toxic Substances Control Act - TSCA	2CMT2023-006525
WEEE B2C / B2B	Business To Business
WEEE Category	5. Small Equipment (No External Dimension More Than 50 cm)

Certificates and Declarations	
CB Certificate	CB_CN_32453
CCC Certificate	CCC_2007010305248106
CQC Certificate	CQC2007010305248106
Declaration of Conformity - CCC	2020980304001219
Declaration of Conformity - CE	1SBD250016U1000

NS53E-20 4/5

Declaration of Conformity - UKCA	1SBD250051U1000
GOST Certificate	GOST_POCCCNME77B07821.pdf
UL Certificate	UL_220108-E312527A
UL Listing Card	NOA_E312527.pdf

Container Information	
Package Level 1 Units	box 1 piece
Package Level 1 Width	72 mm
Package Level 1 Depth / Length	115 mm
Package Level 1 Height	48 mm
Package Level 1 Gross Weight	0.26 kg
Package Level 1 EAN	3471523006201
Package Level 2 Units	32 piece
Package Level 2 Width	250 mm
Package Level 2 Depth / Length	315 mm
Package Level 2 Height	195 mm
Package Level 2 Gross Weight	8.32 kg
Package Level 3 Units	768 piece

External Classifications and Standards	
Object Classification Code	К
ETIM 7	EC000196 - Contactor relay
ETIM 8	EC000196 - Contactor relay
ETIM 9	EC000196 - Contactor relay
eClass	V11.0 : 27371001
UNSPSC	39121529
IDEA Granular Category Code (IGCC)	4761 >> Magnet contactor, AC-switching

Categories

 $Low\ Voltage\ Products\ and\ Systems \rightarrow Control\ Products \rightarrow Contactors \rightarrow Block\ Contactors \rightarrow NS\ Contactor\ Relays \rightarrow NS\ Cont$

NS53E-20 5/5

