

PRODUCT-DETAILS

VBC7-30-01-F-07 VBC7-30-01-F-07 Mini Rev.Contactor 12VDC



General Information	
Extended Product Type	VBC7-30-01-F-07
Product ID	GJL1313903R0017
EAN	4013614404337
Catalog Description	VBC7-30-01-F-07 Mini Rev.Contactor 12VDC
Long Description	The VBC7-30-01-F mini reversing contactor is a compact 3 pole contactor with 1 auxiliary contact, flat pin connection and normal mechanical interlock. They are ideally suited for applications where reliability is a must and space is at a premium. Mini reversing contactors are used in residential buldings, commercial buildings and industrial applications for the control of three-phase motor loads up to 5.5 kW (AC-3). Further features are the noiseless and hum-free coil, a switch position indication and the integrated possibility for rail or wall mounting.
Ordering	
Minimum Order Quantity	1 piece
Customs Tariff Number	85365080
Popular Downloads	
Data Sheet, Technical Information	1SBC100214C0201
Instructions and Manuals	2CDC102046M6801
monacione ana manacio	20001020401110001

VBC7-30-01-F-07

Dimensions	
Product Net Width	96.2 mm
Product Net Height	57.5 mm
Product Net Depth / Length	46.7 mm
Product Net Weight	0.345 kg
Technical	
Number of Poles	3
Rated Operational Voltage	Auxiliary Circuit 690 V AC Auxiliary Circuit 250 V DC Main Circuit 690 V AC Main Circuit 220 V DC
Rated Frequency (f)	Main Circuit 60 Hz Main Circuit 50 Hz Main Circuit DC
Rated Impulse Withstand Voltage (U _{imp})	Main Circuit 6 kV
Rated Insulation Voltage (U _i)	690 V acc. to UL/CSA 600 V
Number of Main Contacts NC	0
Number of Main Contacts NO	3
Rated Operational Current AC-1 (I _e)	(220 / 240 V) 40 °C 20 A (220 / 240 V) 55 °C 16 A (380 / 440 V) 55 °C 20 A (380 / 440 V) 55 °C 16 A (690 V) 40 °C 6 A (690 V) 55 °C 6 A
Rated Operational Power AC-3 (P_e)	(230 V) Three Phase 3 kW (400 V) Three Phase 5.5 kW (500 V) Three Phase 5.5 kW (690 V) Three Phase, NO 3 kW
Rated Short-time Withstand Current Low Voltage (I _{cw})	at 40 °C Ambient Temp, in Free Air, from a Cold State 10 s 96 A
Number of Auxiliary Contacts NC	1
Number of Auxiliary Contacts NO	0
Conventional Free-air Thermal Current (I _{th})	Main Circuit 20 A
Rated Control Circuit Voltage (U _c)	12 V DC
Coil Operating Limits	(acc. to IEC 60947-4-1) for DC supply 0.85 1.1 x Uc (at $\theta \leq$ 55 °C)
Degree of Protection	Main Circuit Terminals IP20
Pollution Degree	3
Mechanical Durability	10000000 cycle
Minimum Switching Capacity	Auxiliary Circuit 17 V Auxiliary Circuit 5 mA
Maximum Electrical Switching Frequency	(AC-1) 300 cycles per hour (AC-15) 600 cycles per hour (AC-3) 600 cycles per hour (DC-1) 600 cycles per hour (DC-13) 600 cycles per hour (DC-3) 600 cycles per hour
Mounting on DIN Rail	TH35-15 (35 x 15 mm Mounting Rail) acc. to IEC 60715 TH35-7.5 (35 x 7.5 mm Mounting Rail) acc. to IEC 60715
Power Loss	at Rated Operating Conditions AC-1 per Pole 1.4 W
Standards	IEC/EN 60947-1 IEC/EN 60947-4-1 IEC/EN 60947-5-1

Maximum Operating Voltage UL/CSA	Main Circuit 600 V AC
Full Load Amps Motor Use	(115 V AC) Single Phase 13.8 / (200 V AC) Three Phase 7.8 / (220 240 V AC) Three Phase 9.6 / (230 V AC) Single Phase 10 / (440 480 V AC) Three Phase 7.6 / (550 600 V AC) Three Phase 6.1 /
Horsepower Rating UL/CSA	(115 V AC) Single Phase 0.75 Hp (200 V AC) Three Phase 2 Hp (220 240 V AC) Three Phase 3 Hp (230 V AC) Single Phase 1.5 Hp (440 480 V AC) Three Phase 5 Hp (550 600 V AC) Three Phase 5 Hp
General Use Rating UL/CSA	(600 V AC) 16 A
Contact Rating UL/CSA	A600
 Environmental	
Ambient Air Temperature	Operation -20 +55 °C Storage -40 +80 °C
Maximum Operating Altitude Permissible	2000 m
Resistance to Shock acc. to IEC 60068-2-27	11 ms Pulse 15ç
Resistance to Vibrations acc. to IEC 60068-2-6	5g / 5 150 Hz
RoHS Status	Following EU Directive 2011/65/EU
RoHS Status	Following EU Directive 2011/65/EU
RoHS Status Certificates and Declarations (Document Number)	Following EU Directive 2011/65/EU
Certificates and Declarations (Document Number)	Following EU Directive 2011/65/EU 1SAA938000-2002 CQC2003010304064033
Certificates and Declarations (Document Number) CB Certificate	1SAA938000-2002
Certificates and Declarations (Document Number) CB Certificate CQC Certificate	1SAA938000-2002 CQC2003010304064033 cUL_E191658
Certificates and Declarations (Document Number) CB Certificate CQC Certificate cURus Certificate Declaration of Conformity	1SAA938000-2002 CQC2003010304064033 cUL_E191658 2020980304001854
Certificates and Declarations (Document Number) CB Certificate CQC Certificate cURus Certificate Declaration of Conformity - CCC Declaration of Conformity	1SAA938000-2002 CQC2003010304064033 cUL_E191658 2020980304001854 1SAD938517-0001
Certificates and Declarations (Document Number) CB Certificate CQC Certificate cURus Certificate Declaration of Conformity - CCC Declaration of Conformity - CE Declaration of Conformity	1SAA938000-2002 CQC2003010304064033
Certificates and Declarations (Document Number) CB Certificate CQC Certificate cURus Certificate Declaration of Conformity - CCC Declaration of Conformity - CE Declaration of Conformity - UKCA	1SAA938000-2002 CQC2003010304064033 cUL_E191658 2020980304001854 1SAD938517-0001 1SAD938501-1001
Certificates and Declarations (Document Number) CB Certificate CQC Certificate cURus Certificate Declaration of Conformity - CCC Declaration of Conformity - CE Declaration of Conformity - UKCA DNV GL Certificate	1SAA938000-2002 CQC2003010304064033 cUL_E191658 2020980304001854 1SAD938517-0001 1SAD938501-1001 1SAA938000-0306
Certificates and Declarations (Document Number) CB Certificate CQC Certificate cURus Certificate Declaration of Conformity - CCC Declaration of Conformity - CE Declaration of Conformity - UKCA DNV GL Certificate EAC Certificate	1SAA938000-2002 CQC2003010304064033 cUL_E191658 2020980304001854 1SAD938517-0001
Certificates and Declarations (Document Number) CB Certificate CQC Certificate cURus Certificate Declaration of Conformity - CCC Declaration of Conformity - CE Declaration of Conformity - UKCA DNV GL Certificate EAC Certificate Environmental Information	1SAA938000-2002 CQC2003010304064033 cUL_E191658 2020980304001854 1SAD938517-0001 1SAD938501-1001 1SAA938000-0306 1SAA920000-2702 1SAC200068H0009 2CDC102046M6801
Certificates and Declarations (Document Number) CB Certificate CQC Certificate cURus Certificate Declaration of Conformity - CCC Declaration of Conformity - CE Declaration of Conformity - UKCA DNV GL Certificate EAC Certificate Environmental Information Instructions and Manuals	1SAA938000-2002 CQC2003010304064033
Certificates and Declarations (Document Number) CB Certificate CQC Certificate cURus Certificate Declaration of Conformity - CCC Declaration of Conformity - CE Declaration of Conformity - UKCA DNV GL Certificate EAC Certificate Environmental Information Instructions and Manuals KC Certificate	1SAA938000-2002 CQC2003010304064033
Certificates and Declarations (Document Number) CB Certificate CQC Certificate cURus Certificate Declaration of Conformity - CCC Declaration of Conformity - CE Declaration of Conformity - UKCA DNV GL Certificate EAC Certificate Environmental Information Instructions and Manuals KC Certificate RMRS Certificate	1SAA938000-2002 CQC2003010304064033 cUL_E191658 2020980304001854 1SAD938517-0001 1SAA938000-0306 1SAA920000-2702 1SAC200068H0009 2CDC102046M6801 1SAA938000-1501 1SAA938000-0704
Certificates and Declarations (Document Number) CB Certificate CQC Certificate cURus Certificate Declaration of Conformity - CCC Declaration of Conformity - UKCA DNV GL Certificate EAC Certificate Environmental Information Instructions and Manuals KC Certificate RMRS Certificate RoHS Information	1SAA938000-2002 CQC2003010304064033 cUL_E191658 2020980304001854 1SAD938517-0001 1SAD938501-1001 1SAA938000-0306 1SAA920000-2702 1SAC200068H0009 2CDC102046M6801 1SAA938000-1501 1SAA938000-0704
Certificates and Declarations (Document Number) CB Certificate CQC Certificate cURus Certificate Declaration of Conformity - CCC Declaration of Conformity - UKCA DNV GL Certificate EAC Certificate Environmental Information Instructions and Manuals KC Certificate RMRS Certificate RMRS Certificate ROHS Information Container Information	1SAA938000-2002 CQC2003010304064033

VBC7-30-01-F-07 4

Package Level 1 Depth / Length	280 mm
Package Level 1 Gross Weight	1.795 kg
Package Level 1 EAN	4013614419379

Classifications		
Object Classification Code	Q	
ETIM 4	EC000066 - Magnet contactor, AC-switching	
ETIM 5	EC000010 - Starter combination	
ETIM 6	EC000010 - Combination of contactors	
ETIM 7	EC000010 - Combination of contactors	
ETIM 8	EC000010 - Combination of contactors	
eClass	V11.0 : 27371009	
UNSPSC	39121529	

Categories

Low Voltage Products and Systems \rightarrow Control Products \rightarrow Contactors \rightarrow Mini Contactors

