# 3 Port Solenoid Valve

Metal Seal / Rubber Seal







# **Compact, High Flow**

		Valve width	Flow characteristics			
Series		(mm)	Metal seal	Rubber seal		
			C [dm <sup>3</sup> /(s·bar)]	C [dm <sup>3</sup> /(s·bar)]		
rted	VQZ100	10	-	0.56 (Poppet)		
Body ported	VQZ200	15	1.3	1.7		
Bod	₩ VQZ300	18	2.4	3.0		
nted	VQZ100	10		1.0 (Poppet)		
Base mounted	VQZ200	15	2.0	3.0		
Base	VQZ300	18	3.2	4.1		






CAT.ES11-91B


# VQZ100/200/300

# **Solenoid Valve Variations**



# Manifold

# **Body Ported**



			Piping specif	Applicable	A !: !- !-	
Series Base model		Piping	Bor	solenoid	Applicable stations	
		direction	1(P), 3(R)	2(A)	valve	
VQZ100	VV3QZ12-□□□	Тор	Rc 1/8	C3 (for ø3.2) C4 (for ø4) C6 (for ø6) M5 (M5 thread)	VQZ115	2 to 20 stations
VQZ200	VV3QZ22-□□□	722 Top Rc 1/8 C4 (for ø4) C6 (for ø6) M5 (M5 thread)		VQZ2□2	2 to 20 stations	
VQZ300	VV3QZ32-□□□	Тор	Rc 1/4	C6 (for ø6) C8 (for ø8) C10 (for ø10) Rc 1/4	VQZ3□2	2 to 20 stations


### **Base Mounted**



			Piping specif	Applicable	A !: !- ! -		
Series	Base model	Piping	Bor	solenoid	Applicable stations		
		direction	1(P), 3(R)	2(A)	valve		
VQZ100	VV3QZ15-□□□	Side/ top	Rc 1/8	C3 (for ø3.2) C4 (for ø4) C6 (for ø6) M5 (M5 thread)	VQZ115	2 to 20 stations	
VQZ200	VV3QZ25-□□□	Side	Rc 1/4	C4 (for ø4) C6 (for ø6) C8 (for ø8) Rc 1/8	VQZ2□5	2 to 20 stations	
VQZ300	VV3QZ35-□□□	Side	1(P) port Rc 3/8 3(R) port Rc 1/4	C6 (for ø6) C8 (for ø8) C10 (for ø10) Rc 1/4	VQZ3□5	2 to 20 stations	

# **Manifold Options**

# **Body Ported**




DIN rail AXT100-DR-□



P.14






P.14

P.24

Base Mounted	
Blanking plate asso VVQZ100-10A-5 (for VQZ100) VVQZ200-10A-5 (for VQZ200) VVQZ300-10A-5 (for VQZ300) P.31	embly
1101	
Blanking plug KQ2P-23	
KQ2P-04	
KQ2P-06	
KQ2P-08 KQ2P-10	
P.31	
DIN rail	
AXT100-DR-□ □	
+	+++++++++++++++++++++++++++++++++++++++
P.31	
Silencer (for EXH port)	



P.31

Port plug VVQZ100-CP (for VQZ100)



P.31




# **Body Ported**

**Plug Lead Unit** 

# 3 Port Solenoid Valve

# Series VQZ100/200/300Single Unit $(\epsilon_{\text{[Option]}})$

## **VQZ100 / How to Order Valve**




Note) For applicable one-touch fitting and silencer models for this valve series, refer to back page 4.



# Body Ported Series VQZ100/200/300

# VQZ200/300 / How to Order Valve





Note 1) Option Note 2) For o

KR Note 1, 2

Note 2) For details on external pilot type, refer to page 15. Note 3) For AC specification power consumption, refer to page 3.

High pressure/External pilot type

# **⚠** Caution

Use standard (DC) specification for continuous duty.


(Metal seal type only)

### Coil voltage

1	100 VAC (50/60 Hz)
2	200 VAC (50/60 Hz)
3	110 VAC [115 VAC] (50/60 Hz)
4	220 VAC [230 VAC] (50/60 Hz)
5	24 VDC
6	12 VDC

(0.9 W)

Note 1) Standard lead wire length: 300 mm



connector

connector

without

With light/

suppressor

YZ: DIN

With light/

suppressor

surge voltage

terminal

surge voltage

connector

With light/

suppressor

surge voltage

with lead wire

terminal

connector

(DC speci

without

With surge

suppressor

voltage



(DC speci-

fication)

Y: DIN

terminal

connector

with lead

wire

With light/

suppressor

YO: DIN

terminal

without

connector

surge voltage

Note) For applicable one-touch fitting and silencer models for this valve series, refer to back page 4.

connector

connector

without

With light/

suppressor

YOS: DIN Note 2) YS: DIN Note 2)

surge voltage

terminal


fication)

With surge

suppressor

voltage

(DC speci-



# **Specifications**

Valve construction	Metal seal	Rubber seal	VQZ100 (Poppet seal)			
Fluid	Air, Inert gas					
Max. operating pressure (MPa)	0.7 (High pressure type: 1.0)	0.7	0.7 (High pressure type: 1.0)			
Min. operating pressure (MPa)	0.1	0.15	0.15			
Ambient and fluid temperature (°C)	-10 to 50 (No freezing)					
Max. operating frequency (Hz)	20	5	20			
Pilot exhaust method	Individua	l exhaust	Common exhaust			
Lubrication		Not required				
Manual override	Push typ	e, Locking type (Tool r	required)			
Mounting orientation	Free					
Impact/Vibration resistance (m/s²) Note 1)	150/30					
Enclosure	Dustpr	oof (DIN terminal: IP65	5 Note 2))			



\* Based on IEC60529

Note 1) Impact resistance: No malfunction occurred when it is tested with a drop tester in the axial direction and at the right angles to the main valve and armsture in both energized and de-

and at the right angles to the main valve and armature in both energized and deenergized states every once for each condition. (Value in the initial state)

Vibration resistance: No malfunction occurred in one sweep test between 45 and 2000 Hz. Test was performed to axis and right angle directions of the main valve and armature when pilot signal is ON and OFF. (Value in the initial state)

Note 2) When IP65 compliant DIN terminals are selected: VQZ<sub>3</sub><sup>2</sup>□2□-□Y□□W1-□□

# **Solenoid Specifications**

# Options

High speed response type
High pressure type (Metal seal type only)
External pilot type*

<sup>\*</sup> For details on external pilot type, refer to page 15.



Symbol	Description
X30	Pilot valve common exhaust
X90	Main valve fluoro-rubber
X113	All fluoro-rubber

Electrical entry			Grommet (G) M-type plug connector (L) DIN terminal (Y)			
			G, L, M Y			
Coil rated voltage			24	, 12		
(V) AC		C 50/60 Hz	100, 110, 200, 220*			
Allowable voltage fluctuation			±10% of rat	ted voltage*		
		Standard	0.35 [(With light: 0.4 (DIN terminal with light: 0			
Power consumption (W)	С	High speed response, high pressure	0.9 [(With light: 0.95 (DIN terminal with light: 1.0)]			
		100 V	0.78 (With light: 0.81)	0.78 (With light: 0.87)		
Apparent power	AC	110 V [115 V]	0.86 (With light: 0.89) [0.94 (With light: 0.97)]	0.86 (With light: 0.87) [0.94 (With light: 1.07)]		
(VA)*	٦٠	200 V	1.18 (With light: 1.22)	1.15 (With light: 1.30)		
		220 V [230 V]	1.30 (With light: 1.34) [1.42 (With light: 1.46)]	1.27 (With light: 1.46) [1.39 (With light: 1.60)]		
Surge voltage suppressor			Varistor			
Indicator light			LED (Neon light when AC with DIN terminal)			




- \* In common between 110 VAC and 115 VAC, and between 220 VAC and 230 VAC.
- \* For 115 VAC and 230 VAC, the allowable voltage is –15% to +5% of rated voltage.

# **Flow Characteristics**

					Flow characteristics					Response time (ms) Note 1)				
Series	Valve construc-			1→2 (P→A)		2→3 (A→R)			olanuaru, i sheen 🔠	High		Note 2) Weight		
tion	tion			C [dm³/(s•bar)]	b	Cv	C [dm³/(s•bar)]	b	Cv	0.35 W	response: 0.9 W	pressure: 0.9 W	ΑΟ	(g)
VQZ100	N.C. valve	Poppet	VQZ115	0.59	0.44	0.17	0.56	0.30	0.14	10 or less	_	13 or less	22 or less	24
	N.C.	Metal seal	VQZ212	1.2	0.21	0.30	1.3	0.24	0.33	22 or less	14 or less	18 or less	34 or less	
VQZ200	valve	Rubber seal	VQZ232	1.6	0.33	0.39	1.7	0.37	0.45	22 or less	15 or less	_	36 or less	57
VQZZUU	N.O.	Metal seal	VQZ222	1.2	0.25	0.31	1.3	0.20	0.31	22 or less	14 or less	18 or less	34 or less	
	valve	Rubber seal	VQZ242	1.6	0.36	0.40	1.7	0.36	0.45	22 or less	15 or less	_	36 or less	
	N.C.	Metal seal	VQZ312	2.7	0.18	0.62	2.4	0.28	0.56	22 or less	17 or less	22 or less	34 or less	
VQZ300	valve	Rubber seal	VQZ332	3.5	0.34	0.87	3.0	0.33	0.72	33 or less	25 or less	_	57 or less	93
	N.O.	Metal seal	VQZ322	2.6	0.21	0.59	2.2	0.16	0.49	22 or less	17 or less	22 or less	34 or less	
	valve	Rubber seal	VQZ342	3.5	0.38	0.88	2.9	0.27	0.69	33 or less	25 or less	_	57 or less	



Note 1) Based on JIS B 8375-1981 (Supply pressure: 0.5 MPa; with light/surge voltage suppressor: clean air) Response time values will change depending on pressure and air quality.







# Body Ported Series VQZ100/200/300

# Construction

# VQZ100 Poppet type








**Component Parts** 


No.	Description	Material	Note
1	Body	Resin	
2	Spool valve	Aluminum/HNBR	
3	Pilot valve assembly	_	
4	P, R port	Resin/Aluminum	VQZ100-12A (Standard) VQZ100-12B (External pilot type)

# VQZ200/300 Metal seal type













# Rubber seal type









### **Component Parts**

No.	Description	Material	Note					
1	Body	Aluminum die-casted						
_	Spool, Sleeve	Spool, Sleeve Stainless steel						
2	Spool valve	Aluminum/HNBR	Rubber seal					
3	Piston	Resin						
4	Pilot valve assembly	_						


Note) For "How to Order Pilot Valve Assembly", refer to page 16.





# **Dimensions: VQZ100**

## Single Unit


Grommet (G): VQZ115□-□G□1-C3, C4, C6-PR







Note) For bracket assembly part no., refer to page




VQZ115□-□G□1-M5-PR


M5 x 0.8
[2(A) port]

Note) For one-touch fittings for P/R port and silencer part no., refer to back page 4.

### L-type plug connector (L): VQZ115□-□L□1-C3, C4, C6-PR



# M-type plug connector (M): VQZ115□-□M□1-C3, C4, C6-PR







# Body Ported Series VQZ100/200/300

# **Dimensions: VQZ200**


## Single Unit

## Grommet (G): VQZ2□2□-□G□1-C4, C6





Note) For bracket assembly part no., refer to page 16.




Note) For one-touch fittings for P/R port and silencer part no., refer to back page 4.

(PE port)

ø2.6 (Reverse-mounting-prevention hole


(CE compliant models only)

#### L-type plug connector (L): VQZ2 2 - L 1-C4, C6




Unless otherwise indicated, dimensions are the same as Grommet (G).

## M-type plug connector (M): VQZ2□2□-□M□1-C4, C6



Unless otherwise indicated, dimensions are the same as Grommet (G).

#### DIN terminal (Y): VQZ2 2 - Y 1-C4, C6







# **Dimensions: VQZ300**


## Single Unit

## Grommet (G): VQZ3□2□-□G□1-C6, C8, C10





Note) For bracket assembly part no., refer to page 16.




ø8, ø5/16"

ø10, ø3/8"

2 x M2.5 x 0.45


Thread length 6

# L-type plug connector (L): VQZ3□2□-□L□1-C6, C8, C10




Unless otherwise indicated, dimensions are the same as Grommet (G).

## M-type plug connector (M): VQZ3□2□-□M□1-C6, C8, C10



Unless otherwise indicated, dimensions are the same as Grommet (G). [ ]: AC

# DIN terminal (Y): VQZ3 2 - Y - 1-C6, C8, C10





# **Body Ported**

**Plug Lead Unit** 


# 3 Port Solenoid Valve

# Series VQZ100/200/300

Manifold Connector Kit



## VQZ100 / How to Order Manifold



For DIN rail part no., refer to page 14.


Note 2) When two or more symbols are specified, indicate them alphabetically.

> Note) For 1(P), 3(R) of optional thread type, refer to page 15.

## VQZ100 / How to Order Valve


Kit type •

**C** Connector




# VQZ200/300 / How to Order Manifold





## VQZ200/300 / How to Order Valve



# **⚠** Caution

Use standard (DC) specification for continuous duty.

#### Coil voltage

1	100 VAC (50/60 Hz)
2	200 VAC (50/60 Hz)
3	110 VAC [115 VAC] (50/60 Hz)
4	220 VAC [230 VAC] (50/60 Hz)
5	24 VDC
6	12 VDC

	= = ioo ii io ii i y								
Symbol	Electrical entry	Light/surge voltage suppressor							
G	Grommet (DC specification)	None							
L	L-type plug connector with lead wire								
LO	L-type plug connector without connector	V							
M	M-type plug connector with lead wire	Yes							
MO	M-type plug connector without connector								
Υ	DIN terminal	Niere							
YO	DIN terminal without connector	None							
YZ	DIN terminal	Yes							
YS Note 2)	IN terminal (DC specification) Yes								
YOS Note 2)	OIN terminal without connector (DC specification) (Without light)								
YOS Note 2)	, ,								


Note 1) Standard lead wire length: 300 mm

Note 2) For AC voltage valves there is no "S" option. It is already built-in to the rectifier circuit.




# Body Ported Series VQZ100/200/300

# **Manifold Specifications**




		Pip	ing spec	ifications	Applicable	A	Manifold	
Series	Base model	Piping direction		Port size	solenoid valve	Applicable stations	base weight (g)	
VQZ100	VV3QZ12-□□□	Тор	1(P), 3(R) Rc 1/8	2(A) C3 (for ø3.2) C4 (for ø4) C6 (for ø6) M5 (M5 thread)	VQZ115	2 to 20 stations	2 stations: 83 Addition per station: 19	
VQZ200	VV3QZ22-□□□	Тор	Rc 1/8	C4 (for ø4) C6 (for ø6) M5 (M5 thread)	VQZ2□2	2 to 20 stations	2 stations: 68 Addition per station: 20	
VQZ300	VV3QZ32-□□□	Тор	Rc 1/4	C6 (for Ø6) C8 (for Ø8) C10 (for Ø10) Rc 1/4	VQZ3□2	2 to 20 stations	2 stations: 114 Addition per station: 37	

# **How to Order Manifold Assembly (Example)**




# **Dimensions: VQZ100**

## VV3QZ12- Stations C




### L-type plug connector (L)

The dashed lines indicate the DIN rail mounting [-D].



Unless otherwise indicated, dimensions are the same as Grommet (G).

## M-type plug connector (M)



Unless otherwise indicated, dimensions are the same as Grommet (G).

**Dimensions** Formula: L5 = 10.5n + 9.5 L3 = 10.5n + 22.5 n: Stations (Max. 20 stations)

														0.0			0			0141.01.0)
$\overline{L}$	n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
	L1	85.5	85.5	98	110.5	123	135.5	148	148	160.5	173	185.5	198	210.5	210.5	223	235.5	248	260.5	273
I	L2	75	75	87.5	100	112.5	125	137.5	137.5	150	162.5	175	187.5	200	200	212.5	225	237.5	250	262.5
	L3	43.5	54	64.5	75	85.5	96	106.5	117	127.5	138	148.5	159	169.5	180	190.5	201	211.5	222	232.5
ı	L4	21	16	17	18	19	20	21	15.5	16.5	17.5	18.5	19.5	20.5	15.5	16.5	17.5	18.5	19.5	20.5
	L5	30.5	41	51.5	62	72.5	83	93.5	104	114.5	125	135.5	146	156.5	167	177.5	188	198.5	209	219.5


# Body Ported *Series VQZ100/200/300*


[1(P),3(R) port]


34 (99)

# **Dimensions: VQZ200**


## VV3QZ22- Stations C








# M-type plug connector (M)




Unless otherwise indicated, dimensions are the same as Grommet (G). [ ]: AC

### DIN terminal (Y)




Dimer	Dimensions Formula: $L5 = 16n + 11$ $L3 = 16n + 22$ n: Stations (Max. 20 stations													stations)					
L	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L1	85.5	110.5	123	135.5	148	173	185.5	198	223	235.5	248	260.5	285.5	298	310.5	335.5	348	360.5	373
L2	75	100	112.5	125	137.5	162.5	175	187.5	212.5	225	237.5	250	275	287.5	300	325	337.5	350	362.5
L3	54	70	86	102	118	134	150	166	182	198	214	230	246	262	278	294	310	326	342
L4	16	20.5	18.5	17	15	19.5	18	16	20.5	19	17	15.5	20	18	16.5	21	19	17.5	15.5
L5	43	59	75	91	107	123	139	155	171	187	203	219	235	251	267	283	299	315	331


# **Dimensions: VQZ300**



# L-type plug connector (L)




# M-type plug connector (M)



Unless otherwise indicated, dimensions are the same as Grommet (G).

[ ]: AC

#### DIN terminal (Y)



ø3.5 to ø7 Unless otherwise indicated, dimensions are the same as Grommet (G).

**Dimensions** Formula: L5 = 19n + 11 L3 = 19n + 23 n: Stations (Max. 20 stations)

_ _ _	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L1	98	110.5	135.5	148	173	198	210.5	235.5	248	273	285.5	310.5	323	348	360.5	385.5	398	423	435.5
L2	87.5	100	125	137.5	162.5	187.5	200	225	237.5	262.5	275	300	312.5	337.5	350	375	387.5	412.5	425
L3	61	80	99	118	137	156	175	194	213	232	251	270	289	308	327	346	365	384	403
L4	18.5	15.5	18.5	15	18	21	18	21	17.5	20.5	17.5	20.5	17	20	17	20	16.5	19.5	16.5
L5	49	68	87	106	125	144	163	182	201	220	239	258	277	296	315	334	353	372	391



# Body Ported Series VQZ100/200/300

# **Manifold Options**


Blanking plate assembly

VVQZ100-10A-5 (for VQZ100)

VVQZ200-10A-2 (for VQZ200)

VVQZ300-10A-2 (for VQZ300)

It is used by attaching on the manifold block for being prepared for removing a valve for maintenance reasons or planning to mount a spare valve, etc.



## **Blanking plug**


KQ2P-23


KQ2P-04

**KQ2P-06** 

**KQ2P-08** 

**KQ2P-10** 






Dimensions (mm)										
Applicable fitting size ød	Model	A	L	D						
3.2	KQ2P-23	16	31.5	3.2						
4	KQ2P-04	16	32	6						
6	KQ2P-06	18	35	8						
8	KQ2P-08	20.5	39	10						
10	KQ2P-10	22	43	12						

# DIN rail AXT100-DR-□

\* As for 

, enter the number from the DIN rail dimensions table. For L dimension, refer to the dimensions of each kit.

Each manifold can be mounted on a DIN rail. Insert "D" at the end of the manifold part number. The DIN rail is approximately 30 mm longer than the length of manifold.







L Dimen	sio	n															L=	= 12.	5n +	10.5
No.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L dimension	23	35.5	48	60.5	73	85.5	98	110.5	123	135.5	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5
No.	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40
L dimension	273	285.5	298	310.5	323	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448	460.5	473	485.5	498	510.5


# Silencer (for manifold EXH port)

Silencer is installed in the manifold EXH port.





Dimensions								
Model	Silencer part no.							
VQZ100	AN110-01							
<b>VQZ200</b>								
VQZ300	AN200-02							






# Series VQZ Body Ported Options

# **External Pilot Specification**


The external pilot specification is used when the operating pressure is below the minimum operating pressure 0.1 to 0.15 MPa or when valve is used for a vacuum application. Order a valve by adding the external pilot specification [R] to the part number.




# Inch Size One-touch Fittings and Optional Threads

Inch size one-touch fittings and NPT, NPTF and G thread are available.






Symbo	JI	14.1	INO	147	INS	1411	IVIO	02		
Applicable tubing	O.D. (Inch)	ø1/8"	ø5/32"	ø1/4"	ø5/16"	ø3/8"	M5 thread	1/4 thread		
	VQZ100	•	•	•	_	1	•	_		
2(A) port	VQZ200	_	•	•	_	_	•	_		
	VQZ300	_	_	•	•	•	_	•		
Note) Metric size one-touch fittings (C□) are also available.										



NPTF

т

## **Manifold Part No.**




## IP65 Enclosure (Based on IEC529)

DIN terminal is available with IP65 enclosure.

Valve Part No.

(Applicable to the VQZ200/300 rubber seal with the exception of the external pilot type)



# Series VQZ Body Ported

# **Replacement Parts**

**One-touch Fitting Assembly (for Cylinder port)** 

Fitting size Model	C3	C3 C4		C8	C10	M5 (VQZ100 only)
VQZ100/200	VVQ1000-50A-C3	VVQ1000-50A-C4	VVQ1000-50A-C6	_	_	VVQ1000-50A-M5
VQZ300	_	_	VVQ1000-51A-C6	VVQ1000-51A-C8	VVQ1000-51A-C10	_

Note) Purchasing order is available in units of 10 pieces.

#### <Plug connector assembly>

DC: SY100-30-4A-

100 VAC: SY100-30-1A-

200 VAC: SY100-30-2A-


Other AC voltages: SY100-30-3A-

Without lead wire: SY100-30-A (with connector and 2 sockets only)

#### Lead wire length

ad who longer								
Nil	300 mm							
6	600 mm							
10	1000 mm							
15	1500 mm							
20	2000 mm							
25	2500 mm							
30	3000 mm							
50	5000 mm							

#### <Pilot valve assembly>



		<b>_</b>	liectrical entry •
Symbol		Floatrical ontro	Light/surge voltage
DC	AC	Electrical entry	suppressor
G	_	Grommet (DC specification)	None
LU	LU LZ L-type plug connector with lead wire		
LOU LOZ L-type plug connector without connector		Yes	
MU	MZ	M-type plug connector with lead wire	165
		1	

MOU | MOZ | M-type plug connector without connector Note) VQZ pilot valve electrical entry (L, M) is the opposite of the how to order of valve body

Valve model	Pilot valve model
VQZ115□-□L□1	V111□M-□M□
VQZ115□-□M□1	V111□M-□L□

#### How to Order

Include the connector assembly part number together with the part number for the plug connector's solenoid valve without connector.


Example) In case of 2000 mm of lead wire

VQZ115-5LO1-M5-PR VQZ115-1LO1-M5-PR SY100-30-4A-20 SY100-30-1A-20

## <Gasket and screw assembly>

Model	Part no.
VQZ100	VQZ100-GS-2
VQZ200	VQZ200-GS-2
VQZ300	VQZ300-GS-2

Note) Above part number consists of 10 units. Each unit has one gasket and two screws. Purchasing order is available in units of 10 pieces.



	ı
Coil voltage	
100 VAC (50/60 Hz)	

1	100 VAC (50/60 Hz)
2	200 VAC (50/60 Hz)
3	110 VAC (50/60 Hz)
4	220 VAC (50/60 Hz)
5	24 VDC
6	12 VDC

# Note) Option

_		001111111111111111111111111111111111111
	1	100 VAC (50/60 Hz)
	2	200 VAC (50/60 Hz)
	3	110 VAC (50/60 Hz)
	4	220 VAC (50/60 Hz)
	5	24 VDC
	6	12 VDC


Nil

#### <Bracket assembly>

Model	Part no.	Tightening torque (N⋅m) Note)
VQZ100	VQZ100-FB	0.45 to 0.55
VQZ200	VQZ200-FB	0.25 to 0.35
VQZ300	VQZ300-FB	0.25 to 0.35

Note) Tightening torque when mounting a bracket on the valve.

## <DIN terminal type (Applicable to the VQZ200/300)>



	Electric	al entry 🖣	
Symbol	Electrical entry	Light/surge voltage suppressor	
Y	DIN terminal	None	
YO	DIN terminal without connector	None	
YZ	DIN terminal with light/surge voltage suppressor	Yes	
YS Note)	DIN terminal with surge voltage suppressor (DC specification)	Yes	
YOS Note)	DIN terminal with surge voltage suppressor, without connector (DC specification)	(Without	

Note) For AC voltage valves there is no "S" option. It is already built-in to the rectifier circuit.

# <u> ∕!∖</u> Caution

When replacing only the pilot valve assembly, use caution because it is not possible to convert to a V115 (DIN terminal) from a V111 (Grommet, L-type, M-type), or vice versa.




# **Base Mounted**

**Plug Lead Unit** 

# 3 Port Solenoid Valve

# Series VQZ100/200/300Single Unit $(\in [Option]$

## VQZ100 / How to Order Valve




Note) For sub-plate part no., refer to page 33.



# Base Mounted Series VQZ100/200/300

# VQZ200/300 / How to Order Valve





rectifier circuit.

Coil voltage		
1	100 VAC (50/60 Hz)	
2	200 VAC (50/60 Hz)	
3	110 VAC [115 VAC] (50/60 Hz)	
4	220 VAC [230 VAC] (50/60 Hz)	
5	24 VDC	
6	12 VDC	

Note) For sub-plate part no., refer to page 33.





# **Specifications**

Valve construction	Metal seal	Rubber seal	VQZ100 (Poppet seal)	
Fluid		Air, Inert gas		
Max. operating pressure (MPa)	0.7 (High pressure type: 1.0)	0.7	0.7 (High pressure type: 1.0)	
Min. operating pressure (MPa)	0.1	0.15	0.15	
Ambient and fluid temperature (°C)	-10 to 50 (No freezing)			
Max. operating frequency (Hz)	20	5	20	
Pilot exhaust method	Individua	l exhaust	Common exhaust	
Lubrication	Not required			
Manual override	Push type, Locking type (Tool required)			
Mounting orientation	Free			
Impact/Vibration resistance (m/s²) Note 1) 150/30   Enclosure   Dustproof (DIN terminal: IP65 Note				
		oof (DIN terminal: IP65	5 Note 2))	



\* Based on IEC60529

Note 1) Impact resistance: No malfunction occurred when it is tested with a drop tester in the axial direction

and at the right angles to the main valve and armature in both energized and deenergized states every once for each condition. (Value in the initial state)

Vibration resistance: No malfunction occurred in one sweep test between 45 and 2000 Hz. Test was performed to axis and right angle directions of the main valve and armature when pilot signal is ON and OFF. (Value in the initial state)

Note 2) When IP65 compliant DIN terminals are selected:  $VQZ_3^2\Box 5\Box -\Box Y\Box \Box W1-\Box -\Box$ 

# Solenoid Specifications

# **Options**

High speed response type
High pressure type (Metal seal type only)
External pilot type*

<sup>\*</sup> For details on external pilot type, refer to page 32.



## **Made to Order** (For details, refer to page 34.)

Symbol	Description
X30	Pilot valve common exhaust
X90	Main valve fluoro-rubber
X113	All fluoro-rubber

Electrical entry			Grommet (G) L-type plug connector (L)	M-type plug connector (M) DIN terminal (Y)
			G, L, M	Υ
Coil rated voltage		С	24	, 12
(V)	-	AC 50/60 Hz	100, 110,	200, 220*
Allowable voltage f	luctua	ation	±10% of ra	ted voltage*
		Standard	0.35 [(With light: 0.4 (DIN	l terminal with light: 0.45)]
Power consumption (W)	DC	High speed response, high pressure	0.9 [(With light: 0.95 (DII	N terminal with light: 1.0)]
		100 V	0.78 (With light: 0.81)	0.78 (With light: 0.87)
Apparent power	AC	110 V [115 V]	0.86 (With light: 0.89) [0.94 (With light: 0.97)]	0.86 (With light: 0.87) [0.94 (With light: 1.07)]
(VA)	AC	200 V	1.18 (With light: 1.22)	1.15 (With light: 1.30)
		220 V [230 V]	1.30 (With light: 1.34) [1.42 (With light: 1.46)]	1.27 (With light: 1.46) [1.39 (With light: 1.60)]
Surge voltage supp	resso	or	Var	ristor
Indicator light			LED (Neon light when	AC with DIN terminal)



- $\ast$  In common between 110 VAC and 115 VAC, and between 220 VAC and 230 VAC.  $\ast$  For 115 VAC and 230 VAC, the allowable voltage is –15% to +5% of rated voltage.

## Flow Characteristics

					Fle	ow char	acteristics			Res	sponse tir	ne (ms) <sup>N</sup>	ote 1)	
Series	Valve construc-	Mode	el	1→2 (	P→A)		2→3 (	A→R)		Standard:	Ispeed	High pressure:	AC	Note 2) Weight
	tion			C [dm³/(s•bar)]	b	Cv	C [dm³/(s•bar)]	b	Cv	0.35 W	rochonco.	0.9 W	AC	(g)
VQZ100	N.C. valve	Poppet	VQZ115	0.87	0.46	0.23	1.0	0.35	0.25	10 or less	_	13 or less	22 or less	24
	N.C.	Metal seal	VQZ215	1.7	0.17	0.38	2.0	0.20	0.45	22 or less	14 or less	18 or less	34 or less	
VQZ200	valve	Rubber seal	VQZ235	2.3	0.46	0.65	3.0	0.40	0.80	22 or less	15 or less	_	36 or less	52
VQZ200	N.O.	Metal seal	VQZ225	1.7	0.18	0.38	1.8	0.21	0.39	22 or less	14 or less	18 or less	34 or less	52
	valve	Rubber seal	VQZ245	2.5	0.43	0.67	3.0	0.30	0.74	22 or less	15 or less	_	36 or less	
	N.C.	Metal seal	VQZ315	3.0	0.21	0.70	3.2	0.27	0.80	22 or less	17 or less	22 or less	34 or less	
VO7200	valve	Rubber seal	VQZ335	4.5	0.42	1.3	4.1	0.36	1.0	33 or less	25 or less	_	57 or less	78
VQZ300	N.O.	Metal seal	VQZ325	2.9	0.21	0.72	2.9	0.16	0.69	22 or less	17 or less	22 or less	34 or less	/8
	valve	Rubber seal	VQZ345	4.4	0.45	1.2	4.5	0.38	1.2	33 or less	25 or less	_	57 or less	



Note 1) Based on JIS B 8375-1981 (Supply pressure: 0.5 MPa; with light/surge voltage suppressor: clean air) Response time values will change depending on pressure and air quality.


Note 2) Weight without sub-plate.




# Base Mounted Series VQZ100/200/300

# Construction

# VQZ100 Poppet type








# **Component Parts**


No.	Description	Material	Note
1	Body	Resin	
2	Spool valve	Aluminum/HNBR	
3	Pilot valve assembly	_	
4	Port plug	Resin/HNBR	VVQZ100-CP

# VQZ200/300 Metal seal type













# Rubber seal type









# **Component Parts**

00111	ponent i arts		
No.	Description	Material	Note
1	Body	Aluminum die-casted	
2	Spool, Sleeve	Stainless steel	Metal seal
2	Spool valve	Aluminum/HNBR	Rubber seal
3	Piston	Resin	
4	Pilot valve assembly	_	


Note) For "How to Order Pilot Valve Assembly", refer to page 33.




# **Dimensions: VQZ100**


# Single Unit

**Grommet (G): VQZ115**□-□**G**□1-01






## L-type plug connector (L): VQZ115□-□L□1-01



# Unless otherwise indicated, dimensions are the same as Grommet (G). [ ]: AC

# M-type plug connector (M): VQZ115□-□M□1-01



Unless otherwise indicated, dimensions are the same as Grommet (G).

[ ]: AC



1/8


[1(P), 3(R) port]


# Base Mounted Series VQZ100/200/300


# **Dimensions: VQZ200**


# Single Unit


Grommet (G): VQZ2□5□-□G□1-01













## L-type plug connector (L): VQZ2 5 - L 1-01



Unless otherwise indicated, dimensions are the same as Grommet (G).


# M-type plug connector (M): VQZ2□5□-□M□1-01



Unless otherwise indicated, dimensions are the same as Grommet (G).

[ ]: AC

# DIN terminal (Y): VQZ2 5 - Y = 1-02








# **Dimensions: VQZ300**


# Single Unit


Grommet (G): VQZ3□5□-□G□1-02













# L-type plug connector (L): VQZ3 \$\Boxed{D}\$5\$\Boxed{-} \Boxed{L} \Boxed{D}\$1-\boxed{0}3



Unless otherwise indicated, dimensions are the same as Grommet (G).


# M-type plug connector (M): VQZ3□5□-□M□1-03



Unless otherwise indicated, dimensions are the same as Grommet (G).

[ ]: AC

# DIN terminal (Y): VQZ3 5 - Y 1-03





# **Base Mounted**

**Plug Lead Unit** 


# 3 Port Solenoid Valve

# Series VQZ100/200/300


Manifold Connector Kit



## VQZ100 / How to Order Manifold




# VQZ100 / How to Order Valve




# VQZ200/300 / How to Order Manifold





## VQZ200/300 / How to Order Valve




# Base Mounted Series VQZ100/200/300


# **Manifold Specifications**



		Pip	ing spec	ifications	Applicable	A	Note) Manifold
Series	Base model	Piping	ı	Port size	solenoid	Applicable stations	base
		direction	1(P), 3(R)	2(A)	valve		weight (g)
VQZ100	VV3QZ15-□□□	Side/Top	Rc 1/8	C3 (for ø3.2) C4 (for ø4) C6 (for ø6) M5 (M5 thread)	VQZ115	2 to 20 stations	2 stations: 83 Addition per station: 19
VQZ200	VV3QZ25-□□□	Side	Rc 1/4	C4 (for ø4) C6 (for ø6) C8 (for ø8) Rc 1/8	VQZ2□5	2 to 20 stations	2 stations: 126 Addition per station: 38
VQZ300	VV3QZ35-□□□	Side 1(P) por Rc 3/8 3(R) por Rc 1/4		C6 (for Ø6) C8 (for Ø8) C10 (for Ø10) Rc 1/4	VQZ3□5	2 to 20 stations	2 stations: 209 Addition per station: 60




# **How to Order Manifold Assembly (Example)**



# **Dimensions: VQZ100: Top Ported**


# VV3QZ15- Stations Port size C



The dashed lines indicate the DIN rail mounting [-D].

#### М5

(7.5)




Dimer	sions								F	ormula: I	L5 = 10.5	5n + 9.5	L3 = 10	).5n + 22	2.5 n: S	tations (	Max. 20	stations)	
L	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L1	85.5	85.5	98	110.5	123	135.5	148	148	160.5	173	185.5	198	210.5	210.5	223	235.5	248	260.5	273
L2	75	75	87.5	100	112.5	125	137.5	137.5	150	162.5	175	187.5	200	200	212.5	225	237.5	250	262.5
L3	43.5	54	64.5	75	85.5	96	106.5	117	127.5	138	148.5	159	169.5	180	190.5	201	211.5	222	232.5
L4	21	16	17	18	19	20	21	15.5	16.5	17.5	18.5	19.5	20.5	15.5	16.5	17.5	18.5	19.5	20.5
L5	30.5	41	51.5	62	72.5	83	93.5	104	114.5	125	135.5	146	156.5	167	177.5	188	198.5	209	219.5



# Base Mounted Series VQZ100/200/300

# **Dimensions: VQZ100: Side Ported**


## VV3QZ15- Stations Port size C



#### 

The dashed lines indicate the DIN rail mounting [-D].


## L-type plug connector (L)



Unless otherwise indicated, dimensions are the same as Grommet (G).

[ ]: AC

## M-type plug connector (M)




Unless otherwise indicated, dimensions are the same as Grommet (G).


**Dimensions** Formula: L5 = 10.5n + 9.5 L3 = 10.5n + 22.5 n: Stations (Max. 20 stations)


Biiiioi	1010110								ommula. I	_0 - 10.0	311 1 3.5	LO - 10	J. JII I ZZ	11. 0	tations (i	IVIUX. 20	Julio 13)		
L	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L1	85.5	85.5	98	110.5	123	135.5	148	148	160.5	173	185.5	198	210.5	210.5	223	235.5	248	260.5	273
L2	75	75	87.5	100	112.5	125	137.5	137.5	150	162.5	175	187.5	200	200	212.5	225	237.5	250	262.5
L3	43.5	54	64.5	75	85.5	96	106.5	117	127.5	138	148.5	159	169.5	180	190.5	201	211.5	222	232.5
L4	21	16	17	18	19	20	21	15.5	16.5	17.5	18.5	19.5	20.5	15.5	16.5	17.5	18.5	19.5	20.5
L5	30.5	41	51.5	62	72.5	83	93.5	104	114.5	125	135.5	146	156.5	167	177.5	188	198.5	209	219.5

# **Dimensions: VQZ200**

## VV3QZ25- Stations Port size C








The dashed lines indicate the DIN rail mounting [-D].

# \_ead wire length) Approx. 300 57.8 [64.8] [84.2]

L-type plug connector (L)


Unless otherwise indicated, dimensions are the same as Grommet (G).
[ ]: AC

## M-type plug connector (M)



the same as Grommet (G).
[ ]: AC

## DIN terminal (Y)




Dimensions	Formula: L5 = 16n + 10	L3 = 16n + 20	n: Stations (Max. 20 stations)
------------	------------------------	---------------	--------------------------------


<u> </u>	1010110								1 01	mula. Lo	_ 1011 1	10 L0	- 1011 1	20 11. 0	tations (	WIGH. 20	Jidilol13)		
L	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L1	85.5	98	123	135.5	148	173	185.5	198	210.5	235.5	248	260.5	285.5	298	310.5	323	348	360.5	373
L2	75	87.5	112.5	125	137.5	162.5	175	187.5	200	225	237.5	250	275	287.5	300	312.5	337.5	350	362.5
L3	52	68	84	100	116	132	148	164	180	196	212	228	244	260	276	292	308	324	340
L4	17	15	19.5	18	16	20.5	19	17	15.5	20	18	16.5	21	19	17.5	15.5	20	18.5	16.5
L5	42	58	74	90	106	122	138	154	170	186	202	218	234	250	266	282	298	314	330


# Base Mounted Series VQZ100/200/300

# **Dimensions: VQZ300**

#### VV3QZ35- Stations Port size C Grommet (G) D side U side L1 PE port ead wire length 64.5 L2 (5) Approx. 300 M5 x 0.8 (Rail mounting hole pitch: 12.5) 49.1 (X: External pilot port) (Pitch) <External pilot only> P = 20 (DIN rail clamp thread) Manual override [3(R) port] (DIN rail) 79.8 (99) 44.5 2 57.6 (32)(9) (8) 5.5 [1(P) port] 2 x ø4.5 (For mounting) 11.5 L3 29.5 (Station 1) ----- (Station n) One-touch fitting [2(A) port] Applicable tubing O.D.: ø6, ø1/4" ø8, ø5/16" ø10, ø3/8" 8 23 (Pitch) 19.5 P = 201/4 1/4 [2(A) port] 34 41.7 (Pitch) 19.5 The dashed lines indicate the DIN rail mounting [-D]. L-type plug connector (L) M-type plug connector (M) DIN terminal (Y) Applicable cable O.D ead wire length 93.8 300 ø3.5 to ø7 86.3 우 Approx. 64.5 [71.5] ۷ax. Pg7 Approx. 300 75.8 [82.8] (Lead wire length)







Dimen	sions							Fo	rmula: L	.5 = 20n	+ 8 L3	= 20n + :	26 n: S	tations (I	Max. 20	stations)			
L n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L1	98	123	148	160.5	185.5	198	223	248	260.5	285.5	298	323	348	360.5	385.5	398	423	448	460.5
L2	87.5	112.5	137.5	150	175	187.5	212.5	237.5	250	275	287.5	312.5	337.5	350	375	387.5	412.5	437.5	450
L3	66	86	106	126	146	166	186	206	226	246	266	286	306	326	346	366	386	406	426
L4	16	18.5	21	17.5	20	16	18.5	21	17.5	20	16	18.5	21	17.5	20	16	18.5	21	17.5
L5	48	68	88	108	128	148	168	188	208	228	248	268	288	308	328	348	368	388	408

# **Manifold Options**


Blanking plate assembly

VVQZ100-10A-5 (for VQZ100)

VVQZ200-10A-5 (for VQZ200)

VVQZ300-10A-5 (for VQZ300)

It is used by attaching on the manifold block for being prepared for removing a valve for maintenance reasons or planning to mount a spare valve, etc.



## **Blanking plug**


**KQ2P-23** 


KQ2P-04

**KQ2P-06** 

**KQ2P-08** 

**KQ2P-10** 






Dimension	s			(mm)
Applicable fitting size ød	Model	Α	L	D
3.2	KQ2P-23	16	31.5	3.2
4	KQ2P-04	16	32	6
6	KQ2P-06	18	35	8
8	KQ2P-08	20.5	39	10
10	KQ2P-10	22	43	12

# DIN rail AXT100-DR-□

\* As for  $\square$ , enter the number from the DIN rail dimensions table. For L dimension, refer to the dimensions of each kit.

Each manifold can be mounted on a DIN rail. Insert "D" at the end of the manifold part number. The DIN rail is approximately 30 mm longer than the length of manifold.







L	<b>L Dimension</b> L = 12.5n + 10															10.5					
	No.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
	L dimension	23	35.5	48	60.5	73	85.5	98	110.5	123	135.5	148	160.5	173	185.5	198	210.5	223	235.5	248	260.5
	No.	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40
	L dimension	273	285.5	298	310.5	323	335.5	348	360.5	373	385.5	398	410.5	423	435.5	448	460.5	473	485.5	498	510.5

# Silencer (for manifold EXH port)

Silencer is installed in the manifold EXH port.





## Dimensions

Model	Silencer part no.
<b>VQZ100</b>	AN110-01
<b>VQZ200</b>	AN200-02
<b>VQZ300</b>	AN200-02

# Port plug VVQZ100-CP (for VQZ100)

This is used when changing piping location. (Side or Top)



# Series VQZ Base Mounted Options


# **External Pilot Specification**

The external pilot specification is used when the operating pressure is below the minimum operating pressure 0.1 to 0.15 MPa or when valve is used for a vacuum application. Order a valve by adding the external pilot specification [R] to the part number.



Entry is the same as standard products.

#### Manifold Part No.





Series		VQZ100 Note 2)	VQZ200/300
Note 1)	Metal seal	_	0.1 to 0.7 MPa
External pilot pressure range	Rubber seal (VQZ100: poppet)	0.2 to 0.7 MPa	0.15 to 0.7 MPa
Operating pressure range Note 1)		-100 kPa to 0.7 MPa	

External pilot port


Note 1) In case of the high pressure type, upper limit of max. operating pressure and external pilot pressure range is 1 MPa.

Note 2) When using the VQZ100 series for a vacuum application, vacuum air through its 1(P) port. When supplying vacuum-release air, supply it through its 3(R) port. But do not supply vacuum-release air exceeding 50% for the external pilot pressure.

# **Inch Size One-touch Fittings and Optional Threads**

Inch size one-touch fittings and NPT, NPTF and G thread are available.






 Thread type
 (Cylinder port and 1(P), 3(R) ports)

Rc
NPT
NPTF
G

# **Optional Threads Other than Rc**

Rc specifications are standard for all ports, however, NPT, NPTF and G are available for overseas markets. Add the appropriate symbol following the port size in the standard part number.

# Valve Part No.




Nil	Rc
N	NPT
Т	NPTF
F	G

## IP65 Enclosure (Based on IEC529)

DIN terminal is available with IP65 enclosure.

### Valve Part No.

(Applicable to the VQZ200/300 rubber seal with the exception of the external pilot type)





# Series VQZ Base Mounted

# **Replacement Parts**

One-touch Fitting Assembly (for Cylinder port)

Fitting size Model	C3	C4	C6	C8	C10	M5 (VQZ100 only)
VQZ100	VVQ1000-50A-C3	VVQ1000-50A-C4	VVQ1000-50A-C6	_	_	VVQ1000-50A-M5
VQZ200	_	VVQ1000-51A-C4	VVQ1000-51A-C6	VVQ1000-51A-C8		_
VQZ300	_	_	VVQ2000-51A-C6	VVQ2000-51A-C8	VVQ2000-51A-C10	_

Note) Purchasing order is available in units of 10 pieces.



DC: SY100-30-4A-

100 VAC: SY100-30-1A-


200 VAC: SY100-30-2A-

Other AC voltages: SY100-30-3A-

Without lead wire: SY100-30-A (with connector and 2 sockets only)

ead wire length 🕯		
Nil	300 mm	
6	600 mm	
10	1000 mm	
15	1500 mm	
20	2000 mm	
25	2500 mm	
30	3000 mm	
50	5000 mm	

#### <Pilot valve assembly>



Liectrical e				
Symbol		Electrical entry	Light/surge voltage	
DC	AC	Electrical entry	suppressor	
G	_	Grommet (DC specification)	None	
LU	LZ	L-type plug connector with lead wire		
LOU LOZ		L-type plug connector without connector	Yes	
MU MZ		M-type plug connector with lead wire	165	
MOU	MOZ	M-type plug connector without connector	or	

Note) The electrical entry (L. M) for the VQZ100 pilot valve is different from that of the main valve model number.

Valve model	Pilot valve model
VQZ115□-□L□1	V111□M-□M□
VQZ115□-□M□1	V111□M-□L□

Include the connector assembly part number together with the part number for the plug connector's solenoid valve without connector.

Example) In case of 2000 mm of lead wire

VQZ115-5LO1-M5 VQZ115-1LO1-M5 SY100-30-4A-20 SY100-30-1A-20

#### <Gasket and screw assembly>

Model	Part no.
VQZ100	VQZ100-GS-5
VQZ200	VQZ200-GS-5
VQZ300	VQZ300-GS-5

Note) Above part number consists of 10 units. Each unit has one gasket and two screws. Purchasing order is available in units of 10 pieces



3

24 VDC

12 VDC


## <Sub-plate>

Model	Sub-plate part no.	
VQZ100	VQZ100-S-01(R) ⊛ (-Q) <sup>Note)</sup>	
VQZ200	VQZ200-S-01 (-Q)	
VQZ300	VQZ300-S- <sup>02</sup> (-Q)	

Thread type

Note) R indicates external pilot type. Except VQZ100, external pilot type and internal pilot type are common.

# <DIN terminal type (Applicable to the VQZ200/300)>



Electrical entry Coil voltage Light/surge voltage suppressor 100 VAC (50/60 Hz) Symbol Electrical entry 200 VAC (50/60 Hz) DIN terminal 110 VAC (50/60 Hz) None DIN terminal without connector 220 VAC (50/60 Hz) **Y7** Yes DIN terminal with light/surge voltage suppressor DIN terminal with surge voltage suppressor (DC specification) Yes (Without DIN terminal with surge voltage suppressor, without connector (DC specification)

> Note) For AC voltage valves there is no "S" option. It is already built-in to the rectifier circuit.



When replacing only the pilot valve assembly, use caution because it is not possible to convert to a V115 (DIN terminal) from a V111 (Grommet, L-type, M-type), or vice versa.



# Series VQZ200/300 Made to Order



Please contact SMC for detailed dimensions, specifications, and lead times.


# 1 Pilot Valve Common Exhaust Specification

Pilot exhaust is exhausted through the main R port.

- \* Not designed to prevent leakage to outside.
- \* A combination of external pilots is not available.
- \* "How to Order Manifold" is the same as standard products. Please specify this to "How to Order Valve."

#### Applicable solenoid valve series: VQZ200/300

### **How to Order**




# 2 Main Valve Fluoro-rubber Specification

The seal material, the part of the main valve in contact with fluid, is made of fluoro-rubber.

\* "How to Order Manifold" is the same as standard products. Please specify this to "How to Order Valve."

## Applicable solenoid valve series: VQZ200/300

### **How to Order**



Entry is the same as standard products.


# 3 All Fluoro-rubber Specification

The rubber material of the part in contact with fluid, is made of fluoro-rubber.

st "How to Order Manifold" is the same as standard products. Please specify this to "How to Order Valve."

#### Applicable solenoid valve series: VQZ200/300

### **How to Order**







These safety instructions are intended to prevent a hazardous situation and/or equipment damage. These instructions indicate the level of potential hazard by labels of "Caution", "Warning" or "Danger". To ensure safety, be sure to observe ISO 4414 Note 1), JIS B 8370 Note 2) and other safety practices.

## **■** Explanation of the Labels

Labels Explanation of the labels		
⚠ Danger In extreme conditions, there is a possible result of serious injury or loss of life.		
★ Warning Operator error could result in serious injury or loss of life.		
<b>⚠</b> Caution	Operator error could result in injury Note 3) or equipment damage. Note 4)	

- Note 1) ISO 4414: Pneumatic fluid power General rules relating to systems
- Note 2) JIS B 8370: General Rules for Pneumatic Equipment
- Note 3) Injury indicates light wounds, burns and electrical shocks that do not require hospitalization or hospital visits for long-term medical treatment.
- Note 4) Equipment damage refers to extensive damage to the equipment and surrounding devices.

# ■ Selection/Handling/Applications

1. The compatibility of the pneumatic equipment is the responsibility of the person who designs the pneumatic system or decides its specifications.

Since the products specified here are used in various operating conditions, their compatibility for the specific pneumatic system must be based on specifications or post analysis and/or tests to meet the specific requirements. The expected performance and safety assurance are the responsibility of the person who has determined the compatibility of the system. This person should continuously review the suitability of all items specified, referring to the latest catalog information with a view to giving due consideration to any possibility of equipment failure when configuring a system.

2. Only trained personnel should operate pneumatically operated machinery and equipment.

Compressed air can be dangerous if handled incorrectly. Assembly, handling or repair of the systems using pneumatic equipment should be performed by trained and experienced operators. (Understanding JIS B 8370 General Rules for Pneumatic Equipment, and other safety rules are included.)

- 3. Do not service machinery/equipment or attempt to remove components until safety is confirmed.
  - 1. Inspection and maintenance of machinery/equipment should only be performed once measures to prevent falling or runaway of the driven objects have been confirmed.
  - 2. When equipment is removed, confirm the safety process as mentioned above. Turn off the supply pressure for this equipment and exhaust all residual compressed air in the system, and release all the energy (liquid pressure, spring, condenser, gravity).
  - 3. Before machinery/equipment is restarted, take measures to prevent quick extension of a cylinder piston rod, etc.
- 4. If the equipment will be used in the following conditions or environment, please contact SMC first and be sure to take all necessary safety precautions.
  - 1. Conditions and environments beyond the given specifications, or if product is used outdoors.
  - 2. Installation on equipment in conjunction with atomic energy, railway, air navigation, vehicles, medical equipment, food and beverages, recreation equipment, emergency stop circuits, clutch and brake circuits in press applications, or safety equipment.
  - 3. An application which has the possibility of having negative effects on people, property, requiring special safety analysis.
  - 4. If the products are used in an interlock circuit, prepare a double interlock style circuit with a mechanical protection function for the prevention of a breakdown. And, examine the devices periodically if they function normally or not.

## **■** Exemption from Liability

- 1. SMC, its officers and employees shall be exempted from liability for any loss or damage arising out of earthquakes or fire, action by a third person, accidents, customer error with or without intention, product misuse, and any other damages caused by abnormal operating conditions.
- 2. SMC, its officers and employees shall be exempted from liability for any direct or indirect loss or damage, including consequential loss or damage, loss of profits, or loss of chance, claims, demands, proceedings, costs, expenses, awards, judgments and any other liability whatsoever including legal costs and expenses, which may be suffered or incurred, whether in tort (including negligence), contract, breach of statutory duty, equity or otherwise.
- 3. SMC is exempted from liability for any damages caused by operations not contained in the catalogs and/or instruction manuals, and operations outside of the specification range.
- 4. SMC is exempted from liability for any loss or damage whatsoever caused by malfunctions of its products when combined with other devices or software.



Be sure to read this before handling.


For Safety Instructions and 3 Port Solenoid Valve Precautions, refer to "Precautions for Handling Pneumatic Devices" (M-03-E3A).

#### **Manual Override**

# **⚠** Caution


Without an electric signal for the solenoid valve the manual override is used for switching the main valve. Push type is standard. Locking type (Tool required) is available as an option.

### 1. VQZ100



Press in the direction of the arrow.

#### Locking type (Tool required)



Turn 90° in the direction of arrow.


### 2. VQZ200/300

#### Push type (Tool required)



Push down on the manual override button with a small screwdriver until it stops. Release the screwdriver and the manual override will return.

#### Locking type (Tool required)



Push down completely on the manual override button with a small screwdriver. While down, turn clockwise 90° to lock it. Turn it counterclockwise to release it.

### Locked position



#### **Precautions**

When operating with a screwdriver, turn it gently using a watchmaker's screwdriver. (Torque: less than 0.1 N·m)


Press and rotate to lock the manual operation of VQZ200/300. If rotate without pressing, manual breakage and air leakage could be occurred.

## How to Use L/M-Type Plug Connector

# **⚠** Caution

# 1. Attaching and detaching connectors


To attach a connector, hold the lever and connector unit between your fingers and insert straight onto the pins of the solenoid valve and remove the pawl from the groove by pushing the lever downward with your thumb, and pull the connector straight out.



## Light/Surge Voltage Suppressor

# 


# 1. L/M-type plug connector




## 2. DIN terminal

<DC>

With surge voltage suppressor (YS, YOS)



### Light/surge voltage suppressor (YZ)



Note) Surge voltage suppressor of varistor has residual voltage corresponding to the protective element and rated voltage; therefore, protect the controller side from the surge.



Be sure to read this before handling.

For Safety Instructions and 3 Port Solenoid Valve Precautions, refer to "Precautions for Handling Pneumatic Devices" (M-03-E3A).


### Light/Surge Voltage Suppressor

# **⚠** Caution

## 1. Surge voltage countermeasures

When shutting off the DC power supply using an emergency circuit breaker, the valve may operate incorrectly due to surge voltage generated by other electric parts (e.g., the solenoid). To ensure that surge does not affect the valve, take anti-surge measures (diode for surge protection, etc.) or use a valve with diode to prevent reverse current. (Contact SMC for model numbers.)

#### Circuit example




(1), (3): Examples of anti-surge measures
 (2): Valve equipped with diode to prevent reverse current

### **Lead Wire Connection**

# **⚠** Caution

## 1. Crimping of lead wires and sockets

Not necessary if ordering the lead wire pre-connected model. Strip 3.2 to 3.7 mm at the end of the lead wires, insert the ends of the core wires evenly into the sockets, and then crimp with a crimping tool. When this is done, take care that the coverings of the lead wires do not enter the core wire crimping area.



Crimping tool part no. DXT170-75-1

#### **Lead Wire Connection**

# **⚠** Caution


# 2. Attaching and detaching sockets with lead wires

#### Attaching

Insert the sockets into the square holes of the connector ( $\oplus$ ,  $\ominus$  indication), and continue to push the sockets all the way in until they lock by hooking into the seats in the connector. (When they are pushed in, their hooks open and they are locked automatically.) Then, confirm that they are locked by pulling lightly on the lead wires.

#### Detaching

To detach a socket from a connector, pull out the lead wire while pressing the socket's hook with a stick having a thin tip (approx. 1 mm). If the socket will be used again, first spread the hook outward.




## **Pilot Valve Replacement**


# **⚠** Caution

1. When replacing a conventional type valve with a new type for maintenance or other reasons, a "conversion connector assembly" is necessary to convert the connector from 3 terminals to 2 terminals and must be ordered separately. (When ordering, refer to the below part nos.)

For pilot valves, there is no compatibility between the conventional type and new type. When replacing a pilot valve, be sure to confirm whether it is the new type or the conventional type.

#### [Conventional]







Be sure to read this before handling.

For Safety Instructions and 3 Port Solenoid Valve Precautions, refer to "Precautions for Handling Pneumatic Devices" (M-03-E3A).

#### **How to Use DIN Terminal**

## 1. EN-175301-803C (Former DIN 43650C)

The DIN terminal type with an IP65 enclosure is protected against dust and water, however, it must not be used in water.

#### 2. Connection

- Loosen the holding screw and pull the connector out of the solenoid valve terminal block.
- After removing the holding screw, insert a flat head screwdriver, etc. into the notch on the bottom of the terminal block and pry it open, separating the terminal block and the housing.
- 3) Loosen the terminal screws (slotted screws) on the terminal block, insert the cores of the lead wires into the terminals according to the connection method, and fasten them securely with the terminal screws.
- 4) Secure the cord by fastening the ground nut.

## 3. Changing the entry direction

After separating the terminal block and housing, the cord entry can be changed by attaching the housing in the desired direction (4 directions at 90° intervals).

\* When equipped with a light, be careful not to damage the light with the cord's lead wires.


#### 4. Precautions

Plug in and pull out the connector vertically without tilting to one side.

#### 5. Compatible cable

Cable O.D.: ø3.5 to ø7

(Reference) 0.5 mm<sup>2</sup>, 2-core or 3-core, equivalent to JIS C 3306



#### **DIN Connector Part No.**


#### Without light

Rated voltage	Voltage symbol	Part no.
All voltages	None	SY100-82-1

#### With light

Rated voltage	Voltage symbol	Part no.
24 VDC	24 V	SY100-82-3-05
12 VDC	12 V	SY100-82-3-06
100 VAC	100 V	SY100-82-2-01
200 VAC	200 V	SY100-82-2-02
110 VAC (115 VAC)	110 V	SY100-82-2-03
220 VAC (230 VAC)	220 V	SY100-82-2-04

### Circuit diagram with light




# Fitting and Silencer Part No. for P, R Ports When Using Valve as an Individual Unit

# Part no. for one-touch fitting for 1(P) port and silencer/one-touch fitting for 3(R) port

Series	(1) One-touch	(2) For 3(R) port	
Series	fitting for 1(P) port	Silencer	One-touch fitting
VQZ100	KQ2H06-M5	AN120-M5	KJS04-M5
VQZ200	KQ2S06-01S	INA-25-46	IN-457-32 (for ø6)
VQZ300	KQ2H08-02S	AN101-01	KQ2H06-01S

The diameter of the above fitting and silencer is the maximum diameter to in the EXH port.







Be sure to read this before handling.


For Safety Instructions and 3 Port Solenoid Valve Precautions, refer to "Precautions for Handling Pneumatic Devices" (M-03-E3A).

#### **One-touch Fittings Replacement**


# **⚠** Caution

The built-in fittings on the manifold can be changed easily. Simply remove the corresponding valve and take out the fitting clip underneath.

Take out the clip with a screwdriver, etc., then replace the fittings. About mounting the fittings, after inserting the fitting until it stops, then put the clip into the prescribed position.



VQZ200: Horizontally clipped to the valve body VQZ100/300: Vertically clipped to the valve body



#### **Precautions**

When pulling the fitting assembly away from the valve base, remove the clip, then connect a tube or plug (KQ2P- $\square\square$ ) with the one-touch fitting and pull it out holding the tube or plug. Do not hold the release bushing to avoid damage.

# **DIN Rail Removal/Mounting**


# **⚠** Caution

## 1. Removing

- Loosen the clamp screw on the (a) side of both ends of the manifold.
- Lift the ⓐ side ➡ of the manifold off the DIN rail and slide it in the direction of the ⓑ side.

#### 2. Mounting

- 1) Catch the hook of the DIN rail bracket on the ⓑ side on the DIN rail.
- Push side (a) onto the DIN rail and tighten the clamp screw. The proper tightening torque for screws is 0.3 to 0.4 N•m.



## **Valve Mounting**

# **⚠** Caution

1. After confirming the gasket is correctly placed under the valve, securely tighten the bolts with the proper torque shown in the table below.

Model	Proper tightening torque	
VQZ100	0.13 to 0.19 N·m	
VQZ200	0.25 to 0.35 N⋅m	
VQZ300	0.5 to 0.7 N⋅m	


Screw

# **VQZ100 Piping Direction Replacement**

# **⚠** Caution

## 1. How to replace the port direction

Fitting and port plug are modules. After removing the clip with a flat head screwdriver, take out the fitting and port plug. The piping direction (side or top) can be altered by exchanging the fitting and port plug. During exchange, insert the fitting and the port plug until they contact the wall, then, insert the clip to specified position.




#### **Precautions**

The clip length for the valve and the base are different. Fitting may detach if the incorrect clip is used.

# 2. Valve piped on top can be operated independently by using PR plate.

(Refer to the below part numbers when placing an order.)



VQZ100-12A (Standard) VQZ100-12B (External pilot type)

\* 2 set screws are included.





#### Record of changes

B edition \* Page 3, 19 Correction of Solenoid Specifications and Flow Characteristics

\* Page 4, 20 Correction of Construction

\* Page 5 to 7, Page 11 to 13, Page 21 to 23, Page 27 to 30

Correction of Dimensions \* Page 34

LX Addition of Made to Order

Safety Instructions Be sure to read "Precautions for Handling Pneumatic Devices" (M-03-E3A) before using.

# **SMC** Corporation

Akihabara UDX 15F, 4-14-1, Sotokanda, Chiyoda-ku, Tokyo 101-0021, JAPAN Phone: 03-5207-8249 Fax: 03-5298-5362 URL http://www.smcworld.pc/

© 2007 SMC Corporation All Rights Reserved

D-DN

1st printing KY printing LX 13500DN Printed in Japan.